

ફાયર એન્ડ ઈમરજન્સી સર્વિસીસ-મહાનગરપાલિકા ભાવનગર

ફા.ઈ.સ.જા.નં ૪૩૭

ફાયર એન્ડ ઈમરજન્સી સર્વિસીસ

મહાનગરપાલિકા

ભાવનગર.

તા:૦૨/૧૨/૨૦૧૯

પ્રતિ,
મરીના કોર્પોરેશન,
પ્લોટ નં.૪૮૭ / A-1,
પ્રભુદાસ તળાવ શિશુવિહાર,
ભાવનગર

વિષય : ફાયર ઓપિનિયન અંગે ફાયરના સાધનો નું ઇન્સ્ટોલેશન કરવા બાબત.
સંદર્ભ : આપની અરજી ૨૬/૧૧/૨૦૧૯

સવિનય સાથ જણાવવાનું કે ઉપરોક્ત વિષય તથા આપના પત્ર સંદર્ભ અનવયે જણાવવાનું કે તમારા માલિકીના પ્લોટનં-૪૮૭/એ-૧ થી એ-૪,૪૮૭ /બી મા ગુજરાત ફાયર પ્રિવેન્શન એન્ડ લાઈફ સેફ્ટી મેસર્સ એક્ટ ૨૦૧૩ અને NBC ની ગાઈડ લાઈન મુજબ નીચે મુજબ ના સાધાનોનું ઇન્સ્ટોલેશન કરવાનું રહેશે ઇન્સ્ટોલેશન થયાબાદ અત્રેના વિભાગ ખાતે જાણકારવાનું રાખશો ત્યારબાદ નિયોમોનુસાર ફાયર NOCઅંગે અત્રે ના વિભાગ ખાતે એપ્લાય થવા નું રાખશો.

- (૧) ફાયર એક્સિગયુસર
- (૨) હોજરીલ હોઝ
- (૩) વેટ રાઈજર
- (૪) હાઇડ્રેન્ટ ફાયર એલાર્મ
- (૫) ૭૫૦૦૦ લીટર અન્ડરગ્રાઉન્ડ ટેંક
- (૬) ૫૦૦૦ લીટર ટેરેશ ટ્રેક
- (૭) જોકી પંપ
- (૮) મેઈન પંપ
- (૯) લિફ્ટ સર્ટી
- (૧૦) ફોર વે ઇનલેટ
- (૧૧) પાર્કિંગમાં સ્પેનકલર

ચીફ ફાયર ઓફીસર
ફાયર એન્ડ ઈમરજન્સી સર્વિસીસ
ભાવનગર મહાનગરપાલિકા



भारतीय विमानपत्तन प्राधिकरण AIRPORTS AUTHORITY OF INDIA

SHRI SALIMBHAI IBRAHIMBHAI GANIYANI

Date: 21-02-2019

231, Madhav Hill Complex, B/h. Bank of
Baroda, Nr. Takteshwar Tarheti Road,
Aksharwadi Road Bhavnagar-364002 C/o. J B
Patel (M) 9426170828, 9825019983

Valid Upto: 20-02-2027

No Objection Certificate for Height Clearance

1. This NOC is issued by Airports Authority of India (AAI) in pursuance of responsibility conferred by and as per the provisions of Govt. of India (Ministry of Civil Aviation) order GSR751 (E) dated 30th Sep. 2015 for Safe and Regular Aircraft Operations.

2. This office has no objection to the construction of the proposed structure as per the following details:

NOC ID :	BHAV/WEST/B/020719/369596
Applicant Name*	Jagdish B Patel
Site Address*	Plot No. 487/A-1 To 487/A-4, 487/B, City Survey No. 1628, 1629, Ward No. 5, Ward Name. Uttar North Krishnanagar, Sheet No. 90, Prabhudash Talav, Village Bhavnagar Taluka Bhavnagar District Bhavnagar, Village Bhavnagar Taluka Bhavnagar District Bhavna, Bhavnagar, Gujarat
Site Coordinates*	72 09 32.68-21 46 39.49, 72 09 33.60-21 46 40.02, 72 09 34.05-21 46 38.22, 72 09 34.58-21 46 38.71
Site Elevation in mtrs AMSL as submitted by Applicant*	10.35 M
Permissible Top Elevation in mtrs Above Mean Sea Level(AMSL)	58.41 M (Restricted)

*As provided by applicant

3. This NOC is subject to the terms and conditions as given below:

a. Permissible Top elevation has been issued on the basis of Site coordinates and Site Elevation submitted by Applicant. AAI neither owns the responsibility nor authenticates the correctness of the site coordinates & site elevation provided by the applicant. If at any stage it is established that the actual data is different, this NOC will stand null and void and action will be taken as per law. The office in-charge of the concerned aerodrome may initiate action under the Aircraft (Demolition of Obstruction caused by Buildings and Trees etc.) Rules, 1994"

b. The Site coordinates as provided by the applicant in the NOC application has been plotted on the street view map and satellite map as shown in ANNEXURE. Applicant/Owner to ensure that the plotted coordinates corresponds to his/her site. In case of any discrepancy, Designated Officer shall be requested for cancellation of the NOC.

c. Airport operator or his designated representative may visit the site (with prior coordination with applicant or owner) to ensure that NOC terms & conditions are complied with.

d. The Structure height (including any superstructure) shall be calculated by subtracting the Site elevation in AMSL from the Permissible Top Elevation in AMSL i.e. Maximum Structure Height = Permissible Top Elevation minus (-) Site Elevation.

e. The issue of the 'NOC' is further subject to the provisions of Section 9-A of the Indian Aircraft Act, 1934 and any notifications issued there under from time to time including the Aircraft (Demolition of Obstruction caused by Buildings and Trees etc.) Rules, 1994.

हवाईअड्डा निदेशक सरदार वल्लभ भाई पटेल अंतर्राष्ट्रीय हवाई अड्डा अहमदाबाद - 380 003 दूरभाष संख्या : 91-79-2286 9211

Airport Director, Sardar Vallabhbhai Patel International Airport, Ahmedabad-380 003 (Gujarat), Telephone - 91-79-2286 9211



भारतीय विमानपत्तन प्राधिकरण AIRPORTS AUTHORITY OF INDIA

f. No radio/TV Antenna, lighting arresters, staircase, Mumtee, Overhead water tank and attachments of fixtures of any kind shall project above the Permissible Top Elevation of 58.41 M (Restricted) (AMSL), as indicated in para 2.

g. Use of oil, electric or any other fuel which does not create smoke hazard for flight operations is obligatory, within 8 KM of the Aerodrome Reference Point.

h. The certificate is valid for a period of 8 years from the date of its issue. One time revalidation without assessment may be allowed, provided construction work has commenced, subject to the condition that such request shall be made within the validity period of the NOC and the delay is due to circumstances which are beyond the control of the developer.

i. No light or a combination of lights which by reason of its intensity, configuration or colour may cause confusion with the aeronautical ground lights of the Airport shall be installed at the site at any time, during or after the construction of the building. No activity shall be allowed which may affect the safe operations of flights.

j. The applicant will not complain/claim compensation against aircraft noise, vibrations, damages etc. caused by aircraft operations at or in the vicinity of the airport.

k. Day markings & night lighting with secondary power supply shall be provided as per the guidelines specified in chapter 6 and appendix 6 of Civil Aviation Requirement Series B Part I Section 4, available on DGCA India website: www.dgca.nic.in

l. The applicant is responsible to obtain all other statutory clearances from the concerned authorities including the approval of building plans. This NOC for height clearances is to ensure the safe and regular aircraft operations and shall not be used as document for any other purpose/claim whatsoever, including ownership of land etc.

m. This NOC has been issued w.r.t. the Civil Airports. Applicant needs to seek separate NOC from Defence, if the site lies within their jurisdiction. Applicants also need to seek clearance from state Govt. as applicable, for sites which lie in the jurisdiction of unlicensed aerodrome as outlined in Rule 13 of GSR751 (E)

n. In case of any discrepancy/interpretation of NOC letter, English version shall be valid.

o. In case of any dispute w.r.t site elevation and/or AGL height, top elevation in AMSL shall prevail.


Chairman NOC Committee

Region Name: WEST

Address: Jt. General Manager Airports Authority
of India, SVP International Airport
Ahmedabad-3800003(Gujrat)

Email ID: nocahm@aai.acro

Contact No: 079-22863396



Name / Designation / Sign with Date	
सहायक महाप्रबंधक (एटीएम-एनओसी)	
Prepared By :	Assistant General Manager (ATM-NOC) सदस्य सचिव (एन ओ सी सी) Member Secretary (NOCC)
Verified By :	भा.वि.प्रा., स.व.प.अ. हवाई अड्डा, अहमदाबाद AAI, S.V.P.I. Airport, Ahmedabad-3

हवाई अड्डा निदेशक सरदार वल्लभ भाई पटेल अंतर्राष्ट्रीय हवाई अड्डा अहमदाबाद - 380 003 दूरभाष संख्या : 91-79-2286 9211
Airport Director, Sardar Vallabhbhai Patel International Airport, Ahmedabad-380 003 (Gujarat), Telephone - 91-79-2286 9211

