



RAJKOT MUNICIPAL CORPORATION

Fire & Emergency Service

Smart City



Dr. Ambedkar Bhavan, Dhebar Road, Rajkot - 360 001. F.No.2227222.

RMC/RFES/Building/NOC/ 686 /2020.

Date. 30.12.2020.

:: FIRE NO OBJECTION CERTIFICATE ::- Ref. No.1.R.M.C.F.B.E.NO.NOC.888, DATE:-23.12.2020.

This is to Fire No Objection Certificate That With Reference to Above Application of Owners Gatrad Home Developers Partners Shree Shaileshbhai Nathubhai Malani and Others Partners, Wing :-A+B. Type of Construction Building:-Frame Structure, Use of Building:-Residence (Dwelling-3), R.S.No.86/P1,2,3, Location :-Jay Ram Park, Kothariya, Rajkot.

Wing: - A. Sub Plot No.15+16+17/1, Building Floor:-G.F. + 5th Floor + Stair, Lift, Height of Building:-0.45+2.80+15.40 M.=18.65 M. Total Plot Area = 204.09 sq.mt. F.S.I. Used= 547.70/204.09 = 2.68 < 2.70.

Wing: - B. Sub Plot No.15+16+17/2, Building Floor:-G.F. + 5th Floor + Stair, Lift, Height of Building:-0.45+2.80+15.40 M.=18.65 M. Total Plot Area = 227.10 sq.mt. F.S.I. Used= 547.70/227.10 = 2.41 < 2.70.

The Building Site Was Inspected by RMC Fire Brigade Fire Station Officers and The Documents Submitted Were Checked and Found Correct on Date:-25.12.2020.

- During inspection of the said premises following system were found adequate and in working condition.

- (1) Fire Hydrant System with Hose Box, Hose Pipe with Nozzle & Hose Reel in Working Condition.
- (2) ABC Fire Extinguishers 6 kg Capacity each floor.
- (3) CO2 Fire Extinguishers 4.5 kg Capacity each floor.
- (4) Fire Pump ON/OFF Switch each floor.
- (5) Ground Floor Fire Sprinklers System.
- (6) Emergency Fire Alarm System each floor.
- (7) Two way fire Service inlet 2 way.
- (8) Fire Man Switch in Fire Lift.

- You are hereby advised to maintain the above system in good working condition.

- (1) The Fire Fighting System to be Maintain perfect working condition all the time.
- (2) In Case of Emergency Fire Safety System must be operated by your trained person immediately.
- (3) The Fire Department of RMC will not be responsible for any loss of life & property Due to Fire/Emergency incident of your premises.
- (4) Electric Wiring must be proper and that Not be Loose and Taped in Building Area.
- (5) Fire Water Tank for fire fighting in Above area.
- (6) Trained man power shall be available for Fire fighting premises round the clock.
- (7) Our fire Certificate is limited to Fire Fighting System available in your premises Only.
- (8) Any other instructions given by fire Department from time to time about fire Safety of the premises to be followed.
- (9) The duration of the Fire N.O.C. is valid up to One Year from the Date of Issue.

Dy. Chief Fire Officer
Fire & Emergency Services
Rajkot Municipal Corporation



Chief Fire Officer
Fire & Emergency Services
Rajkot Municipal Corporation