



AHMEDABAD MUNICIPAL CORPORATION

FIRE & EMERGENCY SERVICE

DANAPITH FIRE STATION, (H. Q.) AHMEDABAD - 380 001

PH. : (079) 22148466 / 67 / 68, 32981178, 32981500 FAX : (079) 22148598.

(No. 340. Dt.:17/11/2015)

To,
Sh. Sanket Vijaybhai Shah,
Prernā farm, in panchwati auto lane,
SG highway, Ahmedabad.

Sub: Fire safety & protection, opinion for a proposed high-rise building
(25 metres) .

Sir,

This is to intimate that , the plans submitted for, Commercial block-E with basement, ground floor + 7 floors. Residential blocks-A,B,C,D with basement + hollow plinth parking & residential + 7 floors. At TP.no.5 (Sanand), FP.no.58, , Survey no.1175/2P/1 + 1175/2P/2, Ahmedabad, have all the required line drawings and write-up required for the fire protection opinion, are as per the requirement of fire prevention and protection.

All norms as per the GDCR (2021) by AUDA have to be followed as far as the construction and Fire Prevention and Protection system, are to be followed.

Moreover, it is required that all the staircases of the building shall be ventilated above the parapet wall at each floor level and shall be 1.5 metres, clear in width.

A motorable road with 40 ton load bearing capacity and minimum 4 metres wide, is required around the building without obstruction to a clear motorable passage for fire/rescue vehicles.


The gate (entry) to the premises shall be minimum 6 meters or more if required, in width, entry gate to be provided on both sides.

The basement parking, hollow plinth parking in all blocks + shops at all levels, shall be sprinklered 1 sprinkler for every 10 sq. Metres.

After, the building is built and all the required Fire safety and Protection equipment have been installed and after due inspection by the Fire service officer an NOC can be issued.

The copies of plans are returned herewith duly signed and have to be submitted during final inspection of the fire fighting system.




(M.F. Dastoor)
Chief Fire Officer