



11418

**SURAT MUNICIPAL CORPORATION
FIRE & EMERGENCY SERVICES
HEAD QUARTERS, MUGLISARA,
SURAT - 395003**

Ph.: S.M.C. : 0261 - 2423750 TO 56, CONTROL : 2414195 -96, FAX : 2451935, 9724345553

Sub:- N.O.C./OPINION Fire& Emergency Services Dept. For High Rise Residential building

Reference:- A Letter from T.D.O Shri bearing No. T.D.O/7213,Dtd.26/03/2018

**PROPOSED SITE :-PROPOSED HIGH RISE LAY OUT PLAN ON T.P.S.NO.24(MOTA-
VARACHHA),F.P.NO.10,O.P.NO.10,BLOCK NO.146,MOJE:MOTA VARACHHA,TA :
(ADAJAN),CITY-SURAT.**

Submitted ,

As per said plan the above building is a High Rise Residential building A,B,C,D,E (Basement +Ground +8 th floor) with Height of 24.55Mtrs.

As per N.B.C.- 2016 The aforesaid Building is to be considered as High Rise Residential building .Hence this dept. Has no-objection if the applicant concerned makes necessary fire fighting arrangement in said building as per N.B.C. Norms. Existing DCR norms. Attached Drawing .

T.D.O.Shri,
For information & further process please.

FES/ OUTWARD/NOC 222.
DT. 30 /04/2018

[Signature]
30-4-18
CHIEF FIRE OFFICER
Surat Municipal Corporation

Received Copy

[Signature]
Clerk T. D. O.
S. M. C.

