



AHMEDABAD MUNICIPAL CORPORATION

FIRE AND EMERGENCY SERVICES DEPARTMENT

Danapith Fire Station (Hqrs.) Nr. AM Corporation, Danapith Ahmedabad-380001.

Phone No: 079 22148466/67/68 Fax No:079 22148598

F.B.No. 140 , Factory NOC

Dt.26/07/2017

NO OBJECTION CERTIFICATE

This is to certify that management of "M/s. M. P. Infra." located at, 20/2, G.I.D.C. Estate. Phase – I, 8, Ahmedabad. unit, has installed necessary Fire Protection equipment.

The Fire Department has NO OBJECTION to the said "M/s. M. P. Infra.", as required level of Fire Protection is provided.

- Fire Extinguishers ;
 - 2 Kg. Capacity Co2 Type Fire Extinguishers. (07 Nos.)
 - 6 Kg. Capacity ABC Type Fire Extinguishers. (50 Nos.)
 - Auto Glow Signs installed in the Building area.

All Extinguishers installed shall be maintained in working order throughout the validity period of this certificate.

The Certificate is valid till 31st July - 2018.

Chief Fire Officer
Ahmedabad Municipal Corporation

