



AHMEDABAD MUNICIPAL CORPORATION

FIRE & EMERGENCY SERVICE

DANAPITH FIRE STATION, (H. Q.) AHMEDABAD - 380 001

PH. : (079) 22148466 / 67 / 68, 32981178, 32981500 FAX : (079) 22148598.

No.149 dt.:15/5/2014

To,
M/s. Savani Infrastructure,
203, Mauriance Ilanza,
132 feet ring rd., Shyamal cross rd.,
Satellite, Ahmedabad.

Sub: Fire safety & protection, opinion for a proposed high-rise buildings.
(45 metres)

Sir,

This is to intimate that , the plans submitted for high-rise, Commercial building with two basements, (upper basement for double level parking) + Ground floor & part hollow plinth parking + 14 floors. at TP.no.3 (Ellis bridge), FP no.114, Ahmedabad, have all the required line drawings and write-up required for the opinion, are as per the requirement of fire prevention and protection.

It is required that all outer staircases of the building shall be ventilated above the parapet wall. Staircase shall be minimum 2 metres wide.

All conditions of the GDR shall be followed.

A motorable road with 40 ton load bearing capacity and minimum 6 metres wide , is required on all sides. There shall be no obstruction to a clear motorable passage for fire/rescue vehicles.

The gate (entry) to the premises shall be minimum 6 meters or more if required, in width, entry gate to be provided on both sides.

The two basements hollow plinth parking and shops at ground floor shall be sprinklered.

The lift and staircase in the basement shall be enclosed in a two hours Fire resistant enclosure along with 2 hrs. Fire rated doors.

After, the building is built and all the required Fire safety and Protection equipment have been installed and after due inspection by the Fire service officer an NOC can be issued.

The copies of plans are returned herewith duly signed and have to be submitted during final inspection of the fire fighting system.



M.F. Dastoor
15/5/14
(M.F.Dastoor)
Chief Fire Officer