



SURAT MUNICIPAL CORPORATION
FIRE & EMERGENCY SERVICES
HEAD QUARTERS, MUGLISARA,
SURAT - 395003

T. D. O.

Inward No. 996

Date 02/05/2019

Ph: S.M.C. : 0261 - 2423750 TO 56, CONTROL : 2414195 -96, FAX : 2451935, 9724345553

Sub:- N.O.C./OPINION Fire & Emergency Services Dept. For High Rise Residential building

Reference:- A Letter from T.D.O Shri bearing No. T.D.O/400, Dt. 30/04/2019

PROPOSED SITE :- REVISED LAYOUT FOR RESIDENTIAL BLDG. 'UNDER AFFORDABLE HOUSING' SCHEME ON T.P.S. NO. 70 (CHHAPRABHATHA-AMROLI-KOSAD-UTRAN), R.S. NO. 49, O.P. NO. 23/A, F.P.NO. 23/A, MOJE. CHHAPRABHATHA, TAL. ADAJAN, DIST. SURAT.

Submitted ,

As per said plan the above building is a High Rise Residential building A-B (Ground + 7th floor) with Height of 24.75 Mtrs.

As per N.B.C.- 2016 The aforesaid Building is to be considered as High Rise Residential Building .Hence this dept. Has no-objection if the applicant concerned makes necessary fire fighting arrangement in said building as per N.B.C. Norms. Existing DCR norms. Attached Drawing .

- (1) The Fire Fighting System to be maintained in perfect working condition all the time.
- (2) In case of Emergency, Fire Safety System must be operated by your trained person immediately to control the situation.
- (3) The Fire dept. of SMC will not be responsible for any loss of life & property due to Fire / Emergency incident in your building premises.
- (4) Trained man-power shall be available for fire fighting & Lift Rescue in the building premises round the clock.
- (5) Any deviations w.r.t.construction shall be verified by the concerned building sanctioning agency.
- (6) The Certificate may not be treated in any case for the regularization of the unauthorised constuction if any.
- (7) Basement shall be used only permissible uses as per CGDCR-2017.
- (8) The entire/exit shall be kept free for any obstruction
- (9) Form 16 from FPCOR at the time of Fire Inspection of building.
- (10) This opinion is given on the basis of submitted drawing / documents only.
- (11) Any other instructions given by fire dept. from time to time about fire safety of the building premises to be followed norms.

T.D.O.Shri,

For information & further process please.

FES/ OUTWARD/NOC/87
DT. 03/05/2019

Divisional Fire Officer

I/C CHIEF FIRE OFFICER
Surat Municipal Corporation



SHAW
3-5-2019