



AHMEDABAD MUNICIPAL CORPORATION

FIRE & EMERGENCY SERVICE

DANAPITH FIRE STATION, (H. Q.) AHMEDABAD - 380 001
PH. : (079) 22148466 / 67 / 68, 32981178, 32981500 FAX : (079) 22148598.

(No.64. Dt.:13/04/2018)

To
Sh. Dipen N. Patel
Sayona Arise,
B/s. Laxmi Sky,
Nr. Dastan Circle, Hanspura,
Ahmedabad.

Sub: Fire safety & protection, opinion for a proposed high-rise building .
(37.50 meters)

Sir.

This is to intimate that , the plans submitted for high-rise Commercial cum Residential building with Block: A - basement parking + ground floor HPP and shops + 1st floor shops & residence + 2nd to 11th floors residence, Block: B/C - basement parking + ground floor HPP + 1st to 11th floors residence. At Sur no,117, F.P.no.76, T.P.no.109 (Muthiya), Ahmedabad have all the required line drawings and write-up required for the opinion, are as per the requirement of fire prevention and protection.

All norms as per the GDCR (2021) by AUDA & Gujarat Fire Prevention & Life Safety Measures ACT, 2013 have to be followed as far as the construction and Fire Prevention and Protection system, are to be followed.

Moreover, it is required that all the staircases of the building shall be ventilated above the parapet wall at each floor level and shall be 2 meters clear in width. The staircase and lift shafts shall not go to the basement but if they go they have to be protected by 4 hours fire resistant construction including the doors.

A motorable road with 40 ton load bearing capacity and 6 metres wide, is required around the building without obstruction to a clear motorable passage for fire/rescue vehicles.

The gate (entry) to the premises shall be minimum 6 meters or more if required, in width, entry gate to be provided on both sides.

The building should have fire Protection system as per approved plans.
• **Basement parking, HPP and shops at all level shall be fully sprinklered.**

After, the building is built and all the required Fire safety and Protection equipment have been installed and after due inspection by the Fire service officer an NOC can be issued.

The copies of plans are returned herewith duly signed and have to be submitted during final inspection of the fire fighting system.



M.F. Dastoor
12/4/18
(M.F.Dastoor)
Chief Fire Officer