

કલેક્ટર અને જિલ્લા મેજિસ્ટ્રેટની કચેરી, સુરત

જિલ્લા સેવા સદન-૨, બી-બ્લોક, પાંચમો માળ, અઠવાલાઇન્સ, સુરત - ૩૯૫૦૦૧ (ગુજરાત)

ફોન નંબર : ૦૨૬૧-૨૬૫૫૧૫૧

ઇ-મેઇલ : collector-sur@gujarat.gov.in

હુકમ નં. 877/22/19/031/2019

તા. 25/09/2019

વંચાણે લીધા :-

(૧) અરજદારશ્રી નિલેશ બાલુભાઇ આહીર

રહે. ૧ જલારામકૃપા બંગલો, કૃષ્ણકુંજ સોસાયટી નજીક, ફુલપાડા સુરત, સુરત-૩૯૫૦૦૮ ની તા. 23/08/2019 ની ઓનલાઇન અરજી તથા સોગંદનામું

(૨) ગુજરાત જમીન મહેસૂલ અધિનિયમ-૧૯૭૯ ની કલમ-૬૫(અ), ૪૮ અને આનુષંગિક નિયમ ઠરાવ અને પરિપત્રોની જોગવાઇઓ.

હુકમ :-

વંચાણે લીધેલ કમ (૧) ની અરજી તથા સોગંદનામા થી અરજદારશ્રી નિલેશ બાલુભાઇ આહીર એ મોજે ડીડોલી તા. ઉધના જિ. સુરત ના સરવે/બ્લોક નં. 164 ના ક્ષેત્રફળ 12,059.00 ચો.મી. પૈકી ક્ષેત્રફળ 7,838.00 ચો.મી ની જમીન અંગે ગુજરાત જમીન મહેસૂલ અધિનિયમ-૧૯૭૯ ની કલમ-૬૫(અ) હેઠળ બિનખેતી હેતુકેરની પરવાનગી મેળવવાની માગણી કરેલ છે.

સવાલવાળી જમીનના ગામ નમૂના નં. ૭/૧૨ માં કબજેદારોની વિગત નીચે મુજબ છે.

સરવે/બ્લોક નંબર ટી.પી. નંબર એફ.પી. નંબર	માંગણીનું ક્ષેત્રફળ (ચો.મી.)	કબજેદારોના નામ (ખાતા નં. 2322)
સરવે/બ્લોક નં. : 164 જુનો સરવે/બ્લોક નં. : --- ટી.પી. નં. : 69 એફ.પી. નં. : 143	7,838.00	મેસર્સ શાંતી કોર્પોરેશન એક ભાગીદારી તરફ અને વતી ભાગીદાર નિલેશ બાલુભાઇ આહીર કેતનભાઇ નારણભાઇ આહીર

સવાલવાળી જમીન અંગેના રજૂ થયેલ રેકર્ડની ચકાસણી કરતાં સદર જમીન હાલમાં બિનખેતી સત્તાપ્રકારે ચાલતી આવે છે. તેમજ અરજદારે સોગંદનામામાં જાહેર કરેલ હકીકત તથા અન્ય આધાર પુરાવાઓ ધ્યાને લેતા મહેસૂલી ટાઇટલ કિલચર હોવાનું જણાય છે. જેથી બિનખેતી હેતુકેરની પરવાનગી આપવાપાત્ર જણાય છે. હુકમના ઉપરોક્ત વંચાણે લીધેલ પત્રમાં જણાવેલ વિગતે અરજદારને રૂપાંતર કર, વિશેષ ધારો તથા અન્ય વેરાની રકમ સરકારશ્રીમાં ભરપાઇ કરવા ઓનલાઇન સિસ્ટમ દ્વારા તેઓને જાણ કરતાં, નીચે જણાવેલ વિગતે ઓનલાઇન સિસ્ટમ દ્વારા અરજદારે નાણા સરકારશ્રીમાં જમા કરાવેલ છે. જે નીચેની વિગતે છે.

કરની વિગત	સદર	માંગણીનું ક્ષેત્રફળ (ચો.મી.)	દર/ તફાવત દર રૂ. પ્રતિ ચો.મી.	કુલ રકમ રૂ.
રૂપાંતર કર	569-0035-00-800-01	7,838.00	40.00	3,13,520.00
વિશેષ ધારો	570-0035-00-101-01	7,838.00	0.60	4,703.00
લોકલ ફંડ	574-0029-00-103-01	7,838.00	0.30	2,351.00
શિક્ષણ ઉપકર	575-0045-00-108-01	7,838.00	0.15	1,176.00
દંડનીય રકમ	570-0035-00-101-01	---	---	1,88,120.00
માપણી ફી	577-0029-00-106-01	7,838.00	---	1,200.00
કુલ રૂ.				5,11,070.00

સબબ, ઉપરોક્ત હકીકત ધ્યાનમાં લેતાં નીચે દર્શાવ્યા મુજબની જમીન અંગે, જમીન મહેસૂલ કાયદાની કલમ-૬૭(ક) હેઠળ નિયમાનુસાર દંડ વસુલ લઈ હુકમમાં જણાવેલ શરતોને આધીન જમીન મહેસૂલ કાયદાની કલમ-૬૫(અ) હેઠળ કાર્યવાહી થયા બાદ સક્ષમ સત્તાધિકારી દ્વારા મળવાપાત્ર બાંધકામના પ્રમાણિત નકશા મુજબ બિનખેતી હેતુકેર કરવા પરવાનગી આપવા આથી હુકમ કરવામાં આવે છે.

-: મોજે: ડીડોલી તાલુકા: ઉધના ની જમીન બિનખેતી હેતુકેર કરવાની વિગત :-

સરવે/બ્લોક નંબર ટી.પી. નંબર એફ.પી. નંબર	જમીનનું ૭/૧૨ મુજબ ક્ષેત્રફળ (ચો.મી.)	અગાઉના હુકમ મુજબ બાંધકામ સહિત બિનખેતી કરવામાં આવેલ જમીનનું ક્ષેત્રફળ (ચો.મી.)	આ હુકમથી બિનખેતી કરવામાં આવેલ જમીનનું ક્ષેત્રફળ (ચો.મી.)
સરવે/બ્લોક નં. : 164 જુનો સરવે/બ્લોક નં. : --- ટી.પી. નં. : 69 એફ.પી. નં.: 143	12,059.00	7,838.00	7,838.00

શરતો : -

- (૧) આ હુકમ મળ્યેથી બે માસમાં "એમ" નમૂનામાં સનદ પ્રાપ્ત થશે.
- (૨) જિલ્લા ઇન્સ્પેક્ટરશ્રી, જમીન રેકર્ડની કચેરીમાં માપણી ફી જમા કરાવેલ છે. જેથી માપણી કરી / કરાવી આ હુકમ આધારે તેમજ મંજૂર થયેલ પ્લાન મુજબ દુરસ્તી પત્રક તૈયાર કરવાનું / કરાવવાનું રહેશે અને દુરસ્તી પત્રકનો મહેસૂલી દફતરે અમલ થયા બાદ જ પ્રશ્નવાળી બિનખેતીની જમીન / પ્લોટનું રજી. દસ્તાવેજથી થયેલ વેચાણ વ્યવહારના અમલ માટે નોંધ પાડવાની રહેશે.
- (૩) અરજદારે પ્રતિ વર્ષે ખેતી સિવાયનો ધારો (વિશેષધારો) દર પ્રતિ ચો.મી. ના રૂ. ૦.૬૦ પ્રમાણે રૂ. ૪,૭૦૩.૦૦ તેમજ નિયમ પ્રમાણે લોકલ ફંડ તથા શિક્ષણ સેસ ભરવો પડશે જે અંગેનો દર વખતે વખત ફેરફારને પાત્ર રહેશે.
- (૪) સુરત મહાનગરપાલિકા એ મંજૂર કરેલા પ્લાન મુજબ બાંધકામ કરવાનું રહેશે અને હુકમ થયા તારીખથી ત્રણ વર્ષમાં બાંધકામ પૂર્ણ કરવાનું રહેશે.
- (૫) સરકારશ્રીના મહેસૂલ વિભાગના ઠરાવ નં. બખપ/૧૦૯૩/૧૦૫૨/ક તા. ૧૩/૦૮/૧૯૯૩ માં ઠરાવ્યા મુજબ સહીયારા / કોમન પ્લોટ અને રસ્તાની જમીન સોસાયટીની માલિકીની અથવા સર્વે પ્લોટ હોલ્ડરની સહીયારી માલિકીની ગણાશે તે ઉપર મુજબ માલિકનો કોઈ હકક રહેશે નહિ.
- (૬) સરકારશ્રીના મહેસૂલ વિભાગના તા. ૦૭/૦૮/૧૯૯૧ ના પરિપત્ર નં. બખપ-૧૦૯૧/૧૭૫૬/ક ની જોગવાઈ મુજબ બિન અધિકૃત બાંધકામ બાબતે બાંધકામ નિયંત્રણ કરતી સંબંધિત મહાનગરપાલિકા / શહેરી વિસ્તાર સત્તા મંડળએ ધોરણસરનાં પગલાં લેવાના રહેશે.
- (૭) સદર જમીનમાંથી પેટ્રોલીયમ / પાણીની કે અન્ય કોઈપણ પ્રકારની પાઇપલાઇન પસાર થતી હશે તો તે સંદર્ભે વિકાસ પરવાનગી આપનાર ઓથોરિટીએ સંબંધિતોનું ના-વાંધા પ્રમાણપત્ર મેળવી વિકાસ પરવાનગી આપવાની રહેશે.
- (૮) સરકારશ્રીનાં મહેસૂલ વિભાગનાં તા. ૦૧/૦૭/૨૦૦૮ ના ઠરાવ નં. બખપ/૧૦૦૬/૪૨૫/ક માં જણાવેલ નીચે મુજબની શરતોનું પાલન કરવાનું રહેશે.
 ૧. જિલ્લા ઇન્સ્પેક્ટરશ્રી, જમીન રેકર્ડ દ્વારા ઇસ્યુ કરાયેલ માપણી શીટ કે જેના ઉપર મૂળ ટિપ્પણની હદ પણ દર્શાવેલ હોવી જોઈએ. રજૂ કરાયેલ પ્લાન તથા લે-આઉટ પ્લાન સક્ષમ કક્ષાએ મંજૂર કરાયેલ હોવી જોઈએ.
 ૨. બાંધકામ શરૂ કરતા પહેલાં બાંધકામનાં નકશા સક્ષમ અધિકારી પાસે મંજૂર કરાવવાના રહેશે. પરંતુ અરજદાર બિનખેતી પરવાનગી મેળવ્યા વગર આવા બાંધકામની રજા ચિઠ્ઠી મેળવી શકશે નહિ.
 ૩. શહેરી વિસ્તાર જ્યાં ટાઉન પ્લાનિંગ સ્કીમ મંજૂર થઈ ગઈ છે ત્યાં જી.ડી.સી.આર. અને ઝોનિંગના નિયમો અનુસાર બાંધકામ કરવાનું રહેશે.
 ૪. મંજૂર થયેલ નકશા મુજબ આરોગ્ય અને સ્વાસ્થ્યની દ્રષ્ટિએ ગંદા પાણીનાં નિકાલની જોગવાઈ કરવાની રહેશે.
 ૫. અરજદારે રિબન ડેવલપમેન્ટ ટ્રસ્ટ નીચે જે તે રસ્તાનો પ્રકાર ધ્યાને લઈ રસ્તાના મધ્યબિંદુથી બાંધકામ વચ્ચે અંતર જાળવવાનું રહેશે અન્યથા અરજદારની જવાબદારી થશે.
 ૬. ફ્લોર, મિલ, સિનેમા/ ટુરિંગ સિનેમા/ થિયેટર માટે બિનખેતી પરવાનગીના કામે જિલ્લા મેજિસ્ટ્રેટની જરૂરી મંજૂરી મેળવી આગળની કાર્યવાહી કરવાની રહેશે.
 ૭. પેટ્રોલ, ડીઝલ, કેરોસીન, સી.એન.જી., એલ.પી.જી. પંપ નાંખવા માટે બિનખેતી પરવાનગીના કામે બાંધકામ શરૂ કરતાં પહેલાં જિલ્લા મેજિસ્ટ્રેટની જરૂરી મંજૂરી મેળવી આગળની કાર્યવાહી કરવાની રહેશે.

૯. ઇન્ડિયન એક્સપ્લોઝિવ એક્ટ અન્વયે મેગેનિઝ, ફાયર વર્ક્સ, દારૂખાના માટે બિનખેતીની કાર્યવાહી કરતા પહેલા જિલ્લા મેજિસ્ટ્રેટની જરૂરી મંજૂરી મેળવી આગળની કાર્યવાહી કરવાની રહેશે.
૯. સવાલવાળી જમીન જો રેલવે હદની નજીક હોય તો રેલવેની હદથી નિયમ મુજબ જગ્યા છોડી બાંધકામ કરવાનું રહેશે.
૧૦. સવાલવાળી જમીન ઉપરથી અથવા બાજુમાંથી વીજળી ગ્રિડના તાર/ હાઇટેન્શન પાવર અગર થાંભલા આવેલ હોય ત્યારે તે અન્વયે લાગુ પડતા નિયમોનું પાલન કરવા અને તે મુજબ બાંધકામ કરવાનું રહેશે.
૧૧. બિનખેતી માંગવામાં આવી હોય તેવી જમીન જો એરોડ્રામ આસપાસ નિયમ મુજબની ત્રિજ્યામાં આવતી હોય ત્યારે બાંધકામની ઉંચાઇ તથા એરોડ્રામની દ્રષ્ટિએ જરૂરી એવું ના-વાંધા પ્રમાણપત્ર સિવિલ એવિએશન ખાતા પાસેથી મેળવવાનું રહેશે અને સિવિલ એવિએશન ખાતાના નિયમોનું પાલન કરવાનું રહેશે.
૧૨. ઓ.એન.જી.સી. ના કુવાની નજીકમાં આવેલ જમીનના કિસ્સામાં અરજદારે સંબંધિત નિયમોનું પાલન કરવાનું રહેશે.
૧૩. નર્મદા કેનાલ/ અન્ય સિંચાઇ કેનાલની નજીકમાં આવેલ જમીનની બાબતમાં અરજદારે સૂચિત બાંધકામ માટે જાળવવાના થતાં અંતર અંગેના નિયમોનું પાલન કરવાનું રહેશે.
૧૪. અરજદારે/ જ્યાં જરૂરી હોય ત્યાં કેન્દ્ર સરકાર કે રાજ્ય સરકારના કાયદા નીચે રક્ષિત સ્મારક (Protected Monuments) તરીકે જાહેર કરેલ પ્રાચીન સ્મારકથી નિયમ મુજબનું અંતર જાળવવાની પ્રવર્તમાન જોગવાઈઓનું પાલન કરવાનું રહેશે.
- (૯) પ્રશ્નવાળી જમીનમાં નગરપાલિકા/ મહાનગરપાલિકા/ શહેરી વિકાસ સત્તા મંડળ દ્વારા જે શરતોએ પરવાનગી આપવામાં આવશે તે શરતોનું પાલન તથા બાંધકામ કરવાનું રહેશે.
- (૧૦) આ જમીનમાં વરસાદી પાણીના ભુગર્ભ વહન/ સંચય માટે દર મકાન/ બહુમાળી મકાન દીઠ એકના દરે આ જમીનમાં ઉપર પરકોલેટીંગ બોરવેલની વ્યવસ્થા અચૂક કરવાની રહેશે તથા વરસાદી પાણીના નિકાલની વ્યવસ્થા કરીને બાંધકામ કરવાનું રહેશે.
- (૧૧) ઉપરની કોઇપણ શરતનો ભંગ થયેથી જમીન મહેસૂલ કાયદાની કલમ-૬૭ મુજબ શિક્ષાત્મક પગલા લેવામાં આવશે તેમજ બીજી કોઇપણ શિક્ષાને પાત્ર હશે તો તેને બાધ આપ્યા સિવાય કે જે ફરમાવવાનું યોગ્ય લાગે તે પ્રમાણે દંડ અથવા આકાર લઇ સદરહુ જમીનનો કબજો કબજેદાર પાસે ચાલુ રહેવા દઇ શકાશે.
- (૧૨) ઉપરોક્ત શરતોમાં ગમે તે મજદૂર હોય તેમ છતાં, કલેક્ટરશ્રી સદરહુ હુકમ વિરૂધ્ધ બાંધેલા અથવા વધારાના કોઇપણ મકાન અથવા ઇમલાને કલેક્ટરશ્રીએ, આ અર્થે જે મુદત ઠરાવી હોય તે મુદત દરમિયાન તેવી રીતે ખસેડવામાં ન આવે કે સૂચવ્યા મુજબ ફેરફાર ન કરવામાં આવે તો તેમ કરવામાં જે ખર્ચ થાય તે કબજેદાર પાસેથી જમીન મહેસૂલની બાકી તરીકે વસુલ કરવાને મુખત્યાર છે.
- (૧૩) મંજૂરી હેઠળની જમીન પરત્વે અલગ અલગ હિસ્સા (સબ પ્લોટ) ના કિસ્સામાં સંબંધિત ડી.ઇ.લે.રે. કચેરીમાં માપણી ફી અલગ અલગ ભરપાઇ કરવાની રહેશે.

વધુમાં ઉપર્યુક્ત શરતોને આધિન અરજદાર દ્વારા રજુ થયેલ સોગંદનામાની વિગતોમાં તેઓ દ્વારા જાહેર કરેલી હકીકતોને આધારે સવાલવાળી જમીનના બિનખેતી ઉપયોગ માટે પરવાનગી આપવામાં આવે છે. તદઅનુસાર સંબંધિત મામલતદારશ્રીએ આ હુકમની ગામના તથા તાલુકાના સંબંધિત રેકર્ડમાં નોંધ, રાખી પ્રતિ વર્ષ વિશેષધારો તથા અન્ય ઉપકર વસુલ કરવાના રહેશે.



રવાના કરવા માટે અધિકૃત

મામલતદાર (બિનખેતી)
કલેક્ટર કચેરી, સુરત

ગાંધી X X X
(ડૉ. ધવલ પટેલ)
કલેક્ટર, સુરત

આર.પી.એ.ડી.

પ્રતિ,

નિલેશ બાલુભાઈ આહીર

૧ જલારામકૃપા બંગલો

કૃષ્ણકુંજ સોસાયટી નજીક

કુલપાડા સુરત

સુરત-૩૯૫૦૦૮

નકલ રવાના:-

૧. નાયબ કલેક્ટરશ્રી, સુરત પ્રાંત, જિ. સુરત તરફ.
૨. મામલતદારશ્રી તા. ઉધના જિ. સુરત તરફ.
૩. જિલ્લા ઇન્સ્પેક્ટરશ્રી જમીન રેકર્ડ સુરત તરફ.
૪. તલાટીશ્રી ડીડોલી તા. ઉધના જિ. સુરત તરફ.

• આ હુકમની ઉ-ધરા કેન્દ્ર, ઉધના માં નોંધ નંબર 2916 થી મોજે.- ડીડોલી તા.- ઉધના જિ.- સુરત માં નોંધ થયેલ છે.





SURAT MUNICIPAL CORPORATION
FIRE & EMERGENCY SERVICES
HEAD QUARTERS, MUGLISARA,
SURAT - 395003

Ph.: S.M.C. : 0261 - 2423750 TO 56, CONTROL : 2414195 -96, FAX : 2451935, 9724345553

Sub :- N.O.C./OPINION Fire & Emergency Services Dept. for High Rise Commercial Building.

Reference :- A letter from Applicant bearing No. FES/N.O.C/INWARD NO.92, Dt.15/06/2020.

PROPOSED SITE :- PROPOSED LAYOUT FOR COMMERCIAL BUILDING ON T.P.S. NO. 69(DINDOLI - GODADRA), BLOCK NO. 164, F.P. NO. 143, SUB PLOT NO-1, O.P. NO. 186, MOJE. DINDOLI, TAL. CITY, DIST. SURAT.

Submitted,

As per said plan the above building is a High Rise Commercial Building-A (Basement + Ground Floor + 4th floor) with Height of 16.46 Mtrs.

The proposal has been considered favorably taking into consideration the following facts that, Subject to satisfactory compliance of the following fire safety requirements :-

As per N.B.C . 2016 the aforesaid buildings are to be considered as High Rise Commercial Building. Hence this dept. has No Objection if the applicant concerned makes necessary fire fighting arrangement in said building as per N.B.C. norms, Existing CGDCR norms, Gujarat Fire Prevention Life Safety Regulation 2017 and Submitted Drawing.

1. The fire department of SMC will not responsible for any loss of life and property due to fire / Emergency incident.
2. Parking shall not be permitted in courtyards and drive ways of fire appliances.
3. Courtyard shall be kept free from encumbrances & encroachments.
4. No structure of any type shall be permitted in courtyard of the building.
5. There shall not be any trees obstructing fire appliances reach in compulsory open spaces required as per CGDCR.
6. The gradient of the ramp shall not be steeper than 1:07.
7. The access provided to the basement shall be kept unobstructed.
8. Repairing/servicing of cars, use of naked light shall not be permitted in the car parking areas.
9. Dwelling, use of naked light / flame, repairing / maintenance of vehicles shall be strictly prohibited in the parking area.
10. The driveways shall be property marked and maintained unobstructed, proper illuminated signage shall be provided for escape route.
11. The top of the podium shall be reinforced suitably to bear the load of fire engine weighing up to 40 M tons each with a point load of 10 kgs/cm. A certificate to that effect issued by structural engineer shall be submitted at the time of NOC for occupation.
12. Car parking shall be permitted in the designated area only.

Page | 1



13. Podium floor shall not be enclosed except for parapet walls.
14. The fins with RCC, brick work, hollow blocks or any such construction materials shall not be permitted.
15. Automatic sprinkler system shall be provided to the entire horizontal car parking area on each podium floor.
16. The driveways shall be properly marked and maintained unobstructed, proper illuminated signage shall be provided for escape route, car lifts, etc. at prominent location.
17. On podium for fire engine movement fixed location shall be unmarked in consultation with C.F.O.'s department for different high reach hydraulic platform & T.T.L. and kept free from any encroachment & easy access shall be maintained for fire brigade vehicles.
18. The layout of staircase shall be enclosed type throughout its height and shall be approached at each floor level by at least two hours fire resistance self closing door.
19. Externally located staircases adequately ventilated to outside air.
20. Permanent vent at the top equal to 5 % of the cross sectional area of the staircase shall be provided.
21. Structural steel members connected to staircase shall be protected with fire retardant coatings.
22. No combustibles shall be kept or stored in staircase / passages.
23. The staircase should not be encroached by shoe-rack, decorative items, earthen pots etc.
24. Walls enclosing lift shaft shall have a fire resistance of not less than two hours.
25. Shaft shall have permanent vent of not less than 0.2 sq. meters in clear area immediately under the machine room.
26. Landing door and lift car door of the lifts shall be of steel shuttered with fire resistance of one hour. No collapsible shutter shall be permitted.
27. The Fire lift shall have a floor area of not less than 1.4 sq. meters it shall have loading capacity of not less than 545 kgs (8 persons lift) with automatic closing doors of minimum 0.8 m. width.
28. The electric supply of fire lift shall be on a separate service from electric supply mains in a building and the cables run in a route safe from fire i.e. within the lift shaft. Light & fans in the elevators having wooden paneling or sheet steel construction shall be operated on 24 volt supply.
29. Fire lift should be provided with a ceiling hatch for use in case for emergency. So that when the car gets stuck up, it shall be easily openable.
30. In case of failure normal electric supply, it shall automatically changeover to alternate supply. For apartment houses, this changeover of supply could be done through manually operated changeover switch. Alternatively, the lift shall be so wired that in case of power failure, it comes down at the ground level and comes to stand-still with door open.
31. The operation of fire lift should be by a simple toggle or two button switch situated in glass-fronted box adjacent to the lift at the entrance level. When the switch is on, landing call point will become inoperative and the lift will be on car control only or on a priority control devices. When the switch is off, the lift will return to normal working. This lift can be used by the occupants in normal times.
32. The words 'fire lift' shall be conspicuously displayed in fluorescent paints on the lift landing doors at each floor level.
33. The speed of the fire lift shall be such that it can reach the top floor from ground level within one minute. Fire lift shall be constructed as per prevailing standard.
34. Corridor / lift lobby at each floor level shall be naturally ventilated as shown in plan for the upper floors.




35. The common corridor / lift lobby at each floor level shall be kept free from obstruction at all times.
36. Self-glowing / fluorescent exit signs in green colour shall be provided showing the means of escape at each floor of building. Portable lights / insta lights shall be provided at strategic location in the staircase and lift lobby.
37. The staircase and corridor lighting shall be on separate circuits and shall be independently connected so that they could be operated by one switch installation on the ground floor easily accessible to fire fighting staff at any time irrespective of the position of the individual control of the light points, if any.
38. Staircase and corridor lighting shall also be connected to alternate supply.
39. Double throw switches shall be installed to ensure that lighting in the staircase and the corridor do not get connected to two sources of supply simultaneously. A double throw switch shall be installed in the service room to terminate the stand-by-supply.
40. Emergency lights shall be provided in the staircase / corridors.
41. Electric cable shaft shall be exclusively used for electric cables and should not be open in staircase enclosure.
42. Electric shaft shall be sealed at each floor level with non-combustible material such as vermiculite concrete. No storage shall be permitted in electric cabin or shaft.
43. Inspection door for the shaft shall have two hours fire resistance.
44. Electric wiring / cable shall be of non-toxic, non-flammable, low smoke hazard having copper core fire resistance for the entire building with provision of ELCB/MCB.
45. Electric meter room shall be provided at location marked on the plans. It shall be adequately ventilated & easily accessible.
46. Electric wiring shall be having copper core having the fire resistance and low smoke hazard cables for the entire building with provision of ELCB/MCB
47. Low and medium voltage wiring running in shaft and in false ceiling should run in separate conduits.
48. Water mains, telephone lines, intercom lines, gas pipes or any other services should not be laid in the duct for electric cable; use of bus bar/solid rising mains instead of cables is preferred.
49. Separate circuits for fire fighting pumps, lifts, staircase and corridor lighting and blowers for pressurizing system shall be provided directly from the main switch gear panel and these circuits shall be laid in separate conduit pipes so that fuse in one circuit will not affect the others. Such circuits shall be protected at origin by an automatic circuit breaker with its no-volt coil removed.
50. Master switches controlling essential services shall be clearly labeled & provide in the lobby for emergency operation.
51. False ceiling if provided in the building shall be of non-combustible material. Similarly, the suspenders of the false ceiling shall be of non-combustible materials.
52. Materials For Interior Decoration / Furnishing :
The use of materials which are combustible in nature and may spread toxic fumes/gases should not be used for interior decoration/furnishing, etc.
53. (A) Basement shall be ventilated naturally & mechanically. Vents with cross, sectional area (Aggregate) not less than 2.5 percent of the floor area spread evenly around the perimeter of the basement shall be provided.
(B) The basement shall be used for designated purpose only as shown in the plan.
54. The staircase of the basement shall be of enclosed type and entry to basement areas



- shall be through two hours higher resistance self closing door provided in the enclosed wall of the staircase and through smoke check/cut off lobby.
55. Mechanical ventilation shall be provided to the basement with 15 air changes per hour with an arrangement to accelerate the rate of air changes to the 30 per hour in the event of a fire emergency.
 56. The ducts of the mechanical ventilation system shall be of substantial metal gauge as per the relevant I.S standard.
 57. The operating switches of the mechanical ventilation shall be located on ground floor with appropriate zonal indication.
 58. Exhaust duct shall be provided to draw out exhaust at ground level of the basement.
 59. Suitable signage's shall be provided in the basement showing exit direction way to exit etc.
 60. Ventilation system shall start automatically on actuation of detector provided in the basement area.
 61. Exhaust duct, mechanical ventilation duct should not pass through exit or entry.
 62. The basement beyond building line shall be paved; suitably to bear the load of fire engines weighing up to 40 m. tones each with point load of 10 kgs. /sq. cms.
 63. Fire drill / evacuation drill :
Fire drill and evacuation drill shall be conducted regularly in accordance with fire safety plan of building at least once in a three month in consultation with Mumbai fire brigade and log of the same shall be maintained.
 64. Signage's :
Self-glowing/fluorescent exit signs in green color shall be provided showing the means of escape of the building.
 65. Fire escape chute : **NOT APPLICABLE.**
 66. Refuge area : **NOT APPLICABLE.**
 67. Basement shall be used only permissible uses as per CGDCR-2017.
 68. The entry /exit shall be kept free for any obstruction.
 69. Astro turf etc. shall not be permitted in the courtyard and in the drive way.
 70. A certificate to the effect that the fire resistance protection has been provided as above shall be furnished from the Structural Engineer/Architect at the time of applying for occupation of the building.
 71. All gaps between floor -slabs and to facade assembly shall be sealed at all levels by approved fire resistant Seal and material of 02 hrs fire rating.
 72. Sprinkler system for glass facade providing full coverage to the glass.
 73. Openable panels shall be provided on each floor and shall be spaced not more than 10 mt apart measured along the external wall from centre to centre of the access opening.
 74. This NOC is issued from fire risk point of view only.
 75. This NOC is subject to approval by High Rise Technical Committee.
 76. Trained man power shall be available for the fire fighting and lift rescue in the building premises round the clock.
 77. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning authority
 78. The certificate may not be treated in any case for regularisation for unauthorised construction if any.
 79. Form 16 from FPCOR to be submitted at the time of fire Inspection of building.
 80. The opinion is given on the basis of submitting drawings /documents only.



81. Any other instructions given by the fire department from time to time about fire safety of the Building premises to be followed norms.
82. Fire officer can check the arrangements of Fire safety at any time, this certificate will be withdrawn without any notice if any deficiency is found.
83. Occupants /Owner should apply for renewal of fire safety certificate 01 Month prior expiry of this certificate.
84. Provision to be made for Helipad at terrace level.
85. Trained officers / security guards :
The trained security / fire supervisor along with trained staff having basic knowledge of firefighting & fix firefighting installation shall be provided / posted in the building. They will be responsible for the following;
- (a) Maintenance of all the first aid firefighting equipment, fixed installations & other firefighting equipment / appliance in good working condition at all times.
 - (b) Imparting training to the occupants of the building in the use of firefighting equipment provided on the premises & keep them informed about fire & other emergency evacuation procedures.
 - (c) To liaise with the city fire brigade on regular & continual basis.
 - (d) The mock drill with the designated fire marshal for any operation of disaster management plan shall be out regularly after occupation as per National Building Code.


15-8-2020
I/C Dy Chief Fire Officer


15/8/2020
I/C CHIEF FIRE OFFICER
Surat Municipal Corporation

FES/ OUTWARD/NOC 49
DT. 15-06-2020

