



RAJKOT MUNICIPAL CORPORATION

Dr. Ambedkar Bhavan, Dhebar Road

Smart City

Fire & Emergency Service

RAJKOT - 360 001.

R.M.C.F.B.NOC.No.250.

Date.17.07.2020.

-:: FIRE NO OBJECTION CERTIFICATE ::-
Reference:-1.R.M.C.F.B.E.NO.NOC.123, DATE:-15.06.2020.

This is to **Residential Building Plan (Dwelling -3)** for **Fire No Objection Certificate** That with Reference to Above Application of Owner **Shree Niteshbhai Laxmanbhai Khunt & Etc. One Building, Type of Construction :-Frame Structure, Use of Building :-Residential (Dwelling -3), Location :- 1, Vishavnagar, Near Patel Boarding, Rajkot, Rev.S.No.404/P, Plot No.56/A+B+C, Ward No.13, T.P.S.No.3 (Rajkot), O.P.No.46/P, F.P.No.157/P, Building Floor: - G.F. + 1st Floor To 5th Floor, Stair Room, Height of Building = 0.450 + 2.950 + 14. 900 =18.3 M. F.S.I. Used = $819.60/313.07 = 2.62 < 2.70$.**

The Building Site Was Inspected by RMC Fire Brigade Fire Station Officers and The Documents Submitted Were Checked and Found Correct on **Date:- 16.07.2020.**

➤ **Fire N.O.C Terms and Conditions.**

1. The Fire Safety Act shall be Followed Where Ever Applicable.
2. **Fire Hydrant System, Fire Hose Reel Hose, Fire Hose Box, Fire Alarm System, Fire Pump, ABC/Co2/DCP Type Fire Extinguishers & Fire Safety Equipments Fire Officer Guideline** are in Area & Etc as Per National Building Code/G.D.C.R.
3. Electric Wiring must be proper and that Not be Loose and Taped in Building Area.
4. There should not be any Obstacle in Exit and Emergency lights in Staircase & Exit Marked by Radium Symbol is Necessary.
5. **Fire Water tank for fire fighting in Above Area. & No Smoking Board in Above Area.**
6. **Emergency Services Like Fire, Medical, Police, Health Telephone Numbers should be list out put on entry point and office room.**



