

કલેક્ટર અને જિલ્લા મેજિસ્ટ્રેટની કચેરી, સુરત

જિલ્લા સેવા સદન-૨, બી-બ્લોક, પાંચમો માળ, અઠવાલાઈન્સ, સુરત - ૩૯૫૦૦૧ (ગુજરાત)

ફોન નંબર : ૦૨૬૧-૨૬૫૫૧૫૧

ઇ-મેઇલ : collector-sur@gujarat.gov.in

હુકમ નં. ૯૪૩/૨૨/૧૮/૦૬૫/૨૦૨૨

તા. ૧૭/૦૫/૨૦૨૨

વંચાણે લીધા :-

(૧) અરજદાર શ્રી મહેબુબભાઈ કાલુભાઈ મહીડા, અમનપાર્ક સોસાયટી, મુ.પો. ખોલવડ, તા. કામરેજ, જી. સુરત-૩૯૪૧૯૦ ની ઓનલાઇન અરજી (નં.62218202102650) તથા સોગંદનામુ

(૨) ગણોત્પાદક કલમ-૪૩ નિયમ-૨૫ (સી)

સરકારશ્રીના મહેસૂલ વિભાગના ઠરાવ ક્રમાંક: નશજ/૧૦૨૦૦૬/૫૩૧/જ (પાર્ટ-૨) તા.૦૪/૦૭/૨૦૦૮

સરકારશ્રીના મહેસૂલ વિભાગના ઠરાવ ક્રમાંક: નશજ/૧૦૨૦૦૬/૫૩૧/જ (પાર્ટ-૨) તા.૦૩/૦૫/૨૦૧૧

સરકારશ્રીના મહેસૂલ વિભાગના ઠરાવ ક્રમાંક: નશજ/૧૦૨૦૦૬/૫૩૧/જ (પાર્ટ-૨) તા.૨૮/૧૨/૨૦૧૫

સરકારશ્રીના મહેસૂલ વિભાગના ઠરાવ ક્રમાંક: એસ/ટીપી/૧૨૨૦૮/૭૬૮/૧૧/હ.૧ તા.૩૧/૦૩/૨૦૧૧

નાયબ કલેક્ટર શ્રી (સ્ટેમ્પ ડ્યુટી) નો તા.૨૯/૦૭/૨૦૨૧ નો અભિપ્રાય

મામલતદાર અને કૃષિપંચ શ્રી (ALT) નો તા.૦૬/૦૮/૨૦૨૧ નો અભિપ્રાય

ડી.આઈ.એલ.આર. શ્રી નો તા.૦૪/૦૮/૨૦૨૧ નો અભિપ્રાય

INCMS પોર્ટલ પરની કેસ વિગત

પ્રસ્તુત પ્રકરણે ચાલેલ કચેરીની કાઇલ નોંધ

હુકમ :-

અરજદાર શ્રી મહેબુબભાઈ કાલુભાઈ મહીડા વગેરેની તા.૨૬/૦૭/૨૦૨૧ ની અરજીથી નીચે જણાવ્યા મુજબની વિગતે હેતુકેરની પરવાનગી આપવા માંગણી કરેલ છે.

તાલુકા/ગામનું નામ	સરવે/બ્લોક નંબર ટી.પી. નં. એફ.પી. નં.	ક્ષેત્રફળ (ચો.મી.)	માંગણી અંગેનું ક્ષેત્રફળ - એફ.પી. મુજબ (ચો.મી.)	હેતુકેર માટેનો પ્રકાર
૧	૨	૩	૪	૫
તાલુકો: પુણા ગામ: સરથાણા	સરવે/બ્લોક નં. : ૨૩ જુનો સરવે/બ્લોક નં. : --- ટી.પી. નં. : ૮૫ સરથાણા-પાસોદરા-લસકાણા એફ.પી. નં.: ૩	4,281.00	2,569.00	બિનખેતી (બહુહેતુક ઉપયોગ)

આમુખ, ની વિગતે નીચે જણાવ્યા મુજબ પ્રિમિયમની રકમ વસુલ લઈ મંજૂરી આપવાની ધાય છે.

અ. નં.	હેતુ	સદર	જમીનની વિગત	ક્ષેત્રફળ (ચો.મી.)	જંત્રી દર પ્રતિ ચો.મી.	કુલ રકમ કો.૫ × કો.૬	પ્રિમિયમનો દર ટકામાં	પ્રિમિયમની રકમ રૂ. કો.૭ × કો.૮
૧	૨	૩	૪	૫	૬	૭	૮	૯
૧	બિનખેતી (બહુહેતુક ઉપયોગ)	૫૬૮- ૦૦૨૯- ૦૦- ૧૦૩- ૦૩	સરવે/બ્લોક નં. : ૨૩ જુનો સરવે/બ્લોક નં. : --- ટી.પી. નં. : ૮૫ સરથાણા-પાસોદરા-લસકાણા એફ.પી. નં.: ૩	2,569.00	7,750.00	199,09,750.00	40%	79,63,900.00

અત્રેથી તા.02/10/2021 થી અરજદારશ્રીને જરૂરી ઉકત પ્રિમિયમની રકમ ભરપાઈ કરવા માટે જણાવવામાં આવેલ. જે પરત્વે તા.11/05/2022 થી તિજોરી અધિકારીશ્રી દ્વારા નીચે જણાવ્યા મુજબની વિગતે પ્રિમિયમની રકમ ભરપાઈ થયેલ છે તેની ચકાસણી કરેલ છે.

તાલુકા/ગામનું નામ	સરવે/બ્લોક નંબર ટી.પી. નં. એફ.પી. નં.	માંગણી અંગેનું ક્ષેત્રફળ - એફ.પી. મુજબ (ચો.મી.)	પ્રિમિયમની રકમ રૂ.	બેંકમાં ચલન ભર્યા તારીખ / નંબર	ટ્રેઝરી અધિકારીશ્રીએ ચલન ચકાસેલ છે કે કેમ ?
૧	૨	૪	૫	૬	૭
તાલુકો: પુણા ગામ: સરથાણા	સરવે/બ્લોક નં. : 23 જુનો સરવે/બ્લોક નં. : --- ટી.પી. નં. : ૮૫ સરથાણા-પાસોદરા-લસકાણા એફ.પી. નં.: 3	2,569.00	79,63,900.00	11/05/2022 57000013551002 906052259456	હા

સબબ આ કામે અરજદારશ્રીની માંગણી મુજબ મોજે: સરથાણા તા. પુણા જી. સુરત ના સરવે/બ્લોક નંબર 23 માં બિનખેતી (બહુહેતુક ઉપયોગ) હેતુ માટે નીચે જણાવ્યા મુજબની શરતોને આધિન હેતુકરની મંજૂરી આપવા આથી હુકમ કરવામાં આવે છે.
શરતો :-

- (૧) આ હુકમથી મંજૂરી આપેલ ક્ષેત્રફળ પુરતી જમીન માટે પ્ર.સ.પ./ નવી શરત શબ્દ દૂર કરવાનો રહેશે.
- (૨) આ હુકમ થયા તારીખથી ૬ માસમાં જમીન મહેસુલ કાયદાની કલમ-૬૫ હેઠળ બિનખેતીની પરવાનગી મેળવવા સક્ષમ અધિકારીશ્રી સમક્ષ માંગણી કરવાની રહેશે.
- (૩) આ જમીન અંગે અરજદારશ્રીએ રજુ કરેલ રેકર્ડ તથા સંબંધીત કચેરીઓ તરફથી રજુ થયેલ રેકર્ડ આધારે હેતુકરની પરવાનગી આપવા અંગેનો નિર્ણય લેવામાં આવેલ છે. જેમાં અરજદારશ્રીની તરફથી જમીનના ટાઈટલ સંબંધી, ક્ષેત્રફળ સંબંધી કોઈ પણ વિગતો છુપાવવામાં આવેલ હશે કે કોઈ પણ કારણોસર સક્ષમ સત્તાઅધિકારીશ્રીઓને વિગતો રજુ કરેલ ન હોય અને પાછળથી સવાલવાળી જમીન અંગે ટાઈટલ સંબંધી કે ક્ષેત્રફળ સંબંધી કોઈ પણ વિવાદ ઉપસ્થિત થશે તો તે અંગેની સંપૂર્ણ જવાબદારી અરજદારશ્રીની રહેશે.
- (૪) આ હુકમ માત્ર ગણોત્તરદાર હેઠળ જમીનના પ્રિમિયમ લેવા બાબત પુરતો કરવામાં આવે છે. અન્ય કાયદાઓ હેઠળ જે પરવાનગીઓ મેળવવાની થતી હોય તેવી તમામ પરવાનગીઓ મેળવવાની રહેશે.
- (૫) આ મંજૂરી ગણોત્તરદાર અંગેની સરકારશ્રીની પ્રવર્તમાન સુચનાઓ, કરાવ તેમજ વખતો વખતની સુચના/ઠરાવોની જોગવાઈઓનું પાલન કરવાની શરતે આપવામાં આવે છે.
- (૬) પ્રશ્નવાળી જમીનના સરવે/બ્લોક નંબર પૈકી બિનખેતીમાં ફેરવાતા ખેતીના હેતુ માટે કોઈ જમીન બાકી રહેતી હોય તો આવી બાકી રહેતી ખેતીની જમીન પરત્વે બિનખેતીના હેતુ માટે પ્રિમિયમને પાત્રના નિયંત્રણો ચાલુ રહે છે. તેવા ગા.ન.નં. ૭/૧૨ માં નાચબ મામલતદારશ્રી (ઈ-ધરા) એ અચૂક નોંધ કરવાની રહેશે. સંબંધિત મહેસુલી અધિકારીએ આવી નોંધ થઈ છે કે નહીં તે સુનિશ્ચિત કરવાનું રહેશે.
- (૭) સરકારશ્રીના મહેસુલ વિભાગના તા. ૦૪/૦૭/૨૦૦૮ ના ઠરાવની જોગવાઈઓ મુજબ પ્રિમિયમ વસુલ લેવાનું રહેશે. ટી.પી. સ્કીમ આખરી થયેથી જો કપાતમાં ઘટાડો થાય તો અરજદાર રીફંડ મેળવવાને હક્કદાર રહેશે નહીં તથા જો વધારો થાય તો વધારા માટેનું જે તે સમયના જંત્રીના દર મુજબ પ્રિમિયમ ભરવાની શરતે મંજૂરી આપવામાં આવે છે.
- (૮) ઉપરની કોઈપણ શરત કે શરતોનો ભંગ થશે અન્યથા અરજદારશ્રી દ્વારા તેવું પાલન કરવાનો ઇન્કાર કરવામાં આવે તેના કિસ્સામાં આ મંજૂરી આપોઆપ રદ થયેલી ગણાશે અને તે ઉપરાંત ગણોત્તરદાર તથા અન્ય લાગુ પડતા કાયદા-નિયમો અન્વયે શિક્ષાત્મક પગલાં લઈ શકાશે.
- (૯) સરકારશ્રીના મહેસુલ વિભાગના પરિપત્ર ક્રમાંક: ગણત-૩ ૨૨૦૦૭-૫૭૭-ઝ તા. ૧૭/૦૨/૨૦૧૨ ની સુચના થી કરેલ જોગવાઈ મુજબ અનુસરતાં આ મંજૂરી મુજબ જે પ્રિમિયમ વસુલ કરવામાં આવે તે એક વર્ષ સુધીના ગાળા માટે જ અમલમાં રહેશે. ત્યારબાદ પ્રવર્તમાન જંત્રીના ભાવ પ્રમાણે પ્રિમિયમ ભરપાઈ કરવાનું રહેશે.
- (૧૦) પ્રશ્નવાળી જમીન અંગે પ્રિમિયમ વસુલ લેવામાં આવેલ છે. જે પ્રિમિયમ ગણતરીમાં ભવિષ્યમાં કોઈ પણ તબક્કે હકીકત દોષ કે ગણતરી દોષ જણાયે નિયમોનુસાર પ્રિમિયમના તફાવતની રકમ ભરપાઈ કરવાની જવાબદારી આ મંજૂરી મેળવનાર/મેળવનારાઓ/ મંજૂરી હેઠળની જમીન ધારણ કરતાંઓની સંયુક્ત અને વ્યક્તિગત બન્ને રીતેની રહેશે. અને/અથવા આ રીતે વસુલ કરવા પાત્ર જણાયેલ સરકારશ્રી પક્ષે બાકી નીકળતી રકમો જમીન મહેસુલની બાકી તરીકે વસુલ કરવાને પાત્ર રહેશે.

- (૧૧) આ પરવાનગીથી જમીનના માલિકી હક્ક બાબતે કોઈ તકરાર ભવિષ્યમાં ઉપસ્થિત થાય તો તેમાં પરવાનગી આપનારની કોઈ જવાબદારી રહેશે નહીં.
- (૧૨) પ્રશ્નવાળી જમીનમાંથી નહેર કે રસ્તો પસાર થતો હોય તો તેના હક્કો યથાવત રહેશે અથવા સક્ષમ અધિકારીની પરવાનગીથી અન્ય વ્યવસ્થા કરવાની રહેશે.
- (૧૩) જો આ જમીન પર કોઈ બેંક/ મંડળીનો બોજો બાકી હોય તો, તે ભરપાઈ કર્યા સિવાય આ મિલકત કોઈપણ પ્રકારે વેચાણ, ભેટ, વસિયત, બાનાખત, ગિરો કરી શકાશે નહિ અને કોઈપણ અન્યને પ્રત્યક્ષ કે પરોક્ષ રીતે માલિકી કે કબજો ભોગવતો તબદીલ કરી શકાશે નહિ.
- (૧૪) ઉપરોક્ત કોઈ પણ શરતના ભંગ બદલ આપવામાં આવેલ પરવાનગી આપોઆપ રદ થયેલ ગણાશે, તથા જમીન તમામ બોજા રહિત સરકાર હસ્તક દાખલ થયેલ ગણાશે.
- (૧૫) ૧. પ્રશ્નવાળી જમીનમાં વિકાસ પરવાનગી આપતા સમયે સક્ષમ સત્તાધિકારીશ્રીએ કાર્યપાલક ઈજનેરશ્રી સિંચાઈ ડિવીઝન-૨ સુરત નું ન વાંધા પ્રમાણપત્ર મેળવવાનું રહેશે. અને તે હિતસંબંધકર્તા તમામને બંધનકર્તા રહેશે.
૨. સવાલવાળી જમીનમાં સુરત શહેરી વિકાસ સત્તામંડળ/સુરત મહાનગરપાલિકાના એક-ફોર્મમાં જણાવેલ એક.પી. મુજબના ક્ષેત્રફળ પુરતી હેતુકેર-બિનખેતીની પરવાનગી આપવામાં આવેલ છે. સદરહું હુકમની નોંધ પ્રમાણિત કરનાર અધિકારીએ તે સીવાયની બાકી રહેતી જમીન અંગે ૭/૧૨ ના બીજા હક્કમાં "સુરત શહેરી વિકાસ સત્તામંડળ/સુરત મહાનગરપાલિકા હેઠળની કપાત" તે મુજબની નોંધ કરવાની રહેશે.

હુકમનો અમલ ગામ દફતરે કરવો.

માન. કલેક્ટરશ્રીના આદેશાનુસાર

નાયબ કલેક્ટર (મ.સુ.)
સુરત.



સહી/-XXX
(આયુષ ઓફ)
કલેક્ટર, સુરત

આર.પી.એ.ડી.

પ્રતિ,

મહેસૂલભાઈ કાલુભાઈ મહીડા

અમનપૂર્ક સોસાયટી

મુ.પો. ખોલવડ

તા. કામરેજ

જી. સુરત-૩૯૪૧૯૦

નકલ સવિનય જાણ સારું રવાના :- નાયબ સચિવશ્રી, મહેસૂલ વિભાગ, "ઝ" શાખા, નવા સચિવાલય, ગાંધીનગર તરફ.

નકલ રવાના :-

નાયબ કલેક્ટરશ્રી, સુરત પ્રાંત, જિ. સુરત તરફ.

૨/- જાણ થવા સારું.

મામલતદારશ્રી તા. પુણા જિ. સુરત તરફ.

૨/- હુકમનો અમલ ગામ દફતરે રેકર્ડ ઓફ રાઈટ્સ મુજબ કરાવવા સારું.

ઈ-ધરા કેન્દ્ર, નાયબ મામલતદારશ્રી તા. પુણા જિ. સુરત તરફ.

૨/- હુકમનો અમલ ગામ દફતરે રેકર્ડ ઓફ રાઈટ્સ મુજબ કરાવવા સારું.

જિલ્લા ઈન્સ્પેક્ટરશ્રી જમીન રેકર્ડ સુરત તરફ.

૨/- રેકર્ડમાં દુરસ્તીની કાર્યવાહી કરવા સારું.

તલાટીશ્રી સરથાણા તા. પુણા જિ. સુરત તરફ.

૨/- સંબંધિત નવી શરતનાં રજીસ્ટરને હુકમ મુજબ અદ્યતન કરવા સારું

રેકર્ડકીપરશ્રી, કલેક્ટર કચેરી, સુરત તરફ.

૨/- જાણ તથા સિલેક્ટ ફાઇલ નિભાવવા સારું.

* આ હુકમની ઇ-ધરા કેન્દ્ર, પુણા માં નોંધ નંબર 6612 થી મોજે.- સરથાણા તા.- પુણા જિ.- સુરત માં નોંધ થયેલ છે.

કલેક્ટર અને જિલ્લા મેજિસ્ટ્રેટની કચેરી, સુરત

જિલ્લા સેવા સદન-૨, બી-બ્લોક, પાંચમો માળ, અઠવાલાઇન્સ, સુરત - ૩૯૫૦૦૧ (ગુજરાત)

ફોન નંબર : ૦૨૬૧-૨૬૫૫૧૫૧

ઇ-મેઇલ : collector-sur@gujarat.gov.in

ગુજરાત જમીન મહેસૂલ અધિનિયમ-૧૯૭૯ ની કલમ-૬૫ હેઠળ [બિનખેતી - બહુહેતુક ઉપયોગ]

ફકમ નં. 962/22/18/065/2022

તા. 19/05/2022

વંચાણે લીધા :-

- (૧) અરજદારશ્રી મહેબુબભાઈ કાલુભાઈ મહીડા
રહે. અમનપાર્ક સોસાયટી, મુ.પો. ખોલવડ, તા. કામરેજ, જી. સુરત-૩૯૪૧૯૦ ની તા.૨૬/૦૭/૨૦૨૧ ની ઓનલાઇન અરજી
(નં.62218202102650) તથા સોગંદનામું
- (૨) મુંબઈ જમીન મહેસૂલ કાયદો ૧૯૭૯ ની કલમ - ૪૮, ૬૫, ૬૬ તથા ૬૭
- (૩) ગુજરાત જમીન મહેસૂલ નિયમો, ૧૯૭૨ ના નિયમ ૮૧, ૧૦૦, ૧૦૧, ૧૦૨
- (૪) સરકારશ્રીના મહેસૂલ વિભાગનાં ઠરાવ નં. બખપ/૧૦૦૬/૪૨૫/ક તા.૦૧/૦૭/૨૦૦૮
- (૫) સરકારશ્રીના મહેસૂલ વિભાગનાં પરિપત્ર ક્રમાંક-બખપ/૧૦૨૦૧૮/૩૨૭/ક તા.૦૮/૦૫/૨૦૧૮
- (૬) સરકારશ્રીના મહેસૂલ વિભાગના ઠરાવ ક્રમાંક: એસ/ટીપી/૧૨૨૦૯/૭૬૯/૧૧/હ.૧ તા.૩૧/૦૩/૨૦૧૧
- (૭) સરકારશ્રીના મહેસૂલ વિભાગનાં ઠરાવ ક્રમાંક: બખપ/૧૦૨૦૧૮/૪૨૫/ક તા.૦૯/૦૧/૨૦૧૯
- (૮) સરકારશ્રીના મહેસૂલ વિભાગનાં પરિપત્ર ક્રમાંક: બખપ/૧૦૨૦૧૮/૪૨૫/ક તા.૧૨/૦૨/૨૦૧૯
- (૯) નાયબ કલેક્ટર શ્રી (સ્ટેમ્પ ડ્યુટી) નો તા.૨૯/૦૭/૨૦૨૧ નો અભિપ્રાય
મામલતદાર અને કૃષિપંચ શ્રી (ALT) નો તા.૦૬/૦૮/૨૦૨૧ નો અભિપ્રાય
ડી.આઈ.ચેલ.આર. શ્રી નો તા.૦૪/૦૮/૨૦૨૧ નો અભિપ્રાય

(૧૦) IRCMS પોર્ટલ પરની કેસ વિગત

ફકમ :-

વંચાણે લીધેલ કમ (૧૦) ની અરજી તથા સોગંદનામા થી અરજદારશ્રી મહેબુબભાઈ કાલુભાઈ મહીડા એ મોજે સરથાણા તા. પુણા જિ. સુરત ના સરવે/બ્લોક નં. ૨૩ ના ક્ષેત્રફળ ૪,૨૮૧.૦૦ ચો.મી. પૈકી ક્ષેત્રફળ ૨,૫૬૯.૦૦ ચો.મી ની જમીન અંગે ગુજરાત જમીન મહેસૂલ અધિનિયમ-૧૯૭૯ ની કલમ-૬૫ હેઠળ બિનખેતીના હેતુ માટે પરવાનગી આપવા વિનંતી કરેલ છે.
સવાલવાળી જમીનના ગામ નમૂના નં. ૭/૧૨ માં કબજેદારોની વિગત નીચે મુજબ છે.

સરવે/બ્લોક નંબર જી.પી. નંબર એફ.પી. નંબર	માંગણીનું ક્ષેત્રફળ (ચો.મી.)	કબજેદારોના નામ (ખાતા નં. ૨૦૧૨)	જમીનનો સત્તાપ્રકાર (૭/૧૨ મુજબ)
સરવે/બ્લોક નં. : ૨૩ જુનો સરવે/બ્લોક નં. : --- ટી.પી. નં. : ૮૫ સરથાણા-પાસોદરા-લસકાણા એફ.પી. નં. : ૩	૨,૫૬૯.૦૦	મેહબુબભાઈ કાલુભાઈ મહીડા	પ્ર.સ.પ્ર.

૩. વસુલ કરવામાં આવેલ કરવેરાની વિગત નીચે મુજબ છે.

બેકમાં ચલન ભર્યા તા.૧૮/૦૫/૨૦૨૨ નં.૬૭૦૦૦૦૧૩૫૬૧૦૦૩૫૧૦૫૨૨૪૦૯૪૪

કરની વિગત	સદર	માંગણીનું ક્ષેત્રફળ (ચો.મી.)	દર રૂ. પ્રતિ ચો.મી.	કુલ રકમ રૂ.
રૂપાંતર કર	૬૬૯-૦૦૩૬-૦૦-૮૦૦-૦૧	૨,૫૬૯.૦૦	૪૦.૦૦	૧,૦૨,૭૬૦.૦૦
વિશેષ ધારો	૬૭૦-૦૦૩૬-૦૦-૧૦૧-૦૧	૨,૫૬૯.૦૦	૦.૬૬	૧,૬૭૦.૦૦
લોકલ ફંડ	૬૭૪-૦૦૨૯-૦૦-૧૦૩-૦૧	૨,૫૬૯.૦૦	૦.૩૦	૭૭૧.૦૦
શિક્ષણ ઉપકર	૬૭૬-૦૦૪૬-૦૦-૧૦૮-૦૧	૨,૫૬૯.૦૦	૦.૧૬	૩૮૬.૦૦
માપણી ફી	૬૭૭-૦૦૨૯-૦૦-૧૦૬-૦૧	૨,૫૬૯.૦૦	---	૧,૨૦૦.૦૦
			કુલ રૂ.	૧,૦૬,૭૮૬.૦૦

૪. ઉપર્યુક્ત તમામ હકીકતો ધ્યાને લઈ મોજે સરથાણા તા. પુણા જિ. સુરત ના સરવે/બ્લોક નં. ૨૩ ના ક્ષેત્રફળ ૪,૨૮૧.૦૦ ચો.મી. પૈકી ક્ષેત્રફળ ૨,૫૬૭.૦૦ ચો.મી ની જમીનને નીચે જણાવેલ શરતોને આધિન ગુજરાત જમીન મહેસૂલ અધિનિયમ-૧૯૭૯ ની કલમ-૬૫ હેઠળ બિનખેતી હેતુ (બહુહેતુક ઉપયોગ) માટે પરવાનગી આપવા આથી હુકમ કરવામાં આવે છે.

શરતો :-


- (૧) આ હુકમ મળ્યેથી બે માસમાં "એમ" નમૂનામાં સનદ પ્રાપ્ત થશે.
- (૨) જિલ્લા ઇન્સ્પેક્ટરશ્રી, જમીન રેકર્ડની કચેરીમાં માપણી ફી જમા કરાવેલ છે. જેથી માપણી કરી / કરાવી આ હુકમ આધારે તેમજ મંજૂર થયેલ પ્લાન મુજબ દુરસ્તી પત્રક તૈયાર કરવાનું / કરાવવાનું રહેશે અને દુરસ્તી પત્રકનો મહેસૂલી દફતરે અમલ થયા બાદ જ પ્રશ્નવાળી બિનખેતીની જમીન / પ્લોટનું રજી. દસ્તાવેજથી થયેલ વેચાણ વ્યવહારના અમલ માટે નોંધ પાડવાની રહેશે.
- (૩) અરજદારે પ્રતિ વર્ષે ખેતી સિવાયનો ધારો (વિશેષધારો) દર પ્રતિ ચો.મી. ના રૂ. ૦.૬૫ પ્રમાણે રૂ. ૧,૬૭૦.૦૦ તેમજ નિયમ પ્રમાણે લોકલ ફંડ તથા શિક્ષણ સેસ ભરવો પડશે જે અંગેનો દર વખતે વખત ડેરફારને પાત્ર રહેશે.
- (૪) સુરત મહાનગરપાલિકા એ મંજૂર કરેલા પ્લાન મુજબ બાંધકામ કરવાનું રહેશે.
- (૫) સરકારશ્રીના મહેસૂલ વિભાગના ઠરાવ નં. બખપ/૧૦૯૩/૧૦૫૨/ક તા. ૧૩/૦૯/૧૯૯૩ માં ઠરાવ્યા મુજબ સહીયારા / કોમન પ્લોટ અને રસ્તાની જમીન સોસાયટીની માલિકીની અથવા સર્વે પ્લોટ હોલ્ડરની સહીયારી માલિકીની ગણાશે તે ઉપર મુજબ માલિકનો કોઇ હકક રહેશે નહિ.
- (૬) સરકારશ્રીના મહેસૂલ વિભાગના તા. ૦૭/૦૮/૧૯૯૧ ના પરિપત્ર નં. બખપ-૧૦૯૧/૧૭૫૬/ક ની જોગવાઈ મુજબ બિન અધિકૃત બાંધકામ બાબતે બાંધકામ નિયંત્રણ કરતી સંબંધિત મહાનગરપાલિકા / શહેરી વિસ્તાર સત્તા મંડળએ ધોરણસરનાં પગલાં લેવાનાં રહેશે.
- (૭) સંદર જમીનમાંથી પેટ્રોલીયમ / પાણીની કે અન્ય કોઇપણ પ્રકારની પાઇપલાઇન પસાર થતી હશે તો તે સંદર્ભે વિકાસ પરવાનગી આપનાર ઓથોરિટીએ સંબંધિતો ના-વાંધા પ્રમાણપત્ર મેળવી વિકાસ પરવાનગી આપવાની રહેશે.
- (૮) સરકારશ્રીના મહેસૂલ વિભાગના તા. ૧૨/૦૨/૨૦૧૯ ના પરિપત્ર નં. બખપ/૧૦૨૦૧૮/૪૨૫/ક મુજબની નીચેની શરતોનું પાલન કરવાનું રહેશે.
 ૧. જો અગાઉ ચોક્કસ હેતુ માટે પ્રિમિયમ ભરપાઇ થયેલ હોય અને અન્ય હેતુ માટે વિકાસ પરવાનગી માંગેલ હોય/ નકશા મંજૂર કરવાના થતા હોય તો વિકાસ પરવાનગી આપતાં પહેલાં પ્રિમિયમ તફાવત ભરાયાની સંબંધિત સત્તામંડળ ખાતરી કરવાની રહેશે અને ત્યારબાદ જ વિકાસ પરવાનગી આપવાની રહેશે.
 ૨. જીડીસીઆર મુજબ જે તે હેતુ/ ઉપયોગ માટે પરવાનગી મળવાપાત્ર નહિં હોય તો તે ઉપયોગ કરી શકાશે નહિં.
 ૩. ખેતી ઝોનમાં જીડીસીઆર મુજબ જેટલું બાંધકામ મળવાપાત્ર હશે તેટલા જ ક્ષેત્રફળ માટે વિકાસ પરવાનગી આપવાની રહેશે.
 ૪. બિનખેતી પરવાનગી મળ્યા બાદ જો ખાસ મંજૂરી વિના ધાર્મિક ઉપયોગ માટે બાંધકામ કરેલ હશે તો તે શરતભંગ ગણાશે અને તે બાંધકામ દૂર કરવાપાત્ર થશે.
- (૯) સરકારશ્રીનાં મહેસૂલ વિભાગનાં તા. ૦૧/૦૭/૨૦૦૮ ના ઠરાવ નં. બખપ/૧૦૦૬/૪૨૫/ક માં જણાવેલ નીચે મુજબની શરતોનું પાલન કરવાનું રહેશે.
 ૧. જિલ્લા ઇન્સ્પેક્ટરશ્રી, જમીન રેકર્ડ દ્વારા ઇસ્યુ કરાયેલ માપણી શીટ કે જેના ઉપર મૂળ ટિપ્પણની હદ પણ દર્શાવેલ હોવી જોઇએ. રજૂ કરાયેલ પ્લાન તથા લે-આઉટ પ્લાન સક્ષમ કક્ષાએ મંજૂર કરાયેલ હોવી જોઇએ.
 ૨. બાંધકામ શરૂ કરતા પહેલાં બાંધકામનાં નકશા સક્ષમ અધિકારી પાસે મંજૂર કરાવવાનાં રહેશે. પરંતુ અરજદાર બિનખેતી પરવાનગી મેળવ્યા વગર આવા બાંધકામની રજા ચિઠ્ઠી મેળવી શકશે નહિ.
 ૩. શહેરી વિસ્તાર જ્યાં ટાઉન પ્લાનિંગ સ્કીમ મંજૂર થઇ ગઇ છે ત્યાં જી.ડી.સી.આર. અને ઝોનિંગના નિયમો અનુસાર બાંધકામ કરવાનું રહેશે.
 ૪. મંજૂર થયેલ નકશા મુજબ આરોગ્ય અને સ્વાસ્થ્યની દ્રષ્ટિએ ગંદા પાણીનાં નિકાલની જોગવાઈ કરવાની રહેશે.
 ૫. અરજદારે રિબન ડેવલપમેન્ટ રુલ્સ નીચે જે તે રસ્તાનો પ્રકાર ધ્યાને લઈ રસ્તાના મધ્યબિંદુથી બાંધકામ વચ્ચે અંતર જાળવવાનું રહેશે અન્યથા અરજદારની જવાબદારી થશે.
 ૬. ફ્લોર, મિલ, સિનેમા/ દુકાન સિનેમા/ થિયેટર માટે બિનખેતી પરવાનગીના કામે જિલ્લા મેજિસ્ટ્રેટની જરૂરી મંજૂરી મેળવી આગળની કાર્યવાહી કરવાની રહેશે.
 ૭. પેટ્રોલ, ડીઝલ, કેરોસીન, સી.એન.જી., એલ.પી.જી. પંપ નાંખવા માટે બિનખેતી પરવાનગીના કામે બાંધકામ શરૂ કરતાં પહેલાં જિલ્લા મેજિસ્ટ્રેટની જરૂરી મંજૂરી મેળવી આગળની કાર્યવાહી કરવાની રહેશે.
 ૮. ઇન્ડિયન એક્સપ્લોઝિવ એક્ટ અન્વયે મેગેનિઝ, ફાયર વર્ક્સ, દારૂખાના માટે બિનખેતીની કાર્યવાહી કરતા પહેલાં જિલ્લા મેજિસ્ટ્રેટની જરૂરી મંજૂરી મેળવી આગળની કાર્યવાહી કરવાની રહેશે.
 ૯. સવાલવાળી જમીન જો રેલવે હદની નજીક હોય તો રેલવેની હદથી નિયમ મુજબ જગ્યા છોડી બાંધકામ કરવાનું રહેશે.

૧૦. સવાલવાળી જમીન ઉપરથી અથવા બાજુમાંથી વીજળી ગ્રિડના તાર/ હાઇટેન્શન પાવર અગર થાંભલા આવેલ હોય ત્યારે તે અન્વયે લાગુ પડતા નિયમોનું પાલન કરવા અને તે મુજબ બાંધકામ કરવાનું રહેશે.
૧૧. બિનખેતી માંગવામાં આવી હોય તેવી જમીન જો એરોડ્રામ આસપાસ નિયમ મુજબની ત્રિજ્યામાં આવતી હોય ત્યારે બાંધકામની ઉંચાઇ તથા એરોડ્રામની દ્રષ્ટિએ જરૂરી એવું ના-વાંધા પ્રમાણપત્ર સિવિલ એવિએશન ખાતા પાસેથી મેળવવાનું રહેશે અને સિવિલ એવિએશન ખાતાના નિયમોનું પાલન કરવાનું રહેશે.
૧૨. ઓ.એન.જી.સી. ના કુવાની નજીકમાં આવેલ જમીનના કિસ્સામાં અરજદારે સંબંધિત નિયમોનું પાલન કરવાનું રહેશે.
૧૩. નર્મદા કેનાલ/ અન્ય સિંચાઇ કેનાલની નજીકમાં આવેલ જમીનની બાબતમાં અરજદારે સૂચિત બાંધકામ માટે જાળવવાના થતાં અંતર અંગેના નિયમોનું પાલન કરવાનું રહેશે.
૧૪. અરજદારે/ જ્યાં જરૂરી હોય ત્યાં કેન્દ્ર સરકાર કે રાજ્ય સરકારના કાયદા નીચે રક્ષિત સ્મારક (Protected Monuments) તરીકે જાહેર કરેલ પ્રાચીન સ્મારકથી નિયમ મુજબનું અંતર જાળવવાની પ્રવર્તમાન જોગવાઈઓનું પાલન કરવાનું રહેશે.
- (૧૦) જો આ જમીન પર કોઇ બેંક/ મંડળીનો બોજો બાકી હોય તો, તે ભરપાઇ કર્યા સિવાય આ મિલકત કોઇપણ પ્રકારે વેચાણ, ભેટ, વસિયત, બાનાખત, ગિરો કરી શકાશે નહિ અને કોઇપણ અન્યને પ્રત્યક્ષ કે પરોક્ષ રીતે માલિકી કે કબજો ભોગવતો તબદીલ કરી શકાશે નહિ.
- (૧૧) પ્રશ્નવાળી જમીનમાં નગરપાલિકા/ મહાનગરપાલિકા/ શહેરી વિકાસ સત્તા મંડળ દ્વારા જે શરતોએ પરવાનગી આપવામાં આવશે તે શરતોનું પાલન તથા બાંધકામ કરવાનું રહેશે.
- (૧૨) આ જમીનમાં વરસાદી પાણીના ભુગર્ભ વહન/ સંચય માટે દર મકાન/ બહુમાળી મકાન દીઠ એકના દરે આ જમીનમાં ઉપર પરકોલેટીંગ બોરવેલની વ્યવસ્થા અચૂક કરવાની રહેશે તથા વરસાદી પાણીના નિકાલની વ્યવસ્થા કરીને બાંધકામ કરવાનું રહેશે.
- (૧૩) પ્રશ્નવાળી જમીનમાં સ્થળે થયેલ બાંધકામ સ્થાનિક સ્વરાજની સંસ્થાના નિયમોનુસાર નહિ હોય તો સ્થાનિક સ્વરાજની સંસ્થા નિયમોનુસાર કાર્યવાહી કરી શકશે. તેમાં આ હુકમથી બાધ આવશે નહિ.
- અરજદારે ઉપરોક્ત શરતોનું પાલન કરવાનું રહેશે. જો તેમાં નિષ્ફળ જશે તો શરતભંગ ગણી સક્ષમ અધિકારી કાયદેસરની કાર્યવાહી કરશે.
- (૧૪) ઉપરની કોઇપણ શરતનો ભંગ થયેથી જમીન મહેસૂલ કાયદાની કલમ-૬૭ મુજબ શિક્ષાત્મક પગલા લેવામાં આવશે તેમજ બીજી કોઇપણ શિક્ષાને પાત્ર હશે તો તેને બાધ આપ્યા સિવાય કે જે ફરમાવવાનું યોગ્ય લાગે તે પ્રમાણે દંડ અથવા આકાર લઇ સદરહુ જમીનનો કબજો કબજેદાર પાસે ચાલુ રહેવા દઇ શકાશે.
- (૧૫) ઉપરોક્ત શરતોમાં ગમે તે મજફૂર હોય તેમ છતાં, કલેક્ટરશ્રી સદરહુ હુકમ વિરુદ્ધ બાંધેલા અથવા વધારાના કોઇપણ મકાન અથવા ઇમાલને કલેક્ટરશ્રીએ, આ અર્થે જે મુદત ઠરાવી હોય તે મુદત દરમિયાન તેવી રીતે ખસેડવામાં ન આવે કે સૂચવ્યા મુજબ ફરફાર ન કરવામાં આવે તો તેમ કરવામાં જે ખર્ચ થાય તે કબજેદાર પાસેથી જમીન મહેસૂલની બાકી તરીકે વસૂલ કરવાને મુખત્યાર છે.
- (૧૬) ૧. પ્રશ્નવાળી જમીનમાં વિકાસ પરવાનગી આપતા સમયે સક્ષમ સત્તાધિકારીશ્રીએ કાર્યપાલક ઈજનેરશ્રી સિંચાઈ ડિવીઝન-૨ સુરત નું નાં વાંધા પ્રમાણપત્ર મેળવવાનું રહેશે. અને તે હિતસંબંધકર્તા તમામને બંધનકર્તા રહેશે.
૨. સવાલવાળી જમીનમાં સુરત શહેરી વિકાસ સત્તામંડળ/સુરત મહાનગરપાલિકાના એફ-ફોર્મમાં જણાવેલ એફ.પી. મુજબના ક્ષેત્રફળ પુરતી હેતુકેર-બિનખેતીની પરવાનગી આપવામાં આવેલ છે. સદરહુ હુકમની નોંધ પ્રમાણિત કરનાર અધિકારીએ તે સીવાયની બાકી રહેતી જમીન અંગે ૭/૧૨ ના બીજા હક્કમાં "સુરત શહેરી વિકાસ સત્તામંડળ/સુરત મહાનગરપાલિકા હેઠળની કપાત" તે મુજબની નોંધ કરવાની રહેશે.

વધુમાં ઉપર્યુક્ત શરતોને આધીન અરજદાર દ્વારા રજુ થયેલ સોગંદનામાની વિગતોમાં તેઓ દ્વારા જાહેર કરેલી હકીકતોને આધારે સવાલવાળી જમીનના બિનખેતી ઉપયોગ માટે પરવાનગી આપવામાં આવે છે.

આર.પી.એ.ડી.
પ્રતિ,
મહેબૂબભાઈ કાલુભાઈ મહીડા

આ.પી.એ.ડી.
પ્રતિ,
મહેબૂબભાઈ કાલુભાઈ મહીડા



સહી-XXX
(આધુષ ઓફિસ)
કલેક્ટર, સુરત

અમનપાર્ક સોસાયટી

મુ.પો. ખોલવડ

તા. કામરેજ

જી. સુરત-394190

નકલ રવાના:-

૧. મુખ્ય અધિકારીશ્રી, સુરત મહાનગરપાલિકા
૨. મામલતદારશ્રી તા. પુણા જિ. સુરત (હુકમનો અમલ ગામ દફતરે રેકર્ડ ઓફ રાઈટ્સ મુજબ કરાવવા સારું.)
૩. જિલ્લા ઇન્સ્પેક્ટરશ્રી જમીન રેકર્ડ જિ. સુરત
૪. તલાટીશ્રી સરથાણા તા. પુણા જિ. સુરત તરફ.
૫. હજુર રેકર્ડ કીપરશ્રી, રેકર્ડ શાખા કલેક્ટર કચેરી સુરત

* આ હુકમની ઇ-ધરા કેન્દ્ર, પુણા માં નોંધ નંબર 6615 થી મોજે.- સરથાણા તા.- પુણા જિ.- સુરત માં નોંધ થયેલ છે.





भारतीय विमानपत्तन प्राधिकरण AIRPORTS AUTHORITY OF INDIA

Date: 08-02-2023

PRASHANTKUMAR BATUKBHAI DUDHAT

85, JAMNA PARK SOCIETY,
SINGANPORE, SURAT

System Generated Auto Assessment for Height Clearance

1. Airports Authority of India (AAI) in pursuance of responsibility conferred by and as per the provisions of Govt. of India (Ministry of Civil Aviation) order GSR 751 (E) dated 30th Sep. 2015 for Safe and Regular Aircraft Operations has assessed the site data filled by the applicant.

2. Assessment details for Height Clearance:

NOC ID :	SURA/WEST/B/020423/740198
Applicant Name*	Sanjay I dholakiya
Site Address*	T.PS.NO-85(SARTHANA-PASODARA-LASKANA), F.P. NO- 3, , O.P.NO-3, BLOCK NO-23/P, MOJE- SARTHANA, TALUKA- KAMREJ, DIST- SURAT DIST- SURAT
Site Coordinates*	21 14 30.13N 72 54 35.30E, 21 14 30.98N 72 54 36.63E, 21 14 27.82N 72 54 36.65E, 21 14 28.46N 72 54 37.66E
Site Elevation in mtrs AMSL as submitted by Applicant*	18.9 M
Type Of Structure*	Building

*As provided by applicant

Your site is located at a distance 22339 mts from ARP and lies in the grid D23 of the published CCZM of Surat airport. The Permitted top elevation for this grid is 109 mts.

the requested top elevation 63.9 mts in AMSL is below CCZM permitted top elevation, the NOC for height clearance is not required from Airports Authority of India.

3. This assessment is subject to the terms and conditions as given below:

- The site-elevation and site coordinates provided by the applicant are taken for calculation of the permissible top elevation for the proposed structure. If however, at any stage it is established that the actual data is different from the one provided by the applicant, this assessment will become invalid.
- The Site coordinates as provided by the applicant in the NOC application has been plotted on the street view map and satellite map as shown in ANNEXURE. Applicant/Owner to ensure that the plotted coordinates corresponds to his/her site. In case of any discrepancy, this assessment shall be treated as null and void.
- Airport operator or his designated representative may visit the site (with prior coordination with applicant or owner) to ensure that assessment terms & conditions are complied with.
- The assessment is further subject to the provisions of Section 9-A of the Indian Aircraft Act, 1934 and any notification issued there under from time to time including the Aircraft (Demolition of Obstruction caused by Buildings and Trees etc.) Rules, 1994.



भारतीय विमानपत्तन प्राधिकरण AIRPORTS AUTHORITY OF INDIA

The applicant is responsible to obtain all other statutory clearances from the concerned authorities including the approval of building plans. This assessment for height is to ensure the safe and regular aircraft operations and shall not be used as document for any other purpose/claim whatsoever, including ownership of land etc.

Use of oil, electric or any other fuel which does not create smoke hazard for flight operations is obligatory, within 8 KM of the Aerodrome Reference Point.

This assessment has been issued w.r.t. the Civil Airports as notified in GSR 751(E). Applicant needs to seek separate NOC for Defence, if the site lies within jurisdiction of Defence Airport. Applicants also need to seek clearance from state Govt. as applicable, for sites which lies in the jurisdiction of unlicensed civil aerodrome as outlined in Rule 13 of GSR751 (E).

This assessment is system auto generated and thus does not require any signature

Designated Officer

Region Name: WEST

Address: General Manager Airports
Authority of India, Regional
Headquarter, Western Region,
Opp. Parsiwada, Sahar Road,
Vale Parle (E)

Email ID: nocwr@aai.aero

Contact No: 022-28300656

Street View



4/4

Satellite View



4/4



SURAT MUNICIPAL CORPORATION
FIRE & EMERGENCY SERVICES
HEAD QUATERS, MUGLISARA,
SURAT - 395003

Ph.: S.M.C. : 0261 - 2423750 TO 56, CONTROL : 2414195 -96, FAX : 2451935, 9724345553

Sub :- N.O.C./OPINION Fire & Emergency Services Dept. for High Rise Mix-Use Building.

Reference :- A letter from T.D.O. Shri bearing No. T.D.O.7404, Dt. 03/03/2023.

PROPOSED SITE :- PROP. LAYOUT PLAN FOR RESIDENTIAL & COMMERCIAL BUILDING ON T.P.S. NO. 85 (SARTHANA-PASODARA-LASAKANA), BLOCK NO. 23/P, O.P. NO. 3/A, 3/B, F.P. NO. 3/A, MOJE. SARTHANA, TAL. CITY, DIST. SURAT.

Submitted,

As per said plan the above building is a High Rise Mix-Use Building. A,B (Basement-1 + Basement-2 + Ground Floor + 14th Floor) with Height of 44.95 Mtrs.

As per N.B.C. 2016 the aforesaid buildings are to be considered as High Rise Mix-Use Building. Hence this dept. has No Objection if the applicant concerned makes necessary fire fighting arrangement in said building as per N.B.C. norms, Existing CGDCR norms, Gujarat Fire Prevention Life Safety Regulation 2017 and Submitted Drawing. Subject to compliance of following fire safety recommendations by the developer/owner during & after construction.

1. Parking shall not be permitted in courtyards and drive ways of fire appliances.
2. Courtyard shall be kept free from encumbrances & encroachments.
3. No structure of any type shall be permitted in courtyard of the building.
4. There shall not be any trees obstructing fire appliances reach in compulsory open spaces required as per CGDCR.
5. The gradient of the ramp shall not be steeper than 1:07.
6. The access provided to the basement shall be kept unobstructed.
7. Repairing/servicing of cars, use of naked light shall not be permitted in the car parking areas.
8. Dwelling, use of naked light / flame, repairing / maintenance of vehicles shall be strictly prohibited in the parking area.
9. The driveways shall be property marked and maintained unobstructed, proper illuminated signage shall be provided for escape route.
10. Car parking shall be permitted in the designated area only.
11. The fins with RCC, brick work, hallow blocks or any such construction materials shall not be permitted.
12. The driveways shall be properly marked and maintained unobstructed, proper illuminated signage shall be provided for escape route, car lifts, etc. at prominent location.
13. The layout of staircase shall be enclosed type throughout its height and shall be approached at each floor level.
14. Externally located staircases adequately ventilated to outside air.



15. Permanent vent at the top equal to 5 % of the cross sectional area of the stair case shall be provided.
16. Structural steel members connected to staircase shall be protected with fire retardant coatings.
17. No combustibles shall be kept or stored in staircase / passages.
18. The staircase should not be encroached by shoe-rack, decorative items, earthen pots etc.
19. Walls enclosing lift shaft shall have a fire resistance of not less than two hours.
20. Shaft shall have permanent vent of not less than 0.2 sq. meters in clear area immediately under the machine room.
21. Landing door and lift car door of the lifts shall be of steel shuttered with fire resistance of one hour. No collapsible shutter shall be permitted.
22. The Fire lift shall have a floor area of not less than 1.4 sq. meters it shall have loading capacity of not less than 545 kgs (8 persons lift) with automatic closing doors of minimum 0.8 m. width.
23. The electric supply of fire lift shall be on a separate service from electric supply mains in a building and the cables run in a route safe from fire i.e. within the lift shaft. Light & fans in the elevators having wooden paneling or sheet steel constriction shall be operated on 24 volt supply.
24. Fire lift should be provided with a ceiling hatch for use in case for emergency. So that when the car gets stuck up, it shall be easily openable.
25. In case of failure normal electric supply, it shall automatically changeover to alternate supply. For apartment houses, this changeover of supply could be done through manually operated changeover switch. Alternatively, the lift shall be so wired that in case of power failure, it comes down at the ground level and comes to stand-still with door open.
26. The operation of fire lift should be by a simple toggle or two button switch situated in glass-fronted box adjacent to the lift at the entrance level. When the switch is on, landing call point will become inoperative and the lift will be on car control only or on a priority control devices. When the switch is off, the lift will return to normal working. This lift can be used by the occupants in normal times.
27. The words 'fire lift' shall be conspicuously displayed in fluorescent paints on the lift landing doors at each floor level.
28. The speed of the fire lift shall be such that it can reach the top floor from ground level within one minute. Fire lift shall be constructed as per prevailing standard.
29. Corridor / lift lobby at each floor level shall be naturally ventilated as shown in plan for the upper floors.
30. The common corridor / lift lobby at each floor level shall be kept free from obstruction at all times.
31. Self-glowing / fluorescent exit signs in green colour shall be provided showing the means of escape at each floor of building. Portable lights / insta lights shall be provided at strategic location in the staircase and lift lobby.
32. The staircase and corridor lighting shall be on separate circuits and shall be independently connected so that they could be operated by one switch installation on the ground floor easily accessible to fire fighting staff at any time irrespective of the position of the individual control of the light points, if any.
33. Staircase and corridor lighting shall also be connected to alternate supply.
34. Double throw switches shall be installed to ensure that lighting in the staircase and the corridor do not get connected to two sources of supply simultaneously. A double throw switch shall be installed in the service room to terminate the stand-by-supply.
35. Emergency lights shall be provided in the staircase / corridors.

36. Electric cable shaft shall be exclusively used for electric cables and should not be open in staircase enclosure.
37. Electric shaft shall be sealed at each floor level with non-combustible material such as vermiculite concrete. No storage shall be permitted in electric cabin or shaft.
38. Inspection door for the shaft shall have two hours fire resistance.
39. Electric wiring / cable shall be of non-toxic, non-flammable, low smoke hazard having copper core fire resistance for the entire building with provision of ELCB/MCB.
40. Electric meter room shall be adequately ventilated, accessible & shall not be under staircase, basement, lift-lobby.
41. Electric wiring shall be having copper core having the fire resistance and low smoke hazard cables for the entire building with provision of ELCB/MCB.
42. Low and medium voltage wiring running in shaft and in false ceiling should run in separate conduits.
43. Water mains, telephone lines, intercom lines, gas pipes or any other services should not be laid in the duct for electric cable; use of bus bar/solid rising mains instead of cables is preferred.
44. Separate circuits for fire fighting pumps, lifts, staircase and corridor lighting and blowers for pressurizing system shall be provided directly from the main switch gear panel and these circuits shall be laid in separate conduit pipes so that fuse in one circuit will not affect the others. Such circuits shall be protected at origin by an automatic circuit breaker with its no-volt coil removed.
45. Master switches controlling essential services shall be clearly labeled & provide in the lobby for emergency operation.
46. False ceiling if provided in the building shall be of non-combustible material. Similarly, the suspenders of the false ceiling shall be of non-combustible materials.
47. Materials For Interior Decoration / Furnishing :
The use of materials which are combustible in nature and may spread toxic fumes/gases should not be used for interior decoration/furnishing, etc.
48. (A) Basement shall be ventilated naturally/mechanically. If naturally ventilated vents with cross sectional area (Aggregate) not less than 2.5 percent of the floor area spread evenly around the perimeter of the basement shall be provided.
(B) The basement shall be used for designated purpose only as shown in the plan.
49. The staircase of the basement shall be of enclosed type and entry to basement areas shall be through two hours higher resistance self closing door provided in the enclosed wall of the staircase and through smoke check/cut off lobby.
50. Suitable signage's shall be provided in the basement showing exit direction way to exit etc.
51. Exhaust duct, mechanical ventilation duct should not pass through exit or entry.
52. The basement beyond building line shall be paved; suitably to bear the load of fire engines weighing up to 40 m. tones each with point load of 10 kgs. /sq. cms.
53. Fire drill / evacuation drill :
Fire drill and evacuation drill shall be conducted regularly in accordance with fire safety plan of building at least once in a three month in consultation with Surat Fire Brigade and log of the same shall be maintained.
54. Signage's :
Self-glowing/fluorescent exit signs in green color shall be provided showing the means of escape of the building.
55. Fire Escape Chute : **NOT APPLICABLE.**
56. Refuge area : External balcony/deck in Bldg. A,B is considered as a Refuge Area. Therefore any alteration in future shall not be allowed.



57. The entry/exit shall be kept free for any obstruction.
58. Astro turf etc. shall not be permitted in the courtyard and in the drive way.
59. A certificate to the effect that the fire resistance protection has been provided as above shall be furnished from the Structural Engineer/Architect at the time of applying for occupation of the building.
60. All gaps between floor-slabs and to facade assembly shall be sealed at all levels by approved fire resistant Seal and material of 02 hrs fire rating.
61. Sprinkler system for glass facade providing full coverage to the glass.
62. Addressable Fire Alarm & Detection System as per NBC-2016 (Table-7).
63. Openable panels shall be provided on each floor and shall be spaced not more than 10 mt apart measured along the external wall from centre to centre of the access opening.
64. This NOC is issued from fire risk point of view only.
65. Trained man power shall be available for the fire fighting and lift rescue in the building premises round the clock.
66. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning authority.
67. The certificate may not be treated in any case for regularisation for unauthorised construction if any.
68. Form 16 from FPCOR to be submitted at the time of Fire Inspection of building.
69. The opinion is given on the basis of submitting drawings /documents only.
70. Facade & Elevation Design & Drawing shall have to be approved by Registered Facade Consultant.
71. Any other instructions given by the fire department from time to time about fire safety of the Building premises to be followed norms.
72. Fire officer can check the arrangements of Fire safety at any time, this certificate will be withdrawn without any notice if any deficiency is found.
73. Occupants /Owner should apply for renewal of fire safety certificate 01 Month prior expiry of this certificate.
74. Trained officers / security guards :
The trained security / fire supervisor along with trained staff having basic knowledge of firefighting & fix firefighting installation shall be provided / posted in the building.
They will be responsible for the following;
 - (a) Maintenance of all the first aid firefighting equipment, fixed installations & other firefighting equipment / appliance in good working condition at all times.
 - (b) Imparting training to the occupants of the building in the use of firefighting equipment provided on the premises & keep them informed about fire & other emergency evacuation procedures.
 - (c) To liaise with the city fire brigade on regular & continual basis.
 - (d) The mock drill with the designated fire marshal for any operation of disaster management plan shall be out regularly after occupation as per National Building Code.
75. The fire department of SMC will not responsible for any loss of life and property due to Fire / Emergency incident.
76. Fully Covered Paramount Grills shall not be allowed in Balconies.
77. One set of pumps shall be provided for each 100 hydrants or part thereof, with a maximum of two sets. In case of more than one pump set installation, both pump sets shall be interconnected as their delivery headers.

Note : (1). Front, rear & side margin & width of staircase to be checked by your department.
(2). Please note that the change of designated/intended/defined occupancy of the building

mentioned in the Pre Approval is not permitted as it will change the group or subdivision in the same group and building/facility has to comply the requirement of the code for relevant group/occupancy as per NBC-2016. Refer clause 3.1.12, 31.13 and 3.1.13.

T.D.O. Shri,
For information & further process please.


I/C Dy Chief Fire Officer


I/C CHIEF FIRE OFFICER
Surat Municipal Corporation

FES/ OUTWARD/NOC 980
DT. 04 - 03 - 2023

