

નવસારી શહેરી વિકાસ સત્તામંડળ
" નુડા " કલેક્ટર કચેરી, પ્રથમ માળ, કાલીયાવાડી,
નવસારી - ૩૮૬૪૪૫

નં. નુડા/બાંધકામ/વશી.૦૧/૧૦/૨૦૧૮

તા. ૦૩/૦૧/૨૦૧૮

પ્રતિ,
રીજનલ ફાયર ઓફિસરશ્રી,
મુગલીસરા, ફાયર સ્ટેશન,
સુરત.



વિષય :- બાંધકામની પરવાનગી બાબત.

મો.જે. છાપરા, તા. નવસારી, જિ. નવસારીનાં
રે.સ.નં. ૧૨૬/પૈકી ૧/પૈકી ૬, શ્રી પ્રદિપકુમાર મનોહરલાલ જૈન શ્યામ
કોર્પોરેશનનાં પાવરદાર ભાગીદારશ્રી જીમી પ્રદિપકુમાર જૈન વિગેરે તા. ૨૮/૧૨/૧૮
ની બાંધકામ પરવાનગી અરજી અન્વયે.

જયભારત સહ ઉપરોક્ત વિષય અંગેની બાંધકામ પરવાનગી મેળવવા બાબતની અરજદારશ્રીની તા. ૨૮/૧૨/૨૦૧૮ ની અરજીનાં અનુસંધાને જણાવવાનું કે, અરજી સાથે રજુ થયેલ પ્લાનમાં રજુ કરેલ સુચિત બાંધકામનાં પ્લાન મુજબ એ-ટાઈપ બિલ્ડીંગનું આયોજન ૨૭.૪૫ મીટરની ઉંચાઈમાં કરવામાં આવેલ છે. સુચિત " એ " ટાઈપનું આયોજન દુકાન-રહેણાંક મિશ્ર ડેવલપમેન્ટ હેતુસર બિલ્ડીંગનું હોય, નામદાર સરકારશ્રીનાં તા. ૧૨/૧૦/૨૦૧૭ નાં સંકલિત સામાન્ય વિકાસ નિયંત્રણ વિનિયમોની જોગવાઈ મુજબ સૌ પ્રથમ ગુજરાત ફાયર પ્રિવેન્શન એન્ડ લાઈફ સેફ્ટી મેઝર એક્ટ-૨૦૧૩ અને તેને આધિન મંજૂર થયેલ નિયમોને આધિન ફાયર સેફ્ટી અંતર્ગત સંબંધિત ચીફ ફાયર ઓફિસરનું જરૂરી ન વાંધા પ્રમાણપત્ર રજુ કરવું જરૂરી છે. જેથી સામેલ લે આઉટ પ્લાન / નકશાની વિગતોને ધ્યાને લઈ તથા ફાયર અંતર્ગત સુવિધાઓને ધ્યાને લઈ આપશ્રીનો જરૂરી અભિપ્રાય / એન.ઓ.સી. પાઠવી આપશોજી.

મુખ્ય કારોબારી અધિકારી
નવસારી શહેરી વિકાસ સત્તામંડળ
નવસારી

નકલ રવાના :-

પ્રતિ,
શ્રી પ્રદિપકુમાર મનોહરલાલ જૈન શ્યામ કોર્પોરેશનનાં પાવરદાર ભાગીદારશ્રી જીમી પ્રદિપકુમાર જૈન વિગેરે
રહે. C/O એચ.કે. દલસાણીયા (એન્જીનીયર)
પ્રથમ માળ-૧૦, ૧-એ, રચના એપાર્ટમેન્ટ,
સાંઢકુવા, નવસારી. તા. નવસારી, જિ. નવસારી તરફે જાણ તથા આગળની કાર્યવાહી કરાવવા સારું.

WE SERVE TO SAVE

પ્રતિ

મુખ્ય કારોબારી અધિકારી
નવસારી શહેરી વિકાસ સત્તામંડળ
નવસારી.

ઘનવર્ડ નં ૧૯૨, તા. ૧૭/૦૫/૨૦૧૯

વિષય:- ગુજરાત ફાયર પ્રિવેન્શન એન્ડ લાઇફ સેફ્ટી મેઝર એક્ટ -૨૦૧૩ અન્વયે અત્રેથી ફક્ત અભિપ્રાય આપવા બાબત. (એફોડેબલ)

સંદર્ભ:- નવસારી નગરપાલિકા ના જાવકપત્ર ક્રમાંક નં. નુડા.૧ થી ૧૦ /૨૦૧૯, તા. ૩/૦૫/૨૦૧૯ ની અરજદાર શ્રી પ્રદિપકુમાર મનોહરલાલ જૈન શ્યામ કોર્પોરેશન નાં પાવરદાર ભાગીદાર શ્રી જીમી પ્રદિપકુમાર જૈન વિગેરે ની મોજે:- છાપરા, તા. નવસારી .જી. નવસારી નાં રે.સ.નં. ૧૨૬/પૈકી ૧/પૈકી ૬, ની બાંધકામ પરવાનગી ની અરજી અન્વયે (એફોડેબલ) સવિનય ઉપરોક્ત વિષય અને સંદર્ભ અન્વયે ના પત્ર અનુસંધાને જણાવવાનું

કે અરજદાર શ્રી પ્રદિપકુમાર મનોહરલાલ જૈન શ્યામ કોર્પોરેશન નાં પાવરદાર ભાગીદાર શ્રી જીમી પ્રદિપકુમાર જૈન વિગેરે ની મોજે:- છાપરા, તા. નવસારી .જી. નવસારી નાં રે.સ.નં. ૧૨૬/પૈકી ૧/પૈકી ૬ ની તા. ૨૯/૧૨/૨૦૧૮ ની જમીનમાં બાંધકામ એ ટાઇપ દુકાન + રહેણાંક + મિક્ષ ડેવલોપમેન્ટ હેતુ માટે ગુજરાત પ્રિવેન્શન એન્ડ લાઇફ સેફ્ટી મેઝર એક્ટ -૨૦૧૩ નાં જુડીસીઆર (૨૦૨૧) નાં ઉલ્લેખીત નિયમો મુજબ અત્રેનાં ફાયર પ્રિવેન્શન અને પ્રોટેક્શન મુજબ નો અભિપ્રાય માંગેલ છે. જેમાં બિલ્ડીંગ-એ, બી (ગ્રાઉન્ડફ્લોર + ૮ માળ) માં ઉચાઇ ૨૭.૪૫ મીટર ધરાવતી ઇમારતમાં ગુજરાત પ્રિવેન્શન એન્ડ લાઇફ સેફ્ટી મેઝર એક્ટ -૨૦૧૩ અન્વયે સ્પ્રીન્કલર ઇન્સ્ટોલ કરવાના રહેશે. તેમજ મેઇન ઇલેક્ટ્રીકલ પંપ, જોડી પંપ તેમજ ડીઝલ પંપ ડ્રોઇંગમાં તેમજ ફીજીકલ ગ્રાઉન્ડ લેવેલ ઇન્સ્ટોલેશન કરેલ હોવો જોઇએ.

ઉપરોક્ત સંદર્ભે જરૂરીયાત મુજબનો સ્ટેરકેસ (દાદર) ૧.૫ મીટર ની પહોળાઇ સહીતનો અને બંને સાઇડનો પેસેજ ખુલ્લો હોવો જોઇએ. દરેક માળે પેરાપેટ વોલ ઉપર ૨ મીટર ની હાઇટ ઉપર હવા ઉજાસ થઇ શકે તે મુજબ હોવું જોઇએ. તેમજ ઇમારત પ્રિમાઇસીસમાં ૪૦ ટન ધરાવતું ફાયર વાહન સંપૂર્ણ ઇમારતના પ્રિમાઇસીસમાં ૦૪ મીટર ની પરિધમાં ફરી શકે તે મુજબ હોવું જોઇએ અને પ્રિમાઇસીસ ની ગેટ એન્ટ્રી બંને સાઇડ ૦૬ મીટર કે તેથી વધુ હોવી જોઇએ.

સંપૂર્ણ ઇમારતમાં ફાયર સેફ્ટી અને પ્રોટેક્શન ઇક્વિપમેન્ટ કાયમી ધોરણે ફીક્સ લગાડવા બાદ જ આપના લેવેલેથી ફાયર સર્વિસ વિભાગનાં ઓફીસરનાં ઇન્સપેક્શન કર્યા બાદ એન.ઓ.સી. આપવા ભલામણ છે.

જાવકનં/અભિપ્રાય નં. ૧૭૪
તા. ૨૧/૦૬/૨૦૧૯



21-6-19.
ડી.એચ. માખીજાની
રીજનલ ફાયર ઓફીસર
સુરત

814451616



1 : 2015 CERTIFIED COMPANY
Reg. No.: KDACQ201612045

World Class
SAFETY KING
The Complete Fire Protection
(Registered Government of India)

A-ONE FIRE SAFETY SERVICES

ALL TYPE FIRE FIGHTING AND P.P.ES, ROAD SAFETY PRODUCTS

5-87, Sardar Complex, Opp. Sardar Bridge, Adajan Road, SURAT-9, Ph. : +91-0261-2780504 / 2785466, Mob. : +91 98251 48113.

E-mail : mandeepa1@yahoo.com | a1firesafety@gmail.com | Website : aonefiresafety.com



TO,
REGIONAL FIRE OFFICER,
SUDA BHAVAN, OPP;
COLLECTOR OFFICE NANPURA,
SURAT -395001


Regional Fire Officer
State Fire Prevention Services
Surat

SUBJECT: Approval of Fire Fighting Layout Plan of "

Respected Sir,

With reference regarding " REVISED LAYOUT PLAN OF RESIDENTIAL AFFORDABLE HOUSING PLAN AT SURVEY.NO. -126/P1/P6, MOJE - CHHAPRA, TA. -, DI- NAVSARI "We are providing to you firefighting Layout Design as per GDCR & N.B.C part-IV. This System is Control Prevent Fire in all premises with safety norms.

1. NAME OF BUILDING: - REVISED LAYOUT PLAN OF RESIDENTIAL AFFORDABLE HOUSING PLAN AT SURVEY.NO. -126/P1/P6, MOJE - CHHAPRA, TA. -, DI- NAVSARI.
2. HEIGHT OF BUILDING: A & B - 27 MTR.
3. TYPE OF BUILDING: - RESIDENTIAL & COMMERCIAL.
4. FLOOR OF BUILDING: - A & B - GROUND FLOOR + 8 FLOOR.

You are hereby requested kindly give us approval for installation of Fire Fighting System as per drawing layout.



OUR PREROGATIVE, OUR JOB"

A-ONE FIRE SAFETY

S E R V I C E S

(GOVT.CONTRACTOR)

Tel: 0261-2780504, 0261-2785466, M: 09825148113

E mail: - mandeepa1@yahoo.com, a1firesafety@gmail.com

Website:- www.aonefiresafety.com

85, 86, 87, 98 SARDAR COMPLEX, OPP SARDAR BRIDGE, ADAJAN ROAD, SURAT-9



TO,

Parishram Architecture Firm

10, First Floor, A-1, Rachana Apartment,
Sandhkuva, Navasari.

KIND ATTENTION- AR VISHAL HALVADIYA.

Regional Fire Officer
State Fire Prevention Services

REVISED LAYOUT PLAN OF RESIDENTIAL AFFORDABLE HOUSING PLAN AT SURVEY.NO. - Surat

126/P1/P6, MOJE - CHHAPRA, TA. -, DL- NAVSARI

BASIC DATA AS PER TAC PUBLICATION GDCR AND N.B.C. PART IV

Sr.No.	Particulars	Descriptions
1.	Supposition of Risk	Coverage of all natural and man-made fire threats.
2.	No. of Hydrant valves / Sprinklers	25-30 / 105-110
3.	Pump size with flow	171m ³ /hr or 47.5 LPS/sec. Pump head 77 mtr i.e.7kf/cm ²
4.	Fire Water Tank required	1,00,000 liters (100KL)
5.	Rating for Main Pump Hydrant / Sprinklers	1850 LPM
6.	Rating for Jockey Pump	10.8m ³ /hr or 3ltr/sec. Pump Head 77 mtr 1850 LPM
7.	Flow consideration for pressure loss to calculate at farther point	47.5ltr/sec 47.5/2=23.75lps
8.	Salient Features	CE Marked Motor, With Energy Efficient Motor (SPDP optional), "F"- Class Insulation, IP 55, Option with 2 & 4 Pole Motors, Back Pull- out Design
9.	Applications	For firefighting in commercial applications
10.	Assumed Pipe Diameter Hit & Trial method	100 mm NB & 100mm NB
11.	Size of Suction Header	100 mm dia(Positive suction)
12.	Size of Discharge Header	100 mm NB
13.	Type of valve in pump room at suction side	100 mm Salves Valves/ Gate Valves
14.	Type of valve in pump room at discharge side	100 mm Salves Valves/ Gate Valves
15.	Loop line valve outside pump room for main distribution line	150 mm Salves Valves/ Gate Valves
16.	Actual Fire water storage tank capacity	1,00,000 liters
17.	Pump Room	Positive Suction (6L *5.5W*4 H pump room size in mtr.)
18.	Pressure at rest of Area	Minimum 3.5kg/cm ²
19.	Type of System	Automatic Operated Wet System
20.	Back up for Emergency	Diesel Pump
21.	Fire Alarm System	Automatic Information.
22.	Building Height	A & B 27 MTR.

MANDEEP SANDHU

1) MASTER'S DEGREE (M.B.A. SAFETY MANAGEMENT) 2) MEMBER OF THE SOUTHERN GUJARAT
CHAMBER OF COMMERCE 3) ARCH OF EXCELLENCE (BUSINESS) AWARD 4) RASHTRA NIRMAN RATNA
AWARD 5) LIFE TIME ACHIEVEMENT AWARD 6) RASHTRIYA UDYOG GOLD AWARD 7) INDIRA GANDHI
MEMORIAL ACHIEVEMENT AWARD

A-ONE FIRE SAFETY SERVICES



A-ONE FIRE SAFETY

S E R V I C E S

(GOVT.CONTRACTOR)

Tel: 0261-2780504, 0261-2785466, M: 09825148113

E mail: - mandeepa1@yahoo.com , a1firesafety@gmail.com

Website:-www.aonefiresafety.com

85, 86, 87, 98 SARDAR COMPLEX, OPP SARDAR BRIDGE, ADAJAN ROAD, SURAT-9



TO,
Parishram Architecture Firm
10, First Floor, A-1, Rachana Apartment,
Sandhkuva, Navasari.

KIND ATTENTION- AR VISHAL HALVADIYA.

Regional Fire Officer
State Fire Prevention Services
Surat

REVISED LAYOUT PLAN OF RESIDENTIAL AFFORDABLE HOUSING PLAN AT SURVEY NO. 126/P1/P6, MOJE - CHHAPRA, TA. -, DL- NAVSARI

The fire safety items given below are implanted in the market as per TAC Publication and GDCR-2017 and N.B.C. Part IV. The following fire layout plan has been prepared under the guidance of Mandeep Sandhu (MBA in Safety Management).

Sr.	FIRE HYDRANT SYSTEM	MAKE	Quantity
1	HYDRANT RISER	Asian/ Jindal / Tata	02 NOS
1	MONO BLOCK MAIN PUMP	Lubi/ Kirloskar / CRI	01 NOS
2	JOCKEY PUMP	Lubi/ Kirloskar / CRI	01 NOS
3	PUMP PANEL	Lubi/ Kirloskar / CRI	01 NOS
5	BUSTER PUMP	Lubi/ Kirloskar / CRI	02 NOS
7	G.I.PIPE "C" CLASS 100 mm ISI (IS : 1239 Part - II/3589)	Asian/ Jindal/Tata	74 RMT
8	G.I.PIPE "C" CLASS 80 mm ISI (IS : 1239 Part - II/3589)	Asian/ Jindal/Tata	13 RMT
9	G.I.PIPE "C" CLASS 25 mm ISI (IS : 1239 Part - II/3589)	Asian/ Jindal/Tata	12 RMT
10	Butterfly Valve CI 150 mm ISI (IS : 13095)	Kranti/ Krishna/Aurum	04 NOS
11	Butterfly Valve CI 100 mm ISI (IS : 13095)	Kranti/ Krishna/Aurum	04 NOS
13	NRV Valve CI 100 mm ISI (IS : 13095)	Kranti/ Krishna/Aurum	07 NOS
15	SLUICE VALVE C.I. 100mm ISI	Kranti/ Krishna/Aurum	06 NOS
16	Y Type Strainer CI 150 mm ISI	Kranti/ Krishna/Aurum	03 NOS
17	GM air release valve SS ISI	Kranti/ Krishna/Aurum	02 NOS
19	Inlet TWO way CI ISI (IS : 904)	Atasi/ New Age/ Safety King	02 NOS
20	Hydrant Valve 63 mm SS ISI (IS : 5290)	Atasi/ New Age / Safety King	24 NOS
21	Hose Reel 19mm Length 30mtr with Rubber hose IS : 444 Type 2	Atasi/ New Age / Safety King	24 NOS
22	Hose Box with Hose Pipe Length 15mtr (ISI 636 Type (A))	Atasi/ New Age / Safety King	24 NOS
23	ABC Type Fire Extinguisher Capacity- 6 Kg ISI (IS : 15683)	Atasi/ New Age / Safety King	24 NOS
24	CO2 Type Fire Extinguisher Capacity- 4.5 Kg ISI (IS : 2878)	Atasi/ New Age / Safety King	24 NOS
25	PRESSURE GAUGE	System sensor/L & T/ Safety King	04 NOS
26	PRESSURE SWITCH	System sensor/L & T/ Safety King	02 NOS

MANDEEP SANDHU

1) MASTER'S DEGREE (M.B.A. SAFETY MANAGEMENT) 2) MEMBER OF THE SOUTHERN GUJARAT CHAMBER OF COMMERCE 3) ARCH OF EXCELLENCE (BUSINESS) AWARD 4) RASHTRA NIRMAN RATNA AWARD 5) LIFE TIME ACHIEVEMENT AWARD 6) RASHTRIYA UDYOG GOLD AWARD 7) INDIRA GANDHI MEMORIAL ACHIEVEMENT AWARD

A-ONE FIRE SAFETY SERVICES



A-ONE FIRE SAFETY

S E R V I C E S

(GOVT.CONTRACTOR)

Tel: 0261-2780504, 0261-2785466, M: 09825148113

E mail: - mandeepa1@yahoo.com , a1firesafety@gmail.com

Website:-www.aonefiresafety.com

85, 86, 87, 98 SARDAR COMPLEX, OPP SARDAR BRIDGE, ADAJAN ROAD, SURAT-9



TO,

Parishram Architecture Firm

10, First Floor, A-1, Rachana Apartment,
Sandhkuva, Navsari.

Regional Fire Officer
State Fire Prevention Services
Surat

KIND ATTENTION- AR VISHAL HALVADIYA.

**REVISED LAYOUT PLAN OF RESIDENTIAL AFFORDABLE HOUSING PLAN AT
SURVEY.NO. -126/P1/P6, MOJE - CHHAPRA, TA. -, DI- NAVSARI**

The fire safety items given below are implanted in the market as per TAC Publication and GDCR-2017 and N.B.C. Part IV. The following fire layout plan has been prepared under the guidance of Mandeep Sandhu (MBA in Safety Management).

Sr.	FIRE SPRINKLER SYSTEM	MAKE	Quantity
1	SPRINKLER RISER	Asian/ Jindal/ Tata	02 NOS
2	MONO BLOCK MAIN PUMP	Lubi/ Kirloskar / CRI	01 NOS
3	JOCKEY PUMP	Lubi/ Kirloskar / CRI	01 NOS
4	PUMP PANEL	Lubi/ Kirloskar / CRI	01 NOS
5	BUSTER PUMP	Asian/ Jindal/ Tata	02 NOS
6	Diesel Pump	Lubi/ Kirloskar / CRI	01 NOS
7	G.I.PIPES "C" CLASS 100 mm (IS : 1239 Part - II/3589)	Asian/ Jindal/Tata	165 RMT
8	G.I.PIPES "C" CLASS 50 mm ISI (IS : 1239 Part - II/3589)	Asian/ Jindal/Tata	138 RMT
9	G.I.PIPES "C" CLASS 25 mm ISI (IS : 1239 Part - II/3589)	Asian/ Jindal/Tata	68 RMT
10	Butterfly Valve CI 150 mm ISI (IS : 13095)	Kranti/ Krishna/Aurum	03 NOS
11	Butterfly Valve CI 100 mm ISI (IS : 13095)	Kranti/ Krishna/Aurum	06 NOS
12	NRV Valve CI 100 mm ISI (IS : 13095)	Kranti/ Krishna/Aurum	04 NOS
13	SLUICE Valve CI 100 mm ISI	Kranti/ Krishna/Aurum	04 NOS
14	GM Air Release Valve SS ISI	Kranti/ Krishna/Aurum	02 NOS
15	Y Type Strainer CI 150 mm	Kranti/ Krishna/Aurum	03 NOS
16	Inlet Two way CI ISI (IS : 904)	Atasi/ Cease fire/ Safety King	03 NOS
17	Rose Pendant Type Sprinkler	Tyco/ Safety King/Atasi	104 NOS
18	PRESSURE GAUGE	System sensor/L & T/ Safety King	04 NOS
19	PRESSURE SWITCH	System sensor/L & T/ Safety King	02 NOS

MANDEEP SANDHU

1) MASTER'S DEGREE (M.B.A. SAFETY MANAGEMENT) 2) MEMBER OF THE SOUTHERN GUJARAT CHAMBER OF COMMERCE 3) ARCH OF EXCELLENCE (BUSINESS) AWARD 4) RASHTRA NIRMAL RATNA AWARD 5) LIFE TIME ACHIEVEMENT AWARD 6) RASHTRIYA UDYOG GOLD AWARD 7) INDIRA GANDHI MEMORIAL ACHIEVEMENT AWARD

A-ONE FIRE SAFETY SERVICES



A-ONE FIRE SAFETY

S E R V I C E S

(GOVT.CONTRACTOR)

Tel: 0261-2780504, 0261-2785466, M: 09825148113

E mail: - mandeepa1@yahoo.com , a1firesafety@gmail.com

Website:-www.aonefiresafety.com

85, 86, 87, 98 SARDAR COMPLEX, OPP SARDAR BRIDGE, ADAJAN ROAD, SURAT-9



TO,

Parishram Architecture Firm

10, First Floor, A-1, Rachana Apartment,
Sandhkuva, Navasari.

[Signature]
22-12-19

Regional Fire Officer
State Fire Prevention Services
Surat

KIND ATTENTION- AR VISHAL HALVADIYA.

**REVISED LAYOUT PLAN OF RESIDENTIAL AFFORDABLE HOUSING PLAN AT SURVEY.NO. -
126/P1/P6, MOJE - CHHAPRA, TA. -, DI.- NAVSARI**

The fire safety items given below are implanted in the Market as per **TACPublication and GDCR-2017andN.B.C. Part IV**. The following fire layout plan has been Prepared under the guidance of **Mandeep Sandhu (MBA in Safety Management)**.

Sr.	FIRE ALARM SYSTEM	Brand	Quantity
1.	Addressable Fire Alarm Panel with Automation System (only basement floor)	Agni suraksha / System sensor	02 NOS
2.	Addressable M.C.P with Automation System ABS	Agni suraksha / System sensor	20 NOS
3.	Addressable Hooter with Automation System ABS	Agni suraksha / System sensor	20 NOS
4.	Wire F.R 3 Core 1.5 Sq.mm	Fire Retardant	74 R.M.T.
5.	Conduit Pipe F.R. 1 inch	Fire Retardant	74 R.M.T.

MANDEEP SANDHU

1) MASTER'S DEGREE (M.B.A. SAFETY MANAGEMENT) 2) MEMBER OF THE SOUTHERN GUJARAT CHAMBER OF COMMERCE 3) ARCH OF EXCELLENCE (BUSINESS) AWARD 4) RASHTRA NIRMAN RATNA AWARD 5) LIFE TIME ACHIEVEMENT AWARD 6) RASHTRIYA UDYOG GOLD AWARD 7) INDIRA GANDHI MEMORIAL ACHIEVEMENT AWARD

A-ONE FIRE SAFETY SERVICES





22-8-19

Regional Fire Officer
State Fire Prevention Services
Surat

PROJECT DETAILS

- Name of Project : SURVEY.NO. -126/P1/P6
- T.P. NO. / R.S. NO. / O.P. NO. / F.P. NO. : CHHAPRA, TA. -, DI.- NAVSARI
- Village/Division : Residential & Commercial
- Type of building (Residential/
Commercial / Industrial Etc.) : AR. VISHAL HALVADIYA.
- Name of Architect : A - ONE FIRE SAFETY SERVICES
- Name of Fire Protection Consultant : SHRI PRADIPKUMAR MOHANLAL JAIN
- Name of Owner : A & B - 8 FLOOR.
- No. of Floors : A & B - 27 MTR.
- Height of the Building from Ground Level : North side
- Abut of the Building : East side
- : South side
- : West side
- Abut Road / Access Road : 12 MTR / 6.00 MTR.
- Road Side Margin : -
- Rear Margin and Side Margin : -
- Margin between two Buildings (Mtr.) : 4.11 MTR
- Margin from COP : -

Directions	From building line to plot boundary	From building line to podium boundary	From podium to plot boundary
North (side space)	4.11 MTR	4 MTR	-
South (side space)	4.00 MTR	4.00 MTR	4.00 MTR
West (side space)	4.07 MTR	4.00 MTR	4.00 MTR
East (side space)	4.00 MTR	-	-

Details of the Building:

Building	Wing	Floors	No. of basements	No. of Shops	Ht. from Ground Level
RESI + COMM.	02	8 FLOOR (EACH)	00	13 SHOPS/ 78 FLATS	27 MTR.





Proposed Pump House & Fire Water Network Arrangement

22-6-19

Regional Fire Officer
State Fire Prevention Services
Surat

Description		Remark
Water storage tank Capacity		
a	Under Ground tank	
b	Overhead Tank	1,00,000
Fire Pump's Control Panel: Totally enclosed cubicle type fire pump control panel free standing, floor mounted, compartmentalised, sectionalised, dust, dump and vermin proof with suitable natural ventilation arrangement, front and rear accessible, lockable power cum control panel.		50,000
1	Main Fire Pump (Centrifugal Pump)	Pump Discharge – 1850 LPM
		Pump head - 77 MTR.
2	Stand by Fire Pump (Diesel Pump)	Pump Discharge – 1850 LPM
		Pump head - 77 MTR.
3	Jockey Pump	Pump Discharge – 1850 LPM
		Pump head - 77 MTR.
4	Sprinkler Pump	Pump Discharge – 1850 LPM
		Pump head - 77 MTR.
5	Booster Pump- Booster pump of Capacity of 900 liters / min. having a pressure of not less than 3.2 kgs. / sq. cms. At the hydrant outlets of the wet riser-cum-down comer shall be provided at the terrace level of the buildings.	Pump Discharge -
		Pump head -
6	Ultra High Pressure Pump	Pump Discharge -
		Pump head -
7	Size of Main Fire Water Header(Not less than 150mm)	PROVIDING
8	Fire water piping (M.S. Pipe shall be C-Class as per IS : 1239 Only)	YES
9	Water Mist Piping (SS – 304 Grade Only)	NO
10	Water Mist Hose pipe (R-3 Pipe Only)	NO
11	Wet riser shall be connected to a fire pump at ground level of 2400 litres / min capacity giving a pressure of not less than 3.2 kgs /sq.cms. at the topmost hydrant	PROVIDING





Proposed Fire Fighting Arrangement

Sprinklers (UL listed, chrome plated brass or SS only)- Automatic sprinkler system shall be provided in entire building Including each habitable room, fitness center, entire basement, Stilted car parking areas and lift lobby and common corridor at Each floor level. The automatic sprinkler system shall be installed as per the standard laid by T.A.C and relevant, I.S. specifications.	 Regional Fire Officer State Fire Prevention Services PROVIDING
Wet Riser	PROVIDING
Fire Pump / Ultra High pressure Fire Fighting System (More than Mtr. Buildings)	PROVIDING
Fire Hydrants(Loop network), Delivery Hose (Type A confirming to IS: 636) Hose Boxes, Hose Reels	PROVIDING
Portable Fire Extinguishers on all Floors. (ISI Mark, CCE Approved and Hydro Tested only)	PROVIDING
Fire Brigade Collecting Head – 4 way	PROVIDING
4 – Way Fire Service Inlet	PROVIDING
Fire Water Draw- out Connection For fire service to suck water from UGT (100 mm suction Coupling)	PROVIDING
An alternative source of L.V. / H.V. supply from separate substation or through D.G. set with appropriate change over switch shall be provided for fire pumps, booster pump, staircase and corridor lighting circuits and manual fire alarm system, Fire Lift Emergency stair case, Lighting Smoke Ventilation System. It shall be housed in a separate cabin	
Appointment of Fire Man	PROVIDING
Appointment of Fire Officer	PROVIDING

Passive Fire Protection Systems

Fire Alarm	PROVIDING
Public Address System (MCP, PA System etc.)	PROVIDING
Fire Detector	PROVIDING
Exit Requirement	PROVIDING
No. of Staircase (Common staircase shall not continue to the basement)	2
Width of Staircase	2 MTR
Separate staircase to access the basement.	YES
Staircase exit shall be provided 02 hrs rating fire door.	YES
Travel distance	12 mtr
Lift wall, lift shaft, lift enclosure shall have of 02 hrs fire rating.	
No. Of Fire Lift (One lift for per 1000 sp. Mts. Of floor are if building height is more than 45 mtrs.)	PROVIDING
Smoke venting System	PROVIDING





Regional Fire Officer
State Fire Prevention Services
Surat

Signage- self glowing / fluorescent fire exit signs in green colour shall be provided showing the means of escape for the entire building.	PROVIDING
Refuge Area- Refuge area provided at staircase mid-landing level at 18 meters, 25 meters, 39 meters, 54 meters, 69 meters, 84 meters. Refuge area shall not be towards ramp side.	N.A.
Skip Floor – 10 and 18 floor - commercial	N.A.
Fire Resistant System to ensure Compartmentation if building height more than 45 mtrs: (As per clause 22.21.6 of GDCR 2017)	N.A.
Fire Resistant Rating of the Building material like bricks, glass, door frame, Aluminum etc. (As per GDCR clause 22.30.3 and IS – 15103:2002)	N.A.
Electrical cable (LSHF, FR etc)	PROVIDING
Provisions for Fire Control Rooms	PROVIDING
Basements Fire Protection (Compartmentation, Mechanical Ducted extractors for Smoke venting Extractors & Automatic sprinkler System) As per GDCR- clause 22.23 and NBC PART 8 Section 3.	PROVIDING
Fire stop system to seal Electrical wiring, Electrical Substation, shafts, Ventilation ducts.	PROVIDING
Fire Door (Lift lobby, staircase and refuge area should be provided with fire door at least 2 Hrs rating and Fire door insulation criteria shall be at least 20 Min) As per NBC Part-4 Clause-2.22.2	PROVIDING
Emergency Lighting System	PROVIDING
Lightning Arrestor	PROVIDING
Control Room at ground level - if floor plate exceeds 3000s.q. meters	PROVIDING
Electrical Shaft – Ventilated from the bottom and terrace level and closed at each floor by a fire resistant door.	PROVIDING

Signature of FPCOR:

Name of Fire Protection Consultant:





Regional Fire Officer
State Fire Prevention Services
Surat

NAVSARI NAGARPALIKA Fire & Emergency Services.

Gujarat Fire Prevention & Life Safety Measures Act, 2017 No. GH/V/23 of 2017/PRC/102013/398/V Gujarat Fire Prevention & Life Safety Regulation, 2017. Dated 3rd February 2017.

"REVISED LAYOUT PLAN OF RESIDENTIAL AFFORDABLE HOUSING PLAN AT SURVEY.NO. -126/P1/P6, MOJE - CHHAPRA, TA. -, DI.- NAVSARI

As per Gujarat Fire Prevention & Life Safety Measures Act, 20132 No. GH/V/23 of 2017/PRC/102013/398/V Gujarat Fire Prevention & Life Safety Regulation, 2017.

Sr.	High- Rise & Other Special Building Fire Fighting Facilities as per Regulations.	Answer as per N.B.C PART IV AND GDCR
1	Automatic Hydrant system	Providing.
2	Automatic Sprinkler System	Providing.
3	Emergency Lighting System	Providing each Floor
4	Escape Lighting	Providing.
5	Escape Route.	Providing.
6	Exit.	Providing, each Floor.
7	Fire Alarm System	Providing, each Floor.
8	Fire Lift	Providing.
9	Fire Proof Door	All Floor Providing. Properties and special features: Available in standard as well as customized sizes. Available in single & double leaf configurations. Sleek, fully flush and sturdy design with good aesthetics. No visible welds. Available in color sheds as per customer requirements. Totally asbestos free. Prefabricated ready to install at site. Provision of hardware as per customer requirement. Available with fire rated vision panel glass as per customer requirement. General purpose HMPS doors as per customer requirements also available. Available with smoke seals & thresholds. Premium quality stainless steel hardware items also available
10	Fire rating	up to 180 minuets
11	Frame/ shutter material	Galvanized steel
12	Door Finish	powder coating PU paint





22-8-19


Regional Fire Officer
State Fire Prevention Services
Surat

13	FR paint	Product Description: Ace panel seal is a fire sealing system which consists of two special types of panel boards, placed parallel to each other, with an air maintained and the exposed surface of boards are coated with fire-hydrant paint providing a fire rating of 2 to 4 hours. It provides a tight seal against the spread of fire toxic gases and smoke. The complete system is factory mutual; USA approved and tested as per ASTME-814 standards. Special features: It has a fire rating of up to 4 hours. Is non hygroscopic, it does not retain moisture and is not effected by humidity. It remains effective even after prolonged outdoor use. The coating does not disintegrate or deteriorate in salt water has no ageing effect. Coating lasts for the lifetime of penetration seal. Is anti-rodent. Is resistant to mineral oil. The coating does not crack or peel. Not affected by radiation. Suitable in radiation areas, ideal for nuclear power plants and atomic energy establishment.
14	Property	Present value
15	Density of Ace mastic	1.25 to 1.40 gms/cc
16	Bulk Density	550 gms./ Ltr.
17	Thickness of coating	1.5 to 2.00 mm
18	Curing rate	4 hours
19	Shelf life	18 months, in original packed condition
20	Application temperature	Room temp.
21	FR Bricks	Providing. Use between multiplex middle wall
22	FR cables	Providing
23	FR Glass	Providing
24	Fire Pump	Providing.
25	Fire Resistance Rating Of The Building	Providing.
26	Fire Separation	Providing.
27	Fire Service Inlet	Providing.
28	Fire Staircase	A & B- 27 MTR.
29	Height of the Building	60 % Occupancy each Shop.
30	Occupant Load	Providing.
31	Roof Exits	Providing.
32	Travel Distance	





33	Wet Riser	
34	Appointment Of Fire Safety Officer	Providing.
35	External Staircase	Providing.
36	Doorways	Providing.
37	Head Room under landing Of Staircase	Providing.
38	Minimum width of Staircase	Providing.
39	Separate power supply (Generator) for Fire Pump, Fire Lift Emergency, Lighting, Smoke Ventilation System	Providing.
40	Underground water Storage Pump	1, 00,000 LTR.
41	Fire Brigade Collecting Head – 4 Way for U.G. water storage Pump.	Providing.
42	Fire Hydrants, House Boxes, Hose Reels	Providing, each Floor.
43	Portable Fire Extinguishers on all Floors	Providing, each Floor.
44	Lightening arrester	Providing, Ground Floor.
45	Fire Control Rooms	Providing, Ground Floor.
46	Fire Drills	Providing.
47	Basements – Mechanical Smoke Extractors & Automatic Sprinkler System.	Providing, All basement.
48	Auto Glow Signage.	Providing, each Floor.
49	Fire Escape Chute	Providing staggered type, as per DCR, having landing each section
50.	Calculation of Refuge Area	Refuge Area required as per person as per NBC part IV. Refuge Area Require for 1 person + 0.3 Sq.m. Additional Area Require for Handicap Wheel Chair = 0.9 Sq.m.
51.	Helipad (above 60 Mtr. Height)	Not Applicable.
52.	Compartmentalization in structures, such as land-based buildings, traffic tunnels, ships, aerospace vehicles, or submarines, is the fundamental basis and aim of passive fire protection.	PROVIDING AS PER NBC PART IV
53.	Fire Resistant System to ensure compartmentation: (As per clause 22.21.6 of GDCR 2017)	Fire Stop system rating 120 mm
54.	UL Tested Fire stop system to seal Electrical Services penetration	As per clause 22.11-1 of GDCR 2017
55.	UL Tested Fire stop system for Electrical Substation penetrations	As per clause 22.12-1 of GDCR 2017
56.	UL Tested Fire stop system for Service	As per clause 22.16-1 of GDCR 2017


 Regional Fire Officer
 State Fire Prevention Services
 Surat



	ducts	
57.	UL Tested Fire stop system for Shafts	
58.	UL Tested Fire stop system for Ventilation ducts	As per clause 22.16-1 of GDCR 2017 As per clause 22.18.-3 of GDCR 2017
59.	In tumescent Fire stop for coatings for steel structures	As per clause 22.29.3 of GDCR 2017
60.	UL Tested Fire stop for Curtain Wall joints	As per clause 3.4.10.2, Part IV of NBC 2016
61.	Lift lobby, staircase and refuge area should be provided with fire door at least 2 Hrs rating and Fire door insulation criteria shall be at least 20 Min (As per NBC Part-4 Clause-2.22.2)	As per NBC Part-4 Clause 4.2.7




 Regional Fire Officer
 State Fire Prevention Services
 Surat

જિલ્લા પંચાયત કચેરી

નં. ડી.પી.વેન.વે. / રજી. ૩૧૩ / ૯૦-૯૧
જિલ્લા પંચાયત કચેરી (મહેસુલશાખા)
વલસાડ, તારીખ: ૨૦ / ૧૦ / ૧૯૯૧.

વચ્ચું :-

- (૧) મરજદારશ્રી અમલદાસ મંગલદાસ પટેલ
રહેવાસી કાપડા તાલુકો અમરગામી જિલ્લો કાપડા
તાલુકો અમરગામી ના સ.નં. બ્લોક નં. ૧૨૫૧ વાળી
જમીનનો બાંધકામનો ખેતી સિવાયનો પરવાનગીનો તા. ૨૫-૭-૯૧
નો મરજો.
(૨) માયોજનશ્રી, તાલુકા વિકાસ મંચિકારીશ્રી અમરગામી ના શેરા
કાપડા ના સ.નં. ૧૨૫૧ ના બ્લોક નં. ૧૨૫૧ ના તારીખથી ૩૦-૪-૯૧ થી
પુરુ થતું પ્રકરણ.
(૩) પ્રમુખશ્રીનો નોંધ હપરનો માટેશ તા. ૧૫-૧૦-૯૧
(૪) તા. ૨૦-૧૦-૯૧ ના રોજનો કારોબારી સમિતિનો ઠરાવ નં.
૧૦૩ થી અમલદાસ મંગલદાસ પટેલ.

હુ ક મ :-

મોજે કાપડા તાલુકો અમરગામી ના સ.નં.
બ્લોક નં. ૧૨૫૧ ની જમીનમાં પ્રકરણ સ.નં. તાલુકા
પંચાયત અમરગામી જે બાંધી કરેલા તારીખ ૨૦-૪-૯૧ ના
નકશામાં અમલદાસ મંગલદાસ પટેલ ખતાવેલ ચો.મી. ૭૫૮ જમીનમાં
કાયમી ખેતી સિવાયનો પ્લોટ બનાવો તેમાં કુની હાટી થી ખતાવેલ
ચો.મી. ૨૫૫૫-૬૫ જમીનમાં નકશામાં જણાવેલ વિગત
મુજબના અમલદાસ મંગલદાસ પટેલ ના બાંધકામ કરવાની જમીન મહેસુલ
કાયદાની કલમ-૬૫(૧) મ-વચે પરવાનગી શ્રી અમલદાસ મંગલદાસ પટેલ
રહેવાસી કાપડા ને આ કામે વિશેષધારો રુ. ૨૨૭૨૦૦
તથા લોકલકંડ શિક્ષણવિપકર તેમજ બીજા કરો લઈ નીચેની શરતોનું પાલન કરવાની
શરતે માંપવામાં આવે છે. તારીખ: ૧.૮.૮૧ ના નવા દરે નકકી થતા વિશેષધારો
ગામવર્ગ અમરગામી ની રેખલ ૭૫૮ માં પડતું બોલાથી ૦=૦૩ હેક્ટર
પેસા દર ચો.મી.ટરે લેવા હુકમ કરવામાં આવે છે. તારીખ: ૧.૮.૭૬ થી અમલમાં
આંવેલ શહેરની જમીનને ખોનખેતીમાં ફેરવવાનો રૂપાંતર કર ૫૦૦૦૦ ની વસ્તીવાળા
શહેર તેમજ તેના ચેક કિલોમીટરના ઘેરાવાના વિસ્તારને લાગુ પડે છે. પરંતુ મુ
ગામની વસ્તી ૫૦૦૦૦ થી ઓછી છે. તેમજ ચેક કિલોમીટરના ઘેરાવામાં આ જમીન
આવતી નથી. એથી રૂપાંતર કર લેવાપાત્ર નથી. રૂપાંતર કર ૨૨૭૨૦૦ ના
હેતુ માટે દર ચો.મી.ટરે ૩૦૧૦૦ પેસા લેવાપાત્ર થતો રૂપાંતર કર
રુ. ૭૫૮ નો પુરા હુકમ મળેથી દિન-૧૫ માં સરકારીમાં નીચેના
હેડે બરપાઈ કરવાનો રહેશે. રૂપાંતર કર બદલો હુકમ અમલી બનશે મુખ્ય સદર
'૦૦૩૫ ટેકાડીસ મોન હમચેલ પ્રોપર્ટી અધર ધેન મેટ્રો કલચરલ મે-૩' ગીણ સદર નોન
મેટ્રો કલચરલ કનવર્ઝન ટેકાડી.

શરતો:-

૧. સ.ઈ. તાલુકા પંચાયત ગાંધીધામ તાલુકો ગાંધીધામ તા. ૨૦-૧-૮૧ ના રોજ ખાતી કરેલ નકશામાં જિલ્લા દારી થી ખતી વ્યા મુજબ ૭૫૫૪ ચો. મીટરના ખેતી સિવાય પ્લોટમાં ૭૫૫૪-૫૫ ચો. મીટરથી વધુ જમીનમાં બાંધકામ કરવું નહીં. તેમજ બાકીની જમીન માકાશ તરફ ખુલ્લી રાખવી.
૨. જિલ્લા વિકાસ અધિકારીશ્રીની આજ્ઞાથી પકવાનગી મેળવ્યા સિવાય મંજૂર કરેલ ખેતી સિવાય પ્લોટમાં કોઈપણ ખાતનો વધારો અથવા બીજો ફેરફાર કરવો નહીં. તેમજ વધારાનું બાંધકામ કરાવવું નહીં.
૩. હેન્ડ રેવ-યુ કોડની કલમ-૪૮ હેઠળ જિલ્લા વિકાસ અધિકારીશ્રીની આજ્ઞાથી લેખિત પરવાનગી મેળવ્યા સિવાય મંજૂર જમીનનો તથા બાંધકામનો ૨૨૨૨૨ મુજબ સિવાયનો હેતુઓ માટે ઉપયોગ કરવા સારું મનાઈ કરમાવવામાં આવે છે.
૪. આ હુકમ ધ્યાની તારીખથી છ માસમાં ખેતી સિવાયનું કૃત્ય શરૂ કરવું પડશે અને જો તેમ કરવામાં કસુર થશે તો જે તારીખથી ખેતી સિવાયની પરવાનગી આપવામાં આવે છે. તે તારીખથી વિશેષાધારો તથા દંડ જે કાંઈ નક્કી થાય તે ભરવું પડશે.
૫. કબજેદારે ખેતી સિવાયના કૃત્ય શરૂ કર્યાની તારીખથી એક માસમાં ગ્રામ પંચાયત અધિ. મારફતે કૃત્ય શરૂ કર્યાની લેખિત ખબર તાલુકા વિકાસ અધિકારીશ્રીને આપવી. પડશે જો તેમ કરવામાં તેઓ કસુર કરશે તો ખેતી સિવાયનો ધારો ઉપરાંત દંડ ભરવાને પાત્ર રહેશે.
૬. મંજૂર કરેલ બોલડોંગ પ્લાનમાં જણાવ્યા મુજબ ન બાંધકામ કરવા પડશે તથા અત્રેથી મંજૂર કરેલ પ્લાન ઉપર ગ્રામ પંચાયતનો સિકકો કરાવવો પડશે.
૭. બાંધકામ શરૂ કરતાં પહેલાં સંબંધિત ગ્રામ/ગામ પંચાયતની પંચાયતધારા મુજબની પરવાનગી લેવાની રહેશે.
૮. સરકારશ્રીની સહેસુલ વિભાગના ઠરાવ નં. જપવન/૧૦૬૫/૨૭૩૩૯-૫ તા. ૧.૩.૬૭ના રેખા નિર્દેશના નિયમો આધિન રહીને બાંધકામ કરવાનું રહેશે.
૯. સરકારશ્રીના વૃક્ષારોપણના ધનિષ્ટ કાર્યક્રમને સકળ બનાવવા માટે અગિલામાં વૃક્ષો રોપી તેનું જતન કરવાનું રહેશે.
૧૦. કબજેદારે પોતાના ખર્ચે સર્વે ખાતા મારફતે ખેતી સિવાયનો પ્લોટની માપણી કરાવવી પડશે અને ખાતા તરફથી માપણી મુજબ દોષકર્ષ માકાશના જે કાંઈ ફેરફાર પડશે તે મુજબ આ હુકમ તથા કરો આપવાનો સમય ફેરફારો પાત્ર રહેશે.
૧૧. કબજેદારે ખેતી સિવાયનું કૃત્ય શરૂ કર્યાની તારીખથી પરંતુ અપીલ મુદત તીત્યા બાદ બે માસની મુદતમાં 'નમુના' 'સેમ' માં હુકમમાં જણાવેલ તમામ શરતો સહિતની સનદ કરી આપવી પડશે અને પરવાનગીથી સનદમાં જણાવેલ શરતોને આધિન રહેશે.
૧૨. ખાળકુવા નિયમિત સાફ કરાવવા જોઈએ ન હોય તો બાંધવા નહીં.
૧૩. કુવાથી ૧૦૦ ફૂટ અંતર નહીં ખાળકુવા બાંધવા નહીં. તેમજ ખાળકુવાનો ઉપયોગ કરવો નહીં.
૧૪. મંજૂર કરેલ ખેતી સિવાયના પ્લોટની જમીનનો આજુબાજુમાં કંપાઉ-ડમાં દિવાલ બાંધવાનો પ્રસંગ થાય તો તે માકાશ ફૂટથી વધુ ત્યાંની બાંધવી નહીં રસ્તા તરફથી બાજુએ જો દિવાલ બાંધવી હોય તો જિલ્લા વિકાસ અધિકારીશ્રીની પૂર્વ મંજૂરી મેળવ્યા સિવાય બાંધવી નહીં.

૧૫. ખાળ કુવા અને ખાળ કોઠીનો ઉપયોગ મળ સંગ્રહ માટે કરવો નહીં.
૧૬. મુંબઈના ગણોત અને ખેતી જમીનના કાયદાની તેમજ પ્રદોલોચન એક્ટની જોગવાઈઓને માધિન આ પરવાનગી આપવામાં આવે છે.
૧૭. આ હુકમથી ત્રણ વર્ષમાં બાંધકામ પુરુ કરવું પડશે અને બાંધકામ પુરુ થયેથી એક માસની મંદર તેની જાણ જિલ્લા વિકાસ અધિકારીશ્રીને કરવાની રહેશે.
૧૮. બાંધકામમાં સહેલાઈથી બળી જાય તેવો સ્પોટક પદાર્થ સાધનોનો ઉપયોગ કરવો નહીં.
- ૧૮/અ બોનખેતીના માકાર અને સરકારશ્રીના વખતોવખતના ઠરાવો, હુકમો, નિયમો પરિપત્ર તથા સુચનાઓ બંધનકર્તા રહેશે.
૧૯. ઉપરની કોઈપણ શરતોને ભંગ કરે તો આ પરવાનગી પુરેપુરી અથવા પરવાનગીનો અમુક ભાગ રદ કરવાને પાત્ર થશે.

સિદ્ધાંત ૨૧૨ જમીનમાં ગાંધી સ્કેલ ના પુનિદે કરે ન લિફ્ટ પાસનાની સુવિધાઓ

૨૦. શિક્ષાત્મક કલમ:-

- (અ) અરજદાર ઉપરોક્ત કોઈપણ શરતોને ભંગ કરે તો જિલ્લા વિકાસ અધિકારીશ્રી સદરહુ કાયદાની ઠરાવો અન્વયે અરજદાર ને કોઈ બીજી શિક્ષાને પાત્ર હોય તો બાંધ આલ્યા સિવાય તેને કરમાવવું યોગ્ય લાગે તોતે પ્રમાણે દંડ અથવા માકાર હઈ સદરહુ જમીનનો કબજો અરજદાર પાસે ચાલુ રહેવા દઈ શકાશે.
- (બ) ઉપરના પેટા કલમ માં ગમે તે મજકુર હોય તેા તે છતાં પણ જિલ્લા વિકાસ અધિકારીશ્રી સદરહુ પરવાનગી વિરુદ્ધ થયેલ અથવા વપરાતા કોઈપણ મકાન અથવા ઈમાલને જિલ્લા વિકાસ અધિકારીશ્રીએ આ અર્થે ને મુદત ઠરાવી હોય તે મુદત દરમ્યાન બસેડવામાં તેમ કરવાનું કરમાવે તો તે કાયદેસર ગણાશે અને ઠરાવેલી મુદત દરમ્યાન કેવો રીતે બસેડવામાં અથવા તેમાં કેરકાર કરવામાં ન આવે તો જિલ્લા વિકાસ અધિકારીશ્રીને તેમ કરવાની અને તેમ કરવામાં ને ખર્ચ થાય તે અરજદાર પાસેથી જમીન મહેસુલની બાકી તરીકે વસુલ કરવાને મુખત્યાર છે.

ગામનું નામ	સ.ન.	બોનખેતી વિસ્તાર	વિશેષાધારાની રકમ.	રૂપાતર કરની રકમ.
સામુલ	૧૯૫૧	૫૦.૦૦	૨૦૦.૦૦	૨૦૦.૦૦



સી. એ. શેખ
જિલ્લા વિકાસ અધિકારી,
જિલ્લા પ્રશાસન, વલસાડ.