



AHMEDABAD MUNICIPAL CORPORATION

FIRE & EMERGENCY SERVICE

DANAPITH FIRE STATION, (H. Q.) AHMEDABAD - 380 001

PH. : (079) 22148466 / 67 / 68, 32981178, 32981500 FAX : (079) 22148598.

(No.334. Dt.:26/11/2018)

To
Sh. Pragneshbhai Patel
A/8, Adishwer Appt.
Ranna Park,
Ghatlodiya, Ahmedabad.

Sub: Fire safety & protection, opinion for a proposed high-rise Building
(25 meters).

Sir,

This is to intimate that , the plans submitted for high-rise Residential Building with Block: A, B - basement parking + ground floor HPP + 1st to 7th floors residence. At R.S.no.55/2, F.P.no.27, T.P.no.56 (Sola-Ognaj-Gota), Ahmedabad have all the required line drawings and write-up required for the opinion, are as per the requirement of fire prevention and protection.

All norms as per the Fire Prevention and Life Safety Measures Act-2013, Gujarat state, have to be followed for providing Fire Prevention and Protection system, are to be followed.

Moreover, it is required that all the staircases of the building shall be ventilated above the parapet wall at each floor level and shall be 1.5 meters clear in width.

A motorable road with 40 ton load bearing capacity and minimum 4 meters wide, is required around the building without obstruction to a clear motorable passage for fire/rescue vehicles. (except one side ramp)

The gate (entry) to the premises shall be minimum 6 meters or more if required, in width, entry gate to be provided on both sides.


The building should have fire Protection system as per approved plans.

- **Basement parking & HPP shall be fully sprinklered.**

After, the building is built and all the required Fire safety and Protection equipment have been installed and after due inspection by the Fire service officer an NOC can be issued.

The copies of plans are returned herewith duly signed and have to be submitted during final inspection of the fire fighting system.




(M.F. Dastoor)
Chief Fire Officer