

કલેક્ટર અને જિલ્લા મેજિસ્ટ્રેટની કચેરી, રાજકોટ
કલેક્ટર કચેરી, જિલ્લા સેવા સદન, શ્રોફ રોડ, રાજકોટ - ૩૬૦૦૦૧
ફોન નંબર : ૦૨૮૧-૨૪૭૩૮૦૦ ઇ-મેઇલ : collector-raj@gujarat.gov.in



ગુજરાત જમીન મહેસૂલ અધિનિયમ-૧૯૭૯ ની કલમ-૬૫ હેઠળ

ફકમ નં. 818/09/17/095/2019
તા. 25/11/2019

(૧) અરજદારશ્રી Matru Vinayak Reality Partnership Firm

રહે. 408-Business Corner, Indira Circle, 150 Feet Ring road, Rajkot-360007 ની તા.06/10/2019 ની ઓનલાઇન અરજી (નં.3091709502246) તથા સોગંદનામું

- (૨) મુંબઇ જમીન મહેસૂલ કાયદો ૧૯૭૯ ની કલમ - ૪૮, ૬૫, ૬૬ તથા ૬૭
 (૩) ગુજરાત જમીન મહેસૂલ નિયમો, ૧૯૭૨ ના નિયમ ૮૧, ૧૦૦, ૧૦૧, ૧૦૨
 (૪) સરકારશ્રીના મહેસૂલ વિભાગનાં ઠરાવ નં. બખપ/૧૦૦૬/૪૨૫/ક તા.૦૧/૦૭/૨૦૦૮
 (૫) સરકારશ્રીના મહેસૂલ વિભાગનાં પરિપત્ર ક્રમાંક: બખપ/૧૦૨૦૧૮/૩૨૭/ક તા.૦૮/૦૫/૨૦૧૮
 (૬) સરકારશ્રીના મહેસૂલ વિભાગના ઠરાવ ક્રમાંક: એસ/ટીપી/૧૨૨૦૯/૭૬૯/૧૧/૬.૧ તા.૩૧/૦૩/૨૦૧૧
 (૭) સરકારશ્રીના મહેસૂલ વિભાગનાં ઠરાવ ક્રમાંક: બખપ/૧૦૨૦૧૮/૪૨૫/ક તા.૦૯/૦૧/૨૦૧૯
 (૮) સરકારશ્રીના મહેસૂલ વિભાગનાં પરિપત્ર ક્રમાંક: બખપ/૧૦૨૦૧૮/૪૨૫/ક તા.૧૨/૦૨/૨૦૧૯
 (૯) નાયબ કલેક્ટર શ્રી (સ્ટેમ્પ ડ્યુટી) નો તા.૦૬/૧૧/૨૦૧૯ નો અભિપ્રાય
 (૧૦) IRCMS પોર્ટલ પરની કેસ વિગત

ફકમ :-

વંચાણે લીધેલ કમ (૧) ની અરજી તથા સોગંદનામા થી અરજદારશ્રી Matru Vinayak Reality Partnership Firm એ મોજે રૈયા-૧ તા. રાજકોટ શહેર (પશ્ચિમ) જિ. રાજકોટ ના સરવે/બ્લોક નં. ૩૨/૧/પ૨/પ૨ ના ક્ષેત્રફળ ૧,૧૪૨.૦૦ ચો.મી. ની જમીન અંગે ગુજરાત જમીન મહેસૂલ અધિનિયમ-૧૯૭૯ ની કલમ-૬૫ હેઠળ બિનખેતીના હેતુ માટે પરવાનગી આપવા વિનંતી કરેલ છે.

૨. સવાલવાળી જમીનના ગામ નમૂના નં. ૭/૧૨ માં કબજેદારોની વિગત નીચે મુજબ છે.

સરવે/બ્લોક નંબર ટી.પી. નંબર એફ.પી. નંબર	માંગણીનું ક્ષેત્રફળ (ચો.મી.)	કબજેદારોના નામ (ખાતા નં. 165)	જમીનનો સત્તાપ્રકાર (૭/૧૨ મુજબ)
સરવે/બ્લોક નં. : ૩૨/૧/પ૨/પ૨ જુનો સરવે/બ્લોક નં. : --- ટી.પી. નં. : 16 એફ.પી. નં.: 44/2/2	1,142.00	માતૃ વિનાયક રીયાલીટી	જુની શરત (જુ.શ.)

૩. વસુલ કરવામાં આવેલ કરવેરાની વિગત નીચે મુજબ છે.

બેંકમાં ચલન ભર્યા તા.25/11/2019 નં.5700001355100352511979974

કરની વિગત	સદર	માંગણીનું ક્ષેત્રફળ (ચો.મી.)	દર રૂ. પ્રતિ ચો.મી.	કુલ રકમ રૂ.
રૂપાંતર કર	569-0035-00-800-01	1,142.00	40.00	45,680.00
વિશેષ ધારો	570-0035-00-101-01	1,142.00	0.60	685.00
લોકલ ફંડ	574-0029-00-103-01	1,142.00	0.30	343.00
શિક્ષણ ઉપકર	575-0045-00-108-01	1,142.00	0.15	171.00
માપણી ફી	577-0029-00-106-01	1,142.00	---	1,800.00
			કુલ રૂ.	48,679.00

૪. ઉપર્યુક્ત તમામ હકીકતો ધ્યાને લઈ મોજે રૈયા-૧ તા. રાજકોટ શહેર (પશ્ચિમ) જિ. રાજકોટ ના સરવે/બ્લોક નં. ૩૨/૧/૫૨/૫૨ ના ક્ષેત્રફળ ૧,૧૪૨.૦૦ ચો.મી. ની જમીનને નીચે જણાવેલ શરતોને આધિન ગુજરાત જમીન મહેસૂલ અધિનિયમ-૧૯૭૯ ની કલમ-૬૫ હેઠળ બિનખેતી હેતુ (બહુહેતુક ઉપયોગ) માટે પરવાનગી આપવા આથી હુકમ કરવામાં આવે છે.

શરતો :-

- (૧) આ હુકમ મળ્યેથી બે માસમાં "એમ" નમૂનામાં સનદ પ્રાપ્ત થશે.
- (૨) જિલ્લા ઇન્સ્પેક્ટરશ્રી, જમીન રેકર્ડની કચેરીમાં માપણી ફી જમા કરાવેલ છે. જેથી માપણી કરી / કરાવી આ હુકમ આધારે તેમજ મંજૂર થયેલ પ્લાન મુજબ દુરસ્તી પત્રક તૈયાર કરવાનું / કરાવવાનું રહેશે અને દુરસ્તી પત્રકનો મહેસૂલી દફતરે અમલ થયો બાદ જ પ્રશ્નવાળી બિનખેતીની જમીન / પ્લોટનું રજી. દસ્તાવેજથી થયેલ વેચાણ વ્યવહારના અમલ માટે નોંધ પાડવાની રહેશે.
- (૩) અરજદારે પ્રતિ વર્ષે ખેતી સિવાયનો ધારો (વિશેષધારો) દર પ્રતિ ચો.મી. ના રૂ. ૦.૬૦ પ્રમાણે રૂ. ૬૮૫.૦૦ તેમજ નિયમ પ્રમાણે લોકલ ફંડ તથા શિક્ષણ સેસ ભરવો પડશે જે અંગેનો દર વખતે વખત ફેરફારને પાત્ર રહેશે.
- (૪) રાજકોટ મહાનગરપાલિકા એ મંજૂર કરેલા પ્લાન મુજબ બાંધકામ કરવાનું રહેશે અને હુકમ થયા તારીખથી ત્રણ વર્ષમાં બાંધકામ પૂર્ણ કરવાનું રહેશે.
- (૫) સરકારશ્રીના મહેસૂલ વિભાગના ઠરાવ નં. બખપ/૧૦૯૩/૧૦૫૨/૬ તા. ૧૩/૦૯/૧૯૯૩ માં ઠરાવ્યા મુજબ સહીયારા / કોમન પ્લોટ અને રસ્તાની જમીન સોસાયટીની માલિકીની અથવા સર્વે પ્લોટ હોલ્ડરની સહીયારી માલિકીની ગણાશે તે ઉપર મુળ માલિકનો કોઈ હક્ક રહેશે નહિ.
- (૬) સરકારશ્રીના મહેસૂલ વિભાગના તા. ૦૭/૦૮/૧૯૯૧ ના પરિપત્ર નં. બખપ-૧૦૯૧/૧૭૫૬/૬ ની જોગવાઈ મુજબ બિન અધિકૃત બાંધકામ બાબતે બાંધકામ નિયંત્રણ કરતી સંબંધિત મહાનગરપાલિકા / શહેરી વિસ્તાર સત્તા મંડળએ ધોરણસરનાં પગલાં લેવાના રહેશે.
- (૭) સદર જમીનમાંથી પેટ્રોલીયમ / પાણીની કે અન્ય કોઈપણ પ્રકારની પાઇપલાઇન પસાર થતી હશે તો તે સંદર્ભે વિકાસ પરવાનગી આપનાર ઓથોરિટીએ સંબંધિતો ના-વાંધા પ્રમાણપત્ર મેળવી વિકાસ પરવાનગી આપવાની રહેશે.
- (૮) સરકારશ્રીના મહેસૂલ વિભાગના તા. ૧૨/૦૨/૨૦૧૯ ના પરિપત્ર નં. બખપ/૧૦૨૦૧૮/૪૨૫/૬ મુજબની નીચેની શરતોનું પાલન કરવાનું રહેશે.
 ૧. જો અગાઉ ચોક્કસ હેતુ માટે પ્રિમિયમ ભરપાઈ થયેલ હોય અને અન્ય હેતુ માટે વિકાસ પરવાનગી માંગેલ હોય/ નકશા મંજૂર કરવાના થતા હોય તો વિકાસ પરવાનગી આપતાં પહેલાં પ્રિમિયમ તફાવત ભરાયો સંબંધિત સત્તામંડળે ખાતરી કરવાની રહેશે અને ત્યારબાદ જ વિકાસ પરવાનગી આપવાની રહેશે.
 ૨. જીડીસીઆર મુજબ જે તે હેતુ/ ઉપયોગ માટે પરવાનગી મળવાપાત્ર નહિ હોય તો તે ઉપયોગ કરી શકાશે નહિ.
 ૩. ખેતી ઝોનમાં જીડીસીઆર મુજબ જેટલું બાંધકામ મળવાપાત્ર હશે તેટલા જ ક્ષેત્રફળ માટે વિકાસ પરવાનગી આપવાની રહેશે.
 ૪. બિનખેતી પરવાનગી મળ્યા બાદ જો ખાસ મંજૂરી વિના ધાર્મિક ઉપયોગ માટે બાંધકામ કરેલ હશે તો તે શરતભંગ ગણાશે અને તે બાંધકામ દૂર કરવાપાત્ર થશે.
- (૯) સરકારશ્રીનાં મહેસૂલ વિભાગનાં તા. ૦૧/૦૭/૨૦૦૮ ના ઠરાવ નં. બખપ/૧૦૦૬/૪૨૫/૬ માં જણાવેલ નીચે મુજબની શરતોનું પાલન કરવાનું રહેશે.
 ૧. જિલ્લા ઇન્સ્પેક્ટરશ્રી, જમીન રેકર્ડ દ્વારા ઇસ્યુ કરાયેલ માપણી શીટ કે જેના ઉપર મૂળ ટિપ્પણની હદ પણ દર્શાવેલ હોવી જોઈએ. રજૂ કરાયેલ પ્લાન તથા લે-આઉટ પ્લાન સક્ષમ કક્ષાએ મંજૂર કરાયેલ હોવી જોઈએ.
 ૨. બાંધકામ શરૂ કરતા પહેલાં બાંધકામનાં નકશા સક્ષમ અધિકારી પાસે મંજૂર કરાવવાના રહેશે. પરંતુ અરજદાર બિનખેતી પરવાનગી મેળવ્યા વગર આવા બાંધકામની રજા ટિફી મેળવી શકશે નહિ.
 ૩. શહેરી વિસ્તાર જ્યાં ટાઉન પ્લાનિંગ સ્કીમ મંજૂર થઈ ગઈ છે ત્યાં જી.ડી.સી.આર. અને ઝોનિંગના નિયમો અનુસાર બાંધકામ કરવાનું રહેશે.
 ૪. મંજૂર થયેલ નકશા મુજબ આરોગ્ય અને સ્વાસ્થ્યની દ્રષ્ટિએ ગંદા પાણીનાં નિકાલની જોગવાઈ કરવાની રહેશે.
 ૫. અરજદારે રિબન ડેવલપમેન્ટ રુલ્સ નીચે જે તે રસ્તાનો પ્રકાર ધ્યાને લઈ રસ્તાના મધ્યબિંદુથી બાંધકામ વચ્ચે અંતર જાળવવાનું રહેશે અન્યથા અરજદારની જવાબદારી થશે.
 ૬. ફ્લોર, મિલ, સિનેમા/ ટુરિંગ સિનેમા/ થિયેટર માટે બિનખેતી પરવાનગીના કામે જિલ્લા મેજિસ્ટ્રેટની જરૂરી મંજૂરી મેળવી આગળની કાર્યવાહી કરવાની રહેશે.
 ૭. પેટ્રોલ, ડીઝલ, કેરોસીન, સી.એન.જી., એલ.પી.જી. પંપ નાંખવા માટે બિનખેતી પરવાનગીના કામે બાંધકામ શરૂ કરતાં પહેલાં જિલ્લા મેજિસ્ટ્રેટની જરૂરી મંજૂરી મેળવી આગળની કાર્યવાહી કરવાની રહેશે.
 ૮. ઇન્ડિયન એક્ષપ્લોઝિવ એક્ટ અન્વયે મેગેનિઝ, ફાયર વર્ક્સ, દારૂખાના માટે બિનખેતીની કાર્યવાહી કરતા પહેલાં જિલ્લા મેજિસ્ટ્રેટની જરૂરી મંજૂરી મેળવી આગળની કાર્યવાહી કરવાની રહેશે.

૯. સવાલવાળી જમીન જો રેલવે હદની નજીક હોય તો રેલવેની હદથી નિયમ મુજબ જગ્યા છોડી બાંધકામ કરવાનું રહેશે.
૧૦. સવાલવાળી જમીન ઉપરથી અથવા બાજુમાંથી વીજળી ગ્રિડના તાર/ હાઇટેન્શન પાવર અગર થાંભલા આવેલ હોય ત્યારે તે અન્વયે લાગુ પડતા નિયમોનું પાલન કરવા અને તે મુજબ બાંધકામ કરવાનું રહેશે.
૧૧. બિનખેતી માંગવામાં આવી હોય તેવી જમીન જો એરોડ્રામ આસપાસ નિયમ મુજબની ત્રિજ્યામાં આવતી હોય ત્યારે બાંધકામની ઉંચાઇ તથા એરોડ્રામની દ્રષ્ટિએ જરૂરી એવું ના-વાંધા પ્રમાણપત્ર સિવિલ એવિએશન ખાતા પાસેથી મેળવવાનું રહેશે અને સિવિલ એવિએશન ખાતાના નિયમોનું પાલન કરવાનું રહેશે.
૧૨. ઓ.એન.જી.સી. ના કુવાની નજીકમાં આવેલ જમીનના કિસ્સામાં અરજદારે સંબંધિત નિયમોનું પાલન કરવાનું રહેશે.
૧૩. નર્મદા કેનાલ/ અન્ય સિંચાઇ કેનાલની નજીકમાં આવેલ જમીનની બાબતમાં અરજદારે સૂચિત બાંધકામ માટે જાળવવાના થતાં અંતર અંગેના નિયમોનું પાલન કરવાનું રહેશે.
૧૪. અરજદારે/ જ્યાં જરૂરી હોય ત્યાં કેન્દ્ર સરકાર કે રાજ્ય સરકારના કાયદા નીચે રક્ષિત સ્મારક (Protected Monuments) તરીકે જાહેર કરેલ પ્રાચીન સ્મારકથી નિયમ મુજબનું અંતર જાળવવાની પ્રવર્તમાન જોગવાઈઓનું પાલન કરવાનું રહેશે.
- (૧૦) જો આ જમીન પર કોઇ બેંક/ મંડળીનો બોજો બાકી હોય તો, તે ભરપાઇ કર્યા સિવાય આ મિલકત કોઇપણ પ્રકારે વેચાણ, ભેટ, વસિયત, બાનાખત, ગિરો કરી શકાશે નહિ અને કોઇપણ અન્યને પ્રત્યક્ષ કે પરોક્ષ રીતે માલિકી કે કબજો ભોગવતો તબદીલ કરી શકાશે નહિ.
- (૧૧) પ્રશ્નવાળી જમીનમાં નગરપાલિકા/ મહાનગરપાલિકા/ શહેરી વિકાસ સત્તા મંડળ દ્વારા જે શરતોએ પરવાનગી આપવામાં આવશે તે શરતોનું પાલન તથા બાંધકામ કરવાનું રહેશે.
- (૧૨) આ જમીનમાં વરસાદી પાણીના ભુગર્ભ વહન/ સંચય માટે દર મકાન/ બહુમાળી મકાન દીઠ એકના દરે આ જમીનમાં ઉપર પરકોલેટીંગ બોરવેલની વ્યવસ્થા અચૂક કરવાની રહેશે તથા વરસાદી પાણીના નિકાલની વ્યવસ્થા કરીને બાંધકામ કરવાનું રહેશે.
- (૧૩) પ્રશ્નવાળી જમીનમાં સ્થળે થયેલ બાંધકામ સ્થાનિક સ્વરાજની સંસ્થાના નિયમોનુસાર નહિ હોય તો સ્થાનિક સ્વરાજની સંસ્થા નિયમોનુસાર કાર્યવાહી કરી શકશે. તેમાં આ હુકમથી બાધ આવશે નહિ.
- અરજદારે ઉપરોક્ત શરતોનું પાલન કરવાનું રહેશે. જો તેમાં નિષ્ફળ જશે તો શરતભંગ ગણી સક્ષમ અધિકારી કાયદેસરની કાર્યવાહી કરશે.
- (૧૪) ઉપરની કોઇપણ શરતનો ભંગ થયેથી જમીન મહેસૂલ કાયદાની કલમ-૬૭ મુજબ શિક્ષાત્મક પગલા લેવામાં આવશે તેમજ બીજી કોઇપણ શિક્ષાને પાત્ર હશે તો તેને બાધ આપ્યા સિવાય કે જે ફરમાવવાનું યોગ્ય લાગે તે પ્રમાણે દંડ અથવા આકાર લઇ સદરહુ જમીનનો કબજો કબજેદાર પાસે ચાલુ રહેવા દઇ શકાશે.
- (૧૫) ઉપરોક્ત શરતોમાં ગમે તે મજફૂર હોય તેમ છતાં, કલેક્ટરશ્રી સદરહુ હુકમ વિરુદ્ધ બાંધેલા અથવા વધારાના કોઇપણ મકાન અથવા ઇમલાને કલેક્ટરશ્રીએ, આ અર્થે જે મુદત ૬૦ રાવી હોય તે મુદત દરમિયાન તેવી રીતે ખસેડવામાં ન આવે કે સૂચવ્યા મુજબ ફેરફાર ન કરવામાં આવે તો તેમ કરવામાં જે ખર્ચ થાય તે કબજેદાર પાસેથી જમીન મહેસૂલની બાકી તરીકે વસુલ કરવાને મુખત્યાર છે.

વધુમાં ઉપર્યુક્ત શરતોને આધીન અરજદાર દ્વારા રજુ થયેલ સોગંદનામાની વિગતોમાં તેઓ દ્વારા જાહેર કરેલી હકીકતોને આધારે સવાલવાળી જમીનના બિનખેતી ઉપયોગ માટે પરવાનગી આપવામાં આવે છે.




(REMYA MOHAN)
કલેક્ટર, રાજકોટ

આર.વી.એ.ડી.

પ્રતિ,

Matru Vinayak Reality Partnership Firm

408 Business Corner

Indira Circle

150 Feet Ring road

Rajkot-360007

નકલ રવાના:-

૧. મુખ્ય અધિકારીશ્રી, રાજકોટ મહાનગરપાલિકા

૨. મામલતદારશ્રી તા. રાજકોટ શહેર (પશ્ચિમ) જિ. રાજકોટ (હુકમનો અમલ ગામ દફતરે રેકર્ડ ઓફ રાઈટ્સ મુજબ કરાવવા સાડ.)
૩. જિલ્લા ઈન્સ્પેક્ટરશ્રી જમીન રેકર્ડ જિ. રાજકોટ
૪. તલાટીશ્રી રૈયા-૧ તા. રાજકોટ શહેર (પશ્ચિમ) જિ. રાજકોટ તરફ.
૫. નાયબ મામલતદારશ્રી ઇધરા, મામલતદાર કચેરી રાજકોટ શહેર પશ્ચિમ
૬. શાખાધ્યક્ષશ્રી રેકર્ડ શાખા, કચેરીમા
૭. સિલેક્ટ, ફાઇલે
૮. પરિશિષ્ટ પ ની, ફાઇલે


* આ હુકમની ઇ-ધરા કેન્દ્ર, રાજકોટ શહેર (પશ્ચિમ) માં નોંધ નંબર 11980 થી મોજે.- રૈયા-૧ તા.- રાજકોટ શહેર (પશ્ચિમ) જિ.- રાજકોટ માં નોંધ થયેલ છે.

TRUE COPY

VIJAY P. BHATT
Govt. of Gujarat
NOTARY
(RAJKOT)

(NAHOM AYMAH)

રાજકોટ, ૨૬/૦૯/૨૦૧૯



રાજકોટ, ૨૬/૦૯/૨૦૧૯

રાજકોટ, ૨૬/૦૯/૨૦૧૯

રાજકોટ, ૨૬/૦૯/૨૦૧૯

રાજકોટ, ૨૬/૦૯/૨૦૧૯

રાજકોટ, ૨૬/૦૯/૨૦૧૯

રાજકોટ, ૨૬/૦૯/૨૦૧૯

રાજકોટ, ૨૬/૦૯/૨૦૧૯

રાજકોટ, ૨૬/૦૯/૨૦૧૯

રાજકોટ, ૨૬/૦૯/૨૦૧૯



RAJKOT MUNICIPAL CORPORATION

Smart City



Dr. Ambedkar Bhavan, Dhebar Road
Fire & Emergency Service
RAJKOT - 360 001.

R.M.C.F.E.S.No.NOC.947.

Date:-30-11-2019.

TO,
Name M/s. Matru Vinayak Reality,
Shree Harshadbhai Nanjibhai Bhimani & Etc.
Matru Vashudha - A+B Wing Building Tower,
Location: - Village :-Raiya,
Rajkot.

-:: PROPOSE FIRE NOC ::-

Reference No.1.RMC/F.B/NOC/E.No.1552, Date:-29-11-2019.


Name of Work Proposed Residential Building (Dwelling -3) Plan for Name M/s. Matru Vinayak Reality, Shree Harshadbhai Nanjibhai Bhimani & Etc. Matru Vashudha - A+B Wing Building Tower, Location: - Village :-Raiya, Rajkot.
Type of Building: - Frame Structure, Use:-Residential, Height of Building:- 24.55 M. Building Floor = G. F. + 1st To 7th Floor, Stair Floor, R.Sr.No.32/1/P2/P2, Plot No.01 (Single Unit), Ward No.09, F.P.No.44/2/2, O.P.No.44/2, T.P.S.No16 (Raiya), Area Table :- Net Plot Area = 1142.00 sq.mt. F.S.I Used = 3033.45 sq.mt. / 1142.00 sq.mt. = 2.656 < 2.700.

Note:-Fire & Safety measures plan must be submitted before starting the construction work general guidelines are as under.

The proposed building is proposed to be provided with fire protection arrangements such as hose reel House, wet riser, yard hydrant, automatic sprinkler system in basement and manual call point provision at upper floors of Underground water storage tank 1,00,000 liters. & Overhead tank 20,000 liters for Building. Fire Pump 3200 LPM. and head of 50 meters. in each Building ISI standard Silent D.G. set must be meet with requirement of occupier consumptions & Connection of DG should be given to fire fighting pump & ALARM SYSTEM & LIFT of the Building of each block, portable fire Extinguishers installation as per req. Emergency Exit Glow sing. Fire lift Provision etc.

There is no objection to this department for the construction of the said High rise building subject to the compliance of the following fire safety condition.

1. Main entrance shall be adequate width to allow easy access to the fire fighting appliance and in no case it shall measure less than As per GDCR The entrance gates shall fold back against the compound wall of the Promises thus leaving the exterior access way within the plot free For Movement of fire service vehicles. If archway is provided over the main entrance than the height of the archway shall not be less than



As per GDCR Access way of As per GDCR Wide all around high rise block shall be of hard surface capable of taking the weight of the fire Engine up to 45 tones and always shall be free from every hindrance parking etc. for easy movement of fire/emergency vehicles.

2. **EXIT REQUIREMENTS:-** Exit requirements shall meet in accordance with provision as per building bye laws clause 16. Width of the main staircase in building shall not be less than 1.25 m. The treads shall be of non slip type.
3. **MEANS OF ESCAPE:-** Means of escape / exit shall be a continuous and unobstructed way of exit travel from and shall open towards means of escape which is away from but shall not obstruct the travel along any exit. No door when opened shall reduce the required width of staircase corridor / passage way. The width of fire escape staircase shall not be less than 100 cms.
4. All exit and exit way marking signs shall be illuminated and wired to independent circuit supplied by alternate source of power supply. Wiring for the illuminated signs must be laid and protected so that it cannot get involved in fire.
5. **VENTILATION:-** The building shall be provided with adequate ventilation. The provision of lighting and ventilation shall be strictly in accordance with part-VIII Section-I or National building code of India
6. **EMERGENCY POWER SUPPLY:-** The stand by electric generator shall be installed of adequate cap. to supply power to staircase and corridor lighting circuits, exit signs and fire pump in case of failure of normal electric supply. The generator shall be capable of taking starting current of all the machines and circuit stated above simultaneously and generator must be automatic in action.
7. Non Combustible material shall be used for construction of the building. Raised floors and false ceiling shall also be of non combustible material including structural support members.
8. **ELECTRIC WIRING:-** The electrical wiring shall be provided in metal conduits. Miniature circuit breaker and earth leakage circuit breaker shall also be installed.
9. **STATIC WATER TANK:-** An underground static water tank of fighting in the complex as marked on the plans. The replenishment through tube well or from the town main shall be ensured 3200 LPM/ to avoid stagnation of water in static tank the fire tank and passes to a domestic tank. This shall conform part-IV. An additional water storage tank of cap. Shall also be provided on the terrace.
10. **STATIONARY FIRE PUMP:-** One no. of electrical driven pumping set automatic in operation of LPM cap. Shall be provided at the farthest point. The standby diesel driven pumping set positive suction. The electric connection for fire pump shall be direct from the meter board it shall have no on/off switch in between. The pressure should be maintaining 3.5 k.g. at top most hydrant's connections.
11. **WET RISER:-02-** Unit Wet riser shall be provided in the bldg. which shall extend from the basement to the terrace floor. The internal hydrants.

The wet riser system and landing valves shall conform to is: code of practice.

12. 02- Unit Way fire brigade inlets shall be provided in the block wet riser.
13. HOSE BOX:- A hose box near each internal hydrant shall be provided comprising of 2 x 15m. Length of 63 mm. rubber lined hose conforming to IS: 903-1984.
14. HOSE REEL:- A hose reel near each internal hydrants containing 30 m. of length of 25 mm. bore terminating into shut off nozzle of 08 mm. Outlet connected directly to down comer shall be provided. This should conform to As per Latest Is:
15. PORTABLE FIRE EXTINGUISHERS: - The portable fire extinguishers of 4kg ABC/DCP and Co₂ 4.5 kg type shall be provided and marked on the plans. The number of the fire extinguishers may have to be increased later when the layout of the partition etc. in and maintained in accordance with IS: 15683
16. All vertical cable ducts/shafts and electrical niches on various floors of the building must be continuously monitored by fixed temperature heat detectors conforming to BIS Code of practice.
17. AUTOMATIC ALARM SMOKE DETECTOR HEAT DETECTOR GAS DETECTOR:-Should be fixed installation system should be reception to basement, theater banquet area, lobby area of all floor, all Room's per requirement for risk area (i.e.NBC code).
18. SMOKE VENTING SYSTEM:-The system shall be provided in the upper floors of Telephone Exchange building as per relevant code of practice.
19. YARD HYDRANTS: - The yard hydrants shall be provided as proposed in the complex as per specified BIS code of Practice.
20. SPRINKLER INSTALLATIONS:-Automatic sprinklers shall be installed in the basement building area. Flow alarm switch/gong shall be incorporated in the installation for giving provided near the testing facility. The entire system including pump capacity and head size of pipe net work, office size, source of water supply, provided in accordance to relevant code of practice-relevant rules (i.e. as TAC Rules / NFPA Code). Fire Services inlet shall also be provided at ground floor level.
21. MANUAL CALL POINTS:- Manual electrical call points at suitable locations on each floor of building shall be installed conforming to K-I.I.I.I. Of the unified building bye laws.
22. AIR CONDITIONING SYSTEM:- Following points must be ensured in respect of the air conditioning system :
 - (A) The ceiling and all its fixtures must be combustible material.
 - (B) Wherever the ducts pass through walls of floors the opening around the ducts must be sealed with fire resisting material. Air ducts must not pass through the staircase enclosures.
 - (C) The air filters of the air handing units must be of non combustible material. Air handling units must not be used for storage of any handling material.
 - (D) Fire dampers shall be provided in the ducts.

- (13) Escape routes like staircase, corridors must not be used as return air passage.
23. **LIGHTING PROTECTION:-** The lighting protection system is conforming to IS: 2309 shall be provided in the building.
24. **LIFT GROUNDING SWITCH:-** The lifts must be equipped with fireman switch so that it is possible to ground all lifts during a fire emergency. In case of failure of normal supply it shall automatically trip over to the Alternate supply. Suitable arrangements such as providing slope in the floor of lift lobby shall be made to prevent water during fire fighting etc. at any landing room entering into the lift shaft. All other conditions as laid down in NBC Part - IV (D-1.5) shall also be followed.
25. **CONTROL ROOM SECURITY ROOM:-** The control room - security room on the entrance of ground level with communication system to all floors and facilitate for receiving messages from different floors. Details of all floor plans along with the detail of firefighting equipment and installations shall be maintained in the control room.
26. **HOUSE KEEPING:-** To prevent the fire hazard, good housekeeping both inside and outside the building shall be strictly maintenance by MTNL authorities. The periodic inspection and maintenance of under floor space and false ceiling shall also be carried out to eliminate the fire risk.
27. **GENERAL:-** The fire prevention/fire safety measures recommended above cannot be effective unless these are backed by the administrative measures and the building, including the maintained in the top condition at times.
The building or part there of shall not be occupied unless compliance is ensured.
28. All the fire fighting system should be in accordance with the provision of Bombay provincial municipal corporation Act, 1949 and National Building code Act.

Note:- (1) After completion of above fire fighting system installation work and On The basis of Inspection of Chief Fire Officer NOC will be issued.



[Signature]
I/C Chief Fire Officer
Fire & Emergency Services
Rajkot Municipal Corporation

Copy to :-

1. T.P.O.