

F.Dastoor
Director



"WE SERVE TO SAVE"

Gujarat State Fire Prevention Services
Block No. 13, 3rd Floor,
Old Sachivalaya,
Gandhinagar. Gujarat, India
Mobile No. + 91 9978407288
Email : - dir.sfps@gmail.com

SFPS/F.no- 84/ /2018
516

Dt.: 28/11/2018

To,
M/s.Vadodara Urban Development Authority
V.I.P. Road, Karelilbag,
Vadodara.

Sub: Fire safety & protection, opinion for a proposed high rise Building.
(25 meters)

Sir,

This is to intimate that , the plans submitted for high rise high rise Commercial cum Residential Building Block: A,E with ground floor HPP & shops + 1st to 7th floors residence, Block: B,C,D,F,G,H – ground floor HPP + 1st to 7th floors residence. At F.P.no.100, T.P.no.02 (Bhayli), Vadodara have all the required line drawings and write-up required for the opinion, are as per the requirement of fire prevention and protection.

All norms as per the Fire Prevention and Life Safety Measures Act-2013, Gujarat state, have to be followed for providing Fire Prevention and Protection system, are to be followed.

Moreover, it is required that all the staircases of the building shall be ventilated above the parapet wall at each floor level and shall be 1.5 meters clear in width.

A motorable road with 40 ton load bearing capacity and minimum 4 meters wide, is required around the building without obstruction to a clear motorable passage for fire/rescue vehicles.

The building should have fire Protection system as per approved plans.

- HPP & shops shall be fully sprinklered.
- Opinion is issued in fire and life safety point of view only, the legality of plot & construction and FSI shall be conformed with concerned department only.

The gate (entry) to the premises shall be minimum 6 meters or more if required, in width, entry gate to be provided on both sides.

After, the building is built and all the required Fire safety and Protection equipment have been installed and after due inspection by the Fire service officer an NOC can be issued.

The copies of plans are returned herewith duly signed and have to be submitted during final inspection of the fire fighting system.



M.F.Dastoor

(M.F.Dastoor)
Director
State Fire Prevention Services,
Gandhinagar, Gujarat.

WE SERVE TO SAVE

આવક-૪
૦૦૨૩/૨
૦૦૨૪
૦૦૨-૧૫

ક્રમાંક :- આર.એફ.ઓ/ફન- ફન- અ.પ્રા./૨૨૯/૨૦૧૮

રીજીયોનલ ફાયર ઓફીસર,
સ્ટેટ ફાયર પ્રિવેન્શન સર્વિસીસ
"વુડા ભવન" વુડા સર્કલ, પાસે,
વી.આઇ.પી.રોડ, કારેલીબાગ પાસે, વડોદરા
ઈ-મેલ : rfovadodara_sfps@yahoo.com
તા. ૦૪/૧૨/૨૦૧૮

પ્રતિ,

શ્રી નગર નિયોજક,

શહેરી વિકાસ સત્તામંડળ,

વુડા ભવન, વુડા સર્કલ પાસે,

વડોદરા.


વિષય :- મોજે ભાયલી, તા.જી.વડોદરાના એફ.પી.નં.૧૦૦, ટી.પી.સ્કીમ નં.૨ ખાતે ફાયર અભિપ્રાય આપવા બાબત.

સંદર્ભ :-૧. આપશ્રીના પત્ર ક્રમાંક :- યુડીએ / પ્લાન- ૪/૭૦/૨૦૧૮.તા.- ૨૨/૧૧/૨૦૧૮.

૨. અરજદારશ્રી વડોદરા અર્બન ડેવલોપમેન્ટ ઓથોરીટીની તા. ૨૨/૧૧/૨૦૧૮ની અરજી

૩. મે. નિયામકશહેરશ્રી અભિપ્રાય પત્ર ક્રમાંક :-સફસ/ફન-૮૪/૫૧૬/૨૦૧૮ તા.- ૨૮/૧૧/૨૦૧૮.

ઉપરોક્ત વિષયે સંદર્ભિત પત્રોથી મોજે ભાયલી, તા.જી.વડોદરાના એફ.પી.નં.૧૦૦, ટી.પી.સ્કીમ નં.૨ વાળી જમીનમાં વાણીજ્ય તથા રહેણાક હેતુ માંટે ગ્રાઉન્ડ ફ્લોર + ૦૭ (સાત) ફ્લોરના બાધકામ વાળી મીલકતમા તેઓએ ગુજરાત સ્ટેટ ફાયર પ્રિવેન્શન એન્ડ લાઈફ મેઝર્સ એક્ટ ની કલમ-૧૮ અનુસાર અગ્નિનિવારણ અને અગ્નિસલામતીની જરૂરીયાતોનું પાલન કરવાની શરતે સદરહુ અરજદારશ્રી વડોદરા અર્બન ડેવલોપમેન્ટ ઓથોરીટી દ્વારા રજુ કરેલ રેખાચીત્ર મુજબ ગુજરાત સ્ટેટ ફાયર પ્રિવેન્શન એન્ડ લાઈફ મેઝર્સ એક્ટ-૨૦૧૩, રૂલ્સ -૨૦૧૪, અને રેગ્યુલેશન-૨૦૧૬ તથા કોમન GDCR નો ચુસ્ત પાલનને આધીન રહીને સદરહુ મીલકતમા બાધકામ પૂર્ણ થયેથી અગ્નિનિવારણ અને અગ્નિસલામતીની જરૂરીયાતોનું પાલન કરી તેની વિગતો રજુ કરી ના-વાંધા પ્રમાણપત્ર મેળવવાનું રહેશે. તા. ૨૮/૧૧/૨૦૧૮ થી અમલમા આવે તે રીતે આ અભિપ્રાય આપેલ છે જે આ સાથે સામેલ રાખેલ છે. જે જાણમાં લેવા વિનંતી છે.



(વી.એન.સોલંકી)

રીજીયોનલ ફાયર ઓફીસર,
સ્ટેટ ફાયર પ્રિવેન્શન સર્વિસીસ
વડોદરા