B/1

LAYOUT PLAN

LAYOUT PLAN SHOWING RESI.+COMM. BUILDING ON (SUR. NO:- 148/2,148/3), F.P.NO.:- 146+147, (O.P.NO.:-146,147), DRAFT T.P.S. NO.:66 (RANIP-CHENPUR-CHANDLODIYA) MOJE:- CHENPUR, TA.:- GHATLODIYA,DIST.:- AHMEDABAD

BLOCK-B

SCALE : 1.00 CM = 2.00 MT

ZONE :- RESIDENCE - 1

USE :- RESIDENCE (DWELLING-7)

AREA TABLE	IN SQ.MTS.
PLOT AREA OF F.P.NO. :- 146+147	1760.00
PERMI. F.S.I. AREA (1760.00 x 1.8)	3168.00
CHARG. F.S.I. AREA (1760.00 x 0.90)	1584.00
TOTAL PERMI.+ CHARGEABLE F.S.I. AREA	4752.00
TOTAL USED F.S.I. AREA	4744.01
CHARGEABLE F.S.I. AREA (4744.01 - 3168.00)	**1576.01**

COLOUR NOTE

PLOT BOUNDARY — TREE

ROAD / PATHWAY — CONTAINER BIN

PROP.WORK — P.WELL

PROP.DRAINAGE

BUILT UP AREA TABLE	IN SQ.MTS.		
	BLOCK: A	BLOCK: B	TOTAL
B.UP AREA ON BASEMENT	1122.96	----	1122.96
B.UP AREA ON GR. FL.	344.24	411.43	755.67
B.UP AREA ON 1st FL.	344.24	411.43	755.67
B.UP AREA ON 2nd FL.	310.16	411.43	721.59
B.UP AREA ON 3rd FL.	310.16	411.43	721.59
B.UP AREA ON 4th FL.	310.16	411.43	721.59
B.UP AREA ON 5th FL.	310.16	411.43	721.59
B.UP AREA ON 6th FL.	310.16	411.43	721.59
B.UP AREA ON 7th FL.	310.16	411.43	721.59
B.UP AREA ON STAIR CABIN	48.90	50.10	99.90
B.UP AREA ON O.H.W.T & L.M.R	30.65	30.54	61.39
TOTAL BUILT UP AREA	3750.07	3372.08	7122.15

F.S.I. AREA TABLE	IN SQ.MTS.		
	BLOCK: A	BLOCK: B	TOTAL
F.S.I. AREA ON GR. FLOOR (S.P.)	183.33	----	183.33
F.S.I. AREA ON 1st FL.	291.85	375.33	667.18
F.S.I. AREA ON 2nd FL.	276.92	375.33	652.25
F.S.I. AREA ON 3rd FL.	276.92	375.33	652.25
F.S.I. AREA ON 4th FL.	276.92	375.33	652.25
F.S.I. AREA ON 5th FL.	276.92	375.33	652.25
F.S.I. AREA ON 6th FL.	276.92	375.33	652.25
F.S.I. AREA ON 7th FL.	276.92	375.33	652.25
TOTAL F.S.I. AREA	2116.70	2627.31	4744.01

TENA. & USE TABLE			IN SQ MTS		
USE			EQ.TENA.		
FLOOR	BLOCK: A	BLOCK: B	A	B	TOTAL
GROUND	COMM.	----	6	---	6
1ST.	COMM.+ RESI.	RESI.	5+2=7	4	11
2ND	RESI.	RESI.	4	4	8
3RD	RESI.	RESI.	4	4	8
4TH	RESI.	RESI.	4	4	8
5TH	RESI.	RESI.	4	4	8
6TH	RESI.	RESI.	4	4	8
7TH	RESI.	RESI.	4	4	8
TOTAL	RESI.	RESI.	11+26=37	28	65

CONTAINER BIN AREA CALC.

REQ. 1 UNIT 10 LIT. REQ. 1 CONTAINER
TOTAL UNIT 65 × 10 LIT. = 650 LIT.
650/ 60 = 8.13 SAY 9 NOS. CONT.
REQU. 9 NOS BIN OF 60 LIT CAP.
PROVI. 9 NOS BIN OF 60 LIT CAP.

TREE PLANTATION CAL.:-

PLOT AREA = 1760.00 SQ.MT.
500.00 SQ. MT. = 12 NOS. TREE REQ.
(1760.00 - 500.00) = 1260.00 / 200 = 6.30 NOS.
7 x 5 = 35 TREE
NO OF PROVIDEC = 12+35 = 47 TREE

PERCOLATING WELL CALC:-

REQ. 1560 TO 4000 SMT= 1 NOS.
1765.00 / 4000.00 = 0.44 NOS.
SAY REQ. P.WELL = 1 NOS.
PROVI. P.WELL = 1 NOS.



LAYOUT PLAN
SCALE :- 1.00 CM. = 2.00 MT.



1. HYDRANT SYSTEM:

ON/OFF switches located near the hose reel hose or hydrant outlet.
At each floor the main Fire Pump at the underground water tank with a capacity to discharge 900 litre per minute at 3 bar pressure as measured at the landing level should be installed.
The Riser for the buildings exclusively 18 meters and above 18 meters height should not be of less than 150 mm. internal diameter. The riser should be connected to the bottom of the tankers tank with a stop valve and a NRV to left as a Down - comer.
One riser is required for every 1800sq. meters floor area and if the One riser is required for every 1800sq. meters floor area and if the building is divided into, two or more parts then each part should have a separate riser with all the fittings at floor level. Each floor should have one hydrant outlet with a coupling for attaching a 63 mm dia hose & 25 mm back Hose-reel hose with 9 mm. dia. Orifice nozzle at each floor landing. The length of the hose reel hose should be enough to reach the farthest corner of the floor. Hose dia. shall 15 meters long 63mm. dia. hose and 12.5 mm. bore nozzle at alternate floors. The Hose-reel hose should be coupled to the Riser.
Fire service inlet should be installed at a wall near the entry to the premises where a Fire service vehicle can approach easily.
A permanent hydrant point containing of 63 mm dia sale Inlet of hydrant valves should be installed at the terrace level.
Overhead tank Refilling Hydrant connection should be done at the terrace level.
The Overhead tank shall be of a capacity of not less than 20,000 liters. The Underground tank shall be of not less than 1,00,000 liters.

2. FIRE LIFT:

The Fire-Lift and all the lifts should have a provision to ground automatically in case of electricity failure. Each building should have at least one lift as a Fire-Lift and if the building is divided into two or more parts then each should have a Fire-Lift. Lift-well should have blower to pressurize the lift well so created that it will automatically operate when watch cell point is operate, so that it prevents the lift well getting smoke logged.

3. FIRE ALARM:

Fire alarm cell point to be installed at each floor with sounder capable of being heard all throughout the building.

4. FIRE EXTINGUISHERS

One Carbon Dioxide (CO2) type extinguisher of 4.5 kg. with ISI mark and one extinguisher of 9kg. Dry Chemical Powder (DCP) type extinguisher with ISI mark to be installed on each floor in case of commercial building.
One Carbon Dioxide (CO2) type extinguisher of 4.5 kg. with ISI mark. Off Two Carbon Dioxide (CO2) type extinguisher of 2 kg. with ISI mark capacity on alternate floors in case of residential building.
If the building is divided into two or more parts then each part should have these extinguishers installed.

5. STAIRCASE:

The staircase has to be open from at least one or two sides but if the staircase is in the centre core of the buildings it has to be pressurised to prevent it from getting smoke logged.

6. BASEMENT:

The basement of 200 sq. meters or more should be protected with Automatic Sprinkler system with at least one sprinkler head for actual Car parking space.
Additionally be protected by a Hydrant outlet and two 25 mm. bore hose-reel hoses with 5 mm. bore nozzles at each basement level.

7. LIGHTENING ARRESTER:

A lightening arrester should also be installed and be properly earthed to prevent damage to the building when the lightening strikes.

8. PHOTO LUMINESCENT (AUTO GLOW SIGNAGES):

If the building falls in a confined area or if it has an enclosed staircase in is not well lit-up on the inside, then adequate photo luminescent (auto glow) signages should be displayed at each floor / landing / pathway / deed-end (along of wall inside) leading to the ground level. The signage should indicate the lighting, the safety equipment present on the respective floor/landing/pathway/deed-end along all exit routes leading to the ground level.

9. ELECTRIC POWER SUPPLY TO THE ENTIRE FIRE-SAFETY SYSTEM:

Electricity supply to the fire pump, fire alarm system, electronic pressurization system and the lift should be made available from the main electrical supply (i.e. from Electricity power supply of the company). This is to ensure availability of power supply to the fire protection & Safety system even after the main electricity supply to the building is switched-off at the time of fire.

10.INDIVIDUAL FIRE SEFTY SYSTEM

FIRE SEFTY SYSTEM SHOULD BE PROVIDED IN (INDIVIDUAL SHOW ROOM BY OWNER

IMPORTANT INSTRUCTIONS:

After inspection of a low-rise building by the fire service authority if the fire officer concerned feels (i) need for additional fire prevention/protection measures / ventilation system required or adjustment (i.e. - Passive system / Suppression system / Fog door - Window / Detection system / Active system / Sprinkler / Stanchion etc.) as per Fire (see) / Factor / Public gathering / Potential / Occupancy / Confined area, those additional measures / equipment have to be implemented / installed.

FIRE HYDRANT LEGEND

SR.	SYMBOL	DESCRIPTION
1		FIRE HYDRANT PIPE WORK
2		SCUCC VALVE
3		NON RETURN VALVE
4		SCUCC YARD HYDRANT VALVE
5		LANDING HYDRANT VALVE
6		MUCC Bib
7		HOSE AND HOSE REEL
8		AIR RELEASE VALVE
9		TWO WAY SUMMUS CONNECTION
10		FIRE PIN POINT

SCRUTINIZE G.
TDO, BUDA, AMC

OWNER

Pramukh Corporation
RAMBHAI PATEL
DEV 1056305323
Prathna Residency,
Nr. Kamuda Party Plot,
Opp. Ansari Bunglow,
Near Rasta, Ahmedabad-382470

DEVELOPER

BIPIN AGARWAL
AMC STRUCT. E/0278/...
STRUCTURAL ENGINEERING
CIVIL ENGINEERING
Mobile : 9...
Email : ...

ST-ENGINEER

GAURAV B. PRAJAPATI
AMC ER 1217051022
AMC CW 085805 1022
5, Krishna Row House,
Nr. E.S.I. Hospital, Kalol.

ENGINEER

GAURAV B. PRAJAPATI
AMC ER 1217051022
AMC CW 085805 1022
5, Krishna Row House,
Nr. E.S.I. Hospital, Kalol.

C.O.W.

AUTHORITY

Ahmedabad Municipal Corporation
Case No.:- BLNT/AMD/0984/15/CGDCRVA/01/30/R/W1 Zone: WEST
Plan Approved as per terms and condition mentioned in the Commencement Certificate.
Date Challa Number :- 0067120/PR/R/01/30/R/W1
Date :- 25/04/2018

Asst. T.D.O.(Main E.D. (Civil) Cashier)
Rajendra Jadhav Dy.T.D.O. WEST
ARJAN SHANKAR PRAJAPATI Dy.MC WEST

LAYOUT PLAN A/1

LAYOUT PLAN SHOWING RESI.+COMM. BUILDING ON (SUR. NO:- 148/2,148/3), F.P.NO.:- 146+147, (O.P.NO.:-146,147), DRAFT T.P.S. NO.:66 (RANIP-CHENPUR-CHANDLODIYA) MOJE:- CHENPUR, TA.:- GHATLODIYA,DIST.:- AHMEDABAD

SCALE : 1.00 CM = 2.00 MT. | **BLOCK-A**

ZONE :- RESIDENCE - I

USE :- RESIDENCE (DWELLING-3)

AREA TABLE	IN SQ.MTS.
PLOT AREA OF F.P.NO. :- 146+147	1760.00
PERMI. F.S.I. AREA (1760.00 x 1.8)	3168.00
CHARG. F.S.I. AREA (1760.00 x 0.90)	1584.00
TOTAL PERMI. + CHARGEABLE F.S.I. AREA	4752.00
TOTAL USED F.S.I. AREA	4744.01
CHARGEABLE F.S.I. AREA (4744.01 - 3168.00)	**1576.01**

COLOUR NOTE

PLOT BOUNDRY — TREE

ROAD / PAYVAAY — CONTAINER BIN

PROP. WORK — P. WELL

PROP.DRAINAGE

BUILT UP AREA TABLE	BLOCK: A	BLOCK: B	TOTAL
B.UP AREA ON BASEMENT	1122.98	----	1122.98
B.UP AREA ON GR. FL.	344.24	411.43	755.67
B.UP AREA ON 1st FL.	344.24	411.43	755.67
B.UP AREA ON 2nd FL.	310.16	411.43	721.59
B.UP AREA ON 3rd FL.	310.16	411.43	721.59
B.UP AREA ON 4th FL.	310.16	411.43	721.59
B.UP AREA ON 5th FL.	310.16	411.43	721.59
B.UP AREA ON 6th FL.	310.16	411.43	721.59
B.UP AREA ON 7th FL.	310.16	411.43	721.59
B.UP AREA ON STAIR CABIN	48.86	50.10	98.90
B.UP AREA ON O.H.W.T. & L.M.R	30.86	30.54	61.39
TOTAL BUILT UP AREA	3750.07	3372.08	7122.15

F.S.I. AREA TABLE	BLOCK: A	BLOCK: B	TOTAL
F.S.I. AREA ON GR. FLOOR (S.P.)	163.33	----	163.33
F.S.I. AREA ON 1st FL.	291.85	375.33	667.18
F.S.I. AREA ON 2nd FL.	276.92	375.33	652.25
F.S.I. AREA ON 3rd FL.	276.92	375.33	652.25
F.S.I. AREA ON 4th FL.	276.92	375.33	652.25
F.S.I. AREA ON 5th FL.	276.92	375.33	652.25
F.S.I. AREA ON 6th FL.	276.92	375.33	652.25
F.S.I. AREA ON 7th FL.	276.92	375.33	652.25
TOTAL F.S.I. AREA	2116.70	2627.31	4744.01

TENA. & USE TABLE			IN SQ.MTS.		
USE			EQ.TENA.		
FLOOR	BLOCK: A	BLOCK: B	A	B	TOTAL
GROUND	COMM.	----	0	---	0
1ST	COMM./RESI.	RESI.	0+3=7	4	11
2ND	RESI.	RESI.	4	4	8
3RD	RESI.	RESI.	4	4	8
4TH	RESI.	RESI.	4	4	8
5TH	RESI.	RESI.	4	4	8
6TH	RESI.	RESI.	4	4	8
7TH	RESI.	RESI.	4	4	8
TOTAL	RESI.	RESI.	11+28=37	28	65

CONTAINER BIN AREA CALC.:
RESI. 1 UNIT 10 LIT. REQ. 1 CONTAINER
TOTAL UNIT 65 x 10 LIT. = 650 LIT.
650 /60 = 8.13 SAY 9 NOS. CONT.
REQU. 9 NOS BIN OF 80 LIT CAP.
PROVI. 9 NOS BIN OF 80 LIT CAP.

TREE PLANTATION CAL.:
PLOT AREA = 1760.00 SQ.MT.
500.00 SQ. MT. = 12 NOS. TREE REQ.
(1760.00 - 500.00) = 1260.00 / 200 = 6.30 NOS.
7 x 5 = 35 TREE
NO OF PROVIDE = 12+35 = 47 TREE

PERCOLATING WELL CALC.:
REQ. 1500 TO 4000 SMT.= 1 NOS.
1760.00 / 4000.00 = 0.44 NOS.
SAY REQ. P.WELL = 1 NOS.
PROVI. P.WELL = 1 NOS.

NOTES:

1. HYYDRANT SYSTEM:
ON/OFF switches marked near the hose reel hose or hydrant outlet.
At each floor the main FirePump at the underground water tank with
a capacity to discharge 900 liters per minute at 4 bar pressure as
measured at the furthest fixed should be installed.
The Riser for the buildings exceeding 15 meters and above 15 meters.
Height should not be of less than 100 mm. internal diameter. The riser
should be connected to the bottom of the tanks tank with a drop valve
and a NRV as well as a Drain - cocker.
One riser is required for every 1500sq. meters floor area and if the
building is divided into, five or more parts then each part should have
a separate riser with all the fittings at their level. Each floor should have
one hydrant outlet with a coupling for attaching a 63 mm rise hose & 30
mm casing horizontal hose with 6 mm. SS. Shut-off nozzle at each floor
landing. The length of the basic last hose should be enough to reach the
farthest corner on the floor. Hose box with 15 meters long 63mm. de-
hose and 15.5 mm. bore nozzle at alternate floors. The hoses reel hose
should be coupled to the Riser.
Fire service inlet should be installed at a point near the entry to the
premises where a Fire service vehicle can approach easily.
A permanent hydrant point comprising of 80 mm dia take 2mm of hydrant
valves should be installed at the terrace level.
Overhead tank Refilling System connection should be done at the terrace level.
The Overhead tank shall be of a capacity of not less than 20,000 litres. The
Underground tank shall be of not less than 1,00,000 liters.

2. FIRE LIFT:
The Fire-lift and all the lifts should have a provision to ground automatically in
case of electricity failure. Each building should have at least one lift as a Fire-
Lift and if the building is divided into two or more parts then each should have
a Fire-Lift. Lifts shall should have provision to accelerate the lift-well as compared
that it will automatically override when a car call point is operated, so that it prevents
the lift well getting smoke logged.

3. WIRELESS:
Fire alarm call point to be installed at each floor with sounders (audible or visual
based) all throughout the building.

4. FIRE EXTINGUISHERS:
One Carbon Dioxide (CO2) type extinguisher of 4.5 kg. with ISI mark, and one extinguisher
of 5kg. Dry Chemical Powder (DCP) type extinguisher with ISI mark to be installed on each
floor in case of commercial building.
One Carbon Dioxide (CO2) type extinguisher of 4.5 kg. with ISI mark, OR Two Carbon
Dioxide (CO2) type extinguisher of 2 kg. with ISI mark capacity on alternate floors in case
of residential building.
If the building is divided into two or more parts, then each part should have a three such points
complied.

5. STAIRCASE:
The staircase has to be open from at least one or two sides but if the staircase is in the
centre core of the buildings it has to be pressurised to prevent it from getting smoke logged.

6. BASEMENT:
The basement of 200 sq. meters or more should be protected with Automatic Sprinkler system
with at least one sprinkler head for actual Car parking space.
Additionally be protected by a Hydrant outlet and two 25 mm. flow Hose reel hoses with 6 mm.
bore nozzles at each basement level.

7. LIGHTENING ARRESTER:
A lightening arrester should also be installed and be properly earthed to prevent damage to the
building when the lightening strikes.

8. PHOTO LUMINESCENT (AUTO GLOW) SIGNAGES:
If the building falls in a crowded area or if it has an enclosed staircase or is not
well lit up on the inside, then adequate photo luminescent / soft glow / signages
should be displayed at each floor / landing / pathway / stairwell along all exit routes
leading to the ground level. The signages should indicate the lighting, the safety equipment
present on the respective floor/landing/pathway/stairwell and along all exit routes
leading to the ground level.

9. ELECTRIC POWER SUPPLY TO THE ENTIRE FIRE-SAFETY SYSTEM
Electricity supply to the fire pump, fire alarm system, staircase pressurization
system and fire lift should be made available from the main electrical supply
i.e. from Electrical power supply of the company. This is to ensure availability
of power supply to the fire protection & Safety system even after the main
electrical supply to the building is switched off at the time of fire.

10. PROVISION FIRE SAFETY SYSTEM
FIRE SAFETY SYSTEM SHOULD BE PROVIDED IN CENTRAL SHOW ROOM BY OWNER

IMPORTANT INSTRUCTIONS:
After inspection of a ten-rise building by the fire service authority, if but the officer
concerned feels the need for additional fire protection/detection measures
/ ventilation system required or improved / i.e. - Pressure system / Suppression system
/ Fire door / Window / Detection system / Active system / Sprinkler /
Drencher etc.) as per Fire read / Fire/ce / Public gathering.
Preamble / Occupancy / Confirmed areas
these additional measures / equipment have to be implemented /
installed.

FIRE HYDRANT LEGEND		
SR.	SYMBOL	DESCRIPTION
1		FIRE HYDRANT PIPE MAIN
2		SLUICE VALVE
3		NON RETURN VALVE
4		COURT YARD HYDRANT VALVE
5		LANDING HYDRANT VALVE
6		HOSE BOX
7		FIRST AID HOSE REEL
8		AIR RELEASE VALVE
9		TWO WAY SIAMESE CONNECTION
10		HOSE ON ROOF

DRAINAGE SECTION
SCALE HORI :- 1CM = 5MT.
VERTI :- 1CM = 1MT.

KEY PLAN
SCALE 1CM=20 MT.

PERCOLATION WELL
N.T.S.

LAYOUT PLAN
SCALE : 1.00 CM. = 2.00 MT.

24.00 MT. WIDE T.P.S. ROAD

OWNER

Pramukh Corporation
RAMBHAI PATEL
BCV 1008000525
Prithna Residency,
Nr. Kamuka Party Plot,
Gen. Ansal Bunglow,
New Ranip, Ahmedabad-382470

DEVELOPER

DIPAK AGRAWAL
ARC./STRUCT. ENGR.
B-1, Shivalik Shilp,
Opp. Iskcon Temple,
S.G. Highway,
Ahmedabad-15.
(M) 9825041434

ST.ENGINEER

GAURAV B. PRAJAPATI
AMC ER 1217051022
AMC CW 0858051022
6, Krishna Row House,
Nr. E.S.I. Hospital, Kalol.

ENGINEER

GAURAV B. PRAJAPATI
AMC ER 1217051022
AMC CW 0858051022
6, Krishna Row House,
Nr. E.S.I. Hospital, Kalol.

C.O.W.

AUTHORITY

Ahmedabad Municipal Corporation
Case No.: BU/ZONE/2/0416/CGDCR/JAN/2016/0001 Zone: WEST
Part Approval as per terms and conditions mentioned in the Commencement Certificate
Note Challan Number : 0057/2/2016/1/01/2/0000/NH
Date : 6/04/2016

Sub Engineer (Electrical) | Asst. T.D.O./Asst. E.O. | Rajkot/G.J.Vathani (Comm. Center) | Rajkot/G.J.Vathani (Comm. Center) | Dy.T.E.O. WEST | Dy.EC WEST

SEPTIC TANK DETAIL
N.T.S. UNLINED SECTION

SECTION COPY