



AHMEDABAD MUNICIPAL CORPORATION

FIRE & EMERGENCY SERVICE

DANAPITH FIRE STATION, (H. Q.) AHMEDABAD - 380 001

PH. : (079) 22148466 / 67 / 68, 32981178, 32981500 FAX : (079) 22148598.

(No.14.) Dt.: 08/01/2019

To,
M/s. Silver Enterprise
C/o. Vimalkumar B. Patel
108, Galaxy Business Park,
Opp. Torrent Power Station,
S.P. Ring Road, Nikol,
Ahmedabad.

Sub: Fire safety & protection, opinion for a proposed Low-rise building.
(6.70 meters)

Sir,

This is to intimate that , the file submitted for a low-rise 141 Industrial sheds building with ground floor + mezzanine floor. At F.P.no.250, Old R.S.no.370+375, New R.S.no.848+844, T.P.no.117 (Kathwada), Ahmedabad is submitted herewith.

The fire protection shall be;

- 141 units DCP extinguishers of 6 kgs. capacity.

Entry gate to the premises shall be 6 metres in width. A paved road should be maintained for movement of fire fighting vehicles.

After the building is built and all the required Fire safety and Protection equipment have been installed in the building and after due inspection by the Fire service officer an NOC can be issued.




(M.F.Dastoor)
Chief Fire Officer