



भारतीय विमानपत्तन प्राधिकरण
AIRPORTS AUTHORITY OF INDIA

द्रुतगामी डाक

दिनांक: 05.09.2017

संदर्भ संख्या: एएआई/एच/एटीसीओ-61/1724/14673

सेवामें,

श्री गुनवंतभाई केशवलाल एवं अन्य,
(श्री तुषार मोरी के द्वारा),
खंड संख्या 37/882,
गुजरात गृह निर्माण मंडल, अंतिम बस ठहराव के समीप,
मेघानीनगर, अहमदाबाद, गुजरात-380016।
M-80000 05292.

विषय: अनापत्ति प्रमाणपत्र पहचान (NOC ID): AHME/WEST/B/090217/244062 का अनापत्ति प्रमाणपत्र जारी करने हेतु।

महोदय,

अनापत्ति प्रमाणपत्र पहचान (NOC ID): AHME/WEST/B/090217/244062 के लिए संलग्न अनापत्ति प्रमाणपत्र.

मालिक का नाम

: Gunvantbhai Keshavial & Others.

(अनापत्ति प्रमाणपत्र पहचान के अनुसार)

कार्यस्थल का पता

T.P.S.No.-79/B Chandkheda, F.P. NO.-331, R.S.No-877/B, At -Chandkheda, Taluka - Sabarmati, Dist - Ahmedabad.

(अनापत्ति प्रमाणपत्र पहचान के अनुसार)

सधन्यवाद,

(हस्ताक्षर)

(सुभाष चन्द्र)

सहा. महाप्रबन्धक (वा. या. प्र. - एन. ओ. सी.)

एवं सदस्य सचिव (एन. ओ. सी. सी.)

कृते विमानपत्तन निदेशक



भारतीय विमानपत्तन प्राधिकरण
AIRPORTS AUTHORITY OF INDIA

- e. Only use of oil fired or electric fired furnace is permissible, within 8 KM of the Aerodrome Reference Point.
- f. The certificate is valid for a period of 8 years from the date of its issue. One time revalidation without assessment may be allowed, provided construction work has commenced, subject to the condition that such request shall be made within the validity period of the NOC and the delay is due to circumstances which are beyond the control of the developer.
- g. No light or a combination of lights which by reason of its intensity, configuration or colour may cause confusion with the aeronautical ground lights of the Airport shall be installed at the site at any time, during or after the construction of the building. No activity shall be allowed which may affect the safe operations of flights.
- h. The applicant will not complain/claim compensation against aircraft noise, vibrations, damages etc. caused by aircraft operations at or in the vicinity of the airport.
- i. Day markings & night lighting with secondary power supply shall be provided as per the guidelines specified in chapter 6 and appendix 6 of Civil Aviation Requirement Series 'B' Part I Section 4, available on DGCA India website: www.dgca.nic.in
- j. The applicant is responsible to obtain all other statutory clearances from the concerned authorities including the approval of building plans. This NOC for height clearances is to ensure the safe and regular aircraft operations and shall not be used as document for any other purpose/claim whatsoever, including ownership of land etc.
- k. This NOC has been issued w.r.t. the Civil Airports. Applicant needs to seek separate NOC from Defence, if the site lies within their jurisdiction.
- l. In case of any discrepancy/interpretation of NOC letter, English version shall be valid.
- m. In case of any dispute w.r.t site elevation and/or AGL height, top elevation in AMSL shall prevail.

Chairman NOC Committee

Region Name: WEST

Address: Jt. General Manager Airports
Authority of India, SVP
International Airport
Ahmedabad-380003(Gujarat)

Email ID: nocahm@aai.aero

Contact No: 079-22861396



हवाईअड्डा निदेशकसदर वल्लभ भाई पटेल अंतर्राष्ट्रीय हवाई अड्डा अहमदाबाद - 380 003 दूरभाष संख्या : 91-79-2286 9211

Airport Director, Sardar Vallabhbhai Patel International Airport, Ahmedabad-380 003 (Gujarat), Telephone - 91-79-2286 9211



Ministry of Health and Family Welfare
Government of India
New Delhi

Health Research Scheme
National Institute of Health

Form No. 1
Date: _____

1. Name of the Institution: _____

2. Name of the Project: _____

3. Name of the Investigator: _____

4. Address of the Institution: _____

5. Name of the Institution: _____

6. Name of the Institution: _____

7. Name of the Institution: _____

8. Name of the Institution: _____

9. Name of the Institution: _____

10. Name of the Institution: _____

11. Name of the Institution: _____

12. Name of the Institution: _____



AHMEDABAD MUNICIPAL CORPORATION

FIRE & EMERGENCY SERVICE

DANAPITH FIRE STATION, (H. Q.)AHMEDABAD - 380 001

PH. : (079) 22148466 / 67 / 68, 32981178, 32981500 FAX : (079) 22148598.

(No.218 Dt.: 30/08/2017.)

To,
Sh. Gunvantbhai Keshavlal
C/o. Alpesh Jadav
407, Akash Avenue,
Mithakhadi underbridge,
Ahmedabad.

Sub: Fire safety & protection, opinion for a proposed high-rise
Buildings (25 metres).

Sir,

This is to intimate that , the plans submitted for high-rise Commercial cum Residential building with Block: A/B/C – Basement parking + ground floor HPP & shops + 1st to 7th floors residence. At R.S.no.877/2, F.P.no.331, T.P.no.76/B (Chandkheda), Gandhinagar have all the required line drawings and write-up required for the opinion, are as per the requirement of fire prevention and protection.

All norms as per the Fire Prevention and Life Safety Measures Act-2013, Gujarat state, have to be followed for providing Fire Prevention and Protection system, are to be followed.

Moreover, it is required that all the staircases of the building shall be ventilated above the parapet wall at each floor level and shall be 1.5 meters clear in width.

A motorable road with 40 ton load bearing capacity and minimum 4 meters wide, is required around the building without obstruction to a clear motorable passage for fire/rescue vehicles. (except one side ramp)

The gate (entry) to the premises shall be minimum 6 meters or more if required, in width, entry gate to be provided on both sides.

The building should have fire Protection system as per approved plans.

- **Basement parking, HPP and shops shall be sprinklered.**

After, the building is built and all the required Fire safety and Protection equipment have been installed and after due inspection by the Fire service officer an NOC can be issued.

The copies of plans are returned herewith duly signed and have to be submitted during final inspection of the fire fighting system.




(M.F.Dastoor)
Chief Fire Officer