


એન.ઓ.સી.

આથી આ એન.ઓ.સી લખી આપવામા આવે છે કે સાણંદ તાલુકાના ખોડા ગામની સીમના સર્વે નંબર-૮૮/૧,૫૮/૧,૮૮/૨/૨,૯૦/૧,૯૧/૧,૯૨/૧,૯૪વાળા સર્વે નંબરો ખોડા ગામની સીમમા આવેલ છે. જે જમીનના માલીક ધન્ધ્યામસિંહ રણજીતસિંહ વાઘેલા નાઓની જમીન આવેલી છે જે જમીનના માલીકે અવીચલ પ્રોજેક્ટર એલએલપી(ક્ષેત્રફળ ચો.મી.૩૧૮૮/-)ની જમીન ઉપર કુલ-૧૫૦ સર્વીસ પ્રોજેક્ટ તથા ૪૦ દુકાનોનુ બાંધકામ હાલમા ચાલુ છે અને ૧૫૦ સર્વીસનુ બાંધકામ આશરે ૨૦થી૨૨ ચો.મીટરનુ છે. તેમજ ૪૨ દુકાનો જે આશરે ૩૨થી૩૫ ચો.મી.નું બાંધકામ ચાલુ છે આ જગ્યાના માલીક ધન્ધ્યામસિંહ રણજીતસિંહ વાઘેલાનાઓના વિરુધ્ધમા કોઇ ગુન્હો કે સજા કે દંડ થયેલ નથી તેમજ સદર જગ્યાયે ટ્રાફિક અંગેની અડચણ ઉભી થાય તેમ નથી. સદર જગ્યા અમોએ જાતે વેરીફાઇ કરેલ છે. તા-

૧૭/૮/૨૦૧૭



ઇ.પોલીસ ઇન્સ્પેક્ટર

સાણંદ જી.આઇ.ડી.સી.

પોલીસ સ્ટેશન



NISHIL. M. SHAH
(BE CIVIL)

F/4, Bhaikakanagar, Thaltej,
Ahmedabad - 380059.

AUDA/ENGG/1015



AHMEDABAD MUNICIPAL CORPORATION

FIRE & EMERGENCY SERVICE

DANAPITH FIRE STATION, (H. Q.) AHMEDABAD - 380 001

PH. : (079) 22148466 / 67 / 68, 32981178, 32981500 FAX : (079) 22148598.

(No.151. Dt.: 30/05/2017.)

To,
Ms. Avichal Projects LLP.
106, Abhishek Complex
Usmanpura,
Ahmedabad.

Sub: Fire safety & protection, opinion for a proposed high-rise
Buildings (22 meters).

Sir,

This is to intimate that , the plans submitted for high-rise Commercial building with basement parking + ground & 1st floors shops + 2nd to 6th floors offices. At F.P.no.90/1+91/1+92/1+88/2/2P, T.P.no.139/P (Chharodi-Naranpura-Khoda), sanand, Ahmedabad, have all the required line drawings and write-up required for the opinion, are as per the requirement of fire prevention and protection.

All norms as per the Fire Prevention and Life Safety Measures Act-2013, Gujarat state, have to be followed for providing Fire Prevention and Protection system, are to be followed.

Moreover, it is required that all the staircases of the building shall be ventilated above the parapet wall at each floor level and shall be 1.5 meters clear in width.

A motorable road with 40 ton load bearing capacity and minimum 4 meters wide, is required around the building without obstruction to a clear motorable passage for fire/rescue vehicles. (except two side ramp)


The gate (entry) to the premises shall be minimum 6 meters or more if required, in width, entry gate to be provided on both sides.

The building should have fire Protection system as per approved plans.

- **Basement parking, HPP and shops at all level shall be fully sprinklered.**

After, the building is built and all the required Fire safety and Protection equipment have been installed and after due inspection by the Fire service officer an NOC can be issued.

The copies of plans are returned herewith duly signed and have to be submitted during final inspection of the fire fighting system.


(M.F.Dastoor)
Chief Fire Officer

