



RAJKOT MUNICIPAL CORPORATION

Dr. Ambedkar Bhavan, Dhebar Road

Fire & Emergency Service

RAJKOT – 360 001.

Smart City

R.M.C.F.E.S.No.NOC.37.

Date.03.06.2020.

To,

Owners Name Janki Developers Partners Shree Utam Manishbhai Rankja
Shree Ishwarbhai Govindbhai Jethloja,

One Building,

Location: - Near Kerala Park, Village :-Raiya,
Rajkot.

-:: PROPOSED FIRE NO OBJECTION CERTIFICATE ::-

Reference:-1.R.M.C.F.B.E.NO.NOC.32, DATE:-28.05.2020.

Name of Work :- (Dwelling - 3) Proposed Residence Building Plan for
Proposed Fire No Objection Certificate That With Reference to Above
Application of **Owners Name Janki Developers Partners Shree Utam
Manishbhai Rankja Shree Ishwarbhai Govindbhai Jethloja, One Building,**
Location: - Near Kerala Park, Village :-Raiya, Rajkot, Use of Building =
Residence (Dwelling -3) Building, Type of Building :-Frame Structure,
Building Floor:- G.F. + 1st To 7th Floor, Stair Room, Height of Building =
24.40 M. Sr.No.2/2, Ward No.9, T.P.S.No.16 (Raiya), O.P.2+6+7,
F.P.No.2+6/1/2+7, Area Table :- Total Plot Area = 1103.07 F.S.I. Used =
2975.28 / 1103.07 = 2.697 < 2.70.

Note:-Fire & Safety measures plan must be submitted before staring the construction
work general guidelines are as under.

The proposed building is proposed to be provided with fire protection arrangements such
as hose reel House, wet riser, yard hydrant, automatic sprinkler system in basement and
manual call point provision at upper floors of Underground water storage tank 1,00,000
liters. & Overhead tank 20,000 liters for Building. Fire Pump 3200 LPM. and head of 50
miters. in each Building ISI standard Silent D.G. set must be meet with requirement of
occupier consumptions & Connection of DG should be given to fire fighting pump &
ALARM SYSTEM & LIFT of the Building of each block, portable fire Extinguishers
installation as per req. Emergency Exit Glow sing, Fire lift Provision etc.

There is no objection to this department for the construction of the said High rise building
subject to the compliance of the following fire safety condition.

1. Main entrance shall be adequate width to allow easy access to the fire fighting
appliance and in no case it shall measure less than As per GDCR The entrance


gates shall fold back against the compound wall of the Promises thus leaving the Exterior access way within the plot free for Movement of fire service vehicles. If archway is provided over the main entrance than the height of the archway shall not be less than As per GDCR Access way of As per GDCR Wide all around high rise block shall be of hard surface capable of taking the weight of the fire Engine up to 45 tonnes and always shall be free from every hindrance parking etc. for easy movement of fire/emergency vehicles.

2. EXIT REQUIREMENTS:- Exit requirements shall meet in accordance with provision as per building bye laws clause 16. Width of the main staircase in building shall not be less than 1.25 m. The treads shall be of non slip type.
3. MEANS OF ESCAPE:- Means of escape / exit shall be a continuous and unobstructed way of exit travel from and shall open towards means of escape which is away from but shall not obstruct the travel along any exit. No door when opened shall reduce the required width of staircase / corridor / passage way. The width of fire escape staircase shall not be less than 100 cms.
4. All exit and exit way marking signs shall be illuminated and wired to independent circuit supplied by alternate source of power supply. Wiring for the illuminated signs must be laid and protected so that it cannot get involved in fire.
5. VENTILATION:- The building shall be provided with adequate ventilation. The provision of lighting and ventilation shall be strictly in accordance with part-VIII Section-I or National building code of India
6. EMERGENCY POWER SUPPLY:- The stand by electric generator shall be installed of adequate cap. to supply power co staircase and corridor lighting circuits, exit signs and fire pump in case of failure of normal electric supply. The generator shall be capable of taking starting current of all the machines and circuit stated above simultaneously and generator must be automatic in action.
7. Non Combustible material shall be used for construction of the building. Raised floors and false ceiling shall also be of non combustible material including structural support members.
8. ELECTRIC WIRING:- The electrical wiring shall be provided in metal conduits. Miniature circuit breaker and earth leakage circuit breaker shall also be installed.
9. STATIC WATER TANK:- An underground static water tank of fighting in the complex as marked on the plans. The replenishment through tube well or from the town main shall be ensured 3200 LPM/ to avoid stagnation of water in static tank the fire tank and passes to a domestic tank. This shall conform part-IV. An additional water storage tank of cap. Shall also be provided on the terrace.
10. STATIONARY FIRE PUMP:- One no. of electrical driven pumping act automatic in operation of LPM cap. Shall be provided at the farthest point. The standby diesel driven pumping set positive suction. The electric connection for fire pump shall be direct from the meter board it shall have no on/off switch in between. The pressure should be maintaining 3.5 k.g. at Top most hydrant's connections.
11. WET RISER:- 01-Wet riser shall be provided in the bldg. which shall extend from the basement to the terrace floor. The internal hydrants.
The wet riser system and landing valves shall conform to is: code of practice.
12. 01-Way fire brigade inlets shall be provided in the block wet riser.

13. HOSE BOX:- A hose box near each internal hydrant shall be provided comprising of 2 x 15m. Length of 63 mm. rubber lined hose conforming to IS: 903-1984.
14. HOSE REEL:- A hose reel near each internal hydrants containing 30 m. of length of 25 mm. bore terminating into shut off nozzle of 08 mm.
Outlet connected directly to down comer shall be provided. This should conform to As per Latest Is:
15. PORTABLE FIRE EXTINGUISHERS: - The portable fire extinguishers of 4kg ABC/DCP and Co2 4.5 kg type shall be provided and marked on the plans. The number of the fire extinguishers may have to be increased later when the layout of the partition etc. in and maintained in accordance with IS: 15683
16. All vertical cable ducts/shafts and electrical niches on various floors of the building must be continuously monitored by fixed temperature heat detectors conforming to BIS Code of practice.
17. AUTOMATIC ALARM SMOKE DETECTOR HEAT DETECTOR GAS DETECTOR:-Should be fixed installation system should be reception to basement, theater banquet area, lobby area of all floor, all Room's per requirement for risk area (i.e.NBC code).
18. SMOKE VENTING SYSTEM:-The system shall be provided in the upper floors of Telephone Exchange building as per relevant code of practice.
19. YARD HYDRANTS: - The yard hydrants shall be provided as proposed in the complex as per specified BIS code of Practice.
20. SPRINKLER INSTALLATIONS:-Automatic sprinklers shall be installed in the Basement Building area. Flow alarm switch/gong shall be incorporated in the installation for giving provided near the testing facility. The entire system including pump capacity and head size of pipe net work, office size, source of water supply, provided in accordance to relevant code of practice/relevant rules (i.e. as TAC Rules / NFPA Code). Fire Services inlet shall also be provided at ground floor level.
21. MANUAL CALL POINTS:- Manual electrical call points at suitable locations on each floor of building shall be installed conforming to K-II.I.I. Of the unified building bye laws.
22. AIR CONDITIONING SYSTEM:- Following points must be ensured in respect of the air conditioning system :
 - (A) The ceiling and all its fixtures must be combustible material.
 - (B) Wherever the ducts pass through walls of floors the opening around the ducts must be sealed with fire resisting material. Air ducts must not pass through the staircase enclosures.
 - (C) The air filters of the air handing units must be of non combustible material. Air handling units must not be used for storage of any handling material.
 - (D) Fire dampers shall be provided in the ducts.
 - (E) Escape routes like staircase, corridors must not be used as return air passage.
23. LIGHTING PROTECTION:-The lighting protection system is conforming to IS: 2309 shall be provided in the building.

24. LIFT GROUNDING SWITCH:-The lifts must be equipped with fireman switch so that it is possible to ground all lifts during a fire emergency. In case of failure of normal supply it shall automatically trip over to the Alternate supply. Suitable arrangements such as providing slope in the floor of lift lobby shall be made to prevent water during fire fighting etc. at any landing room entering into the lift shaft. All other conditions as laid down in NBC Part - IV (D-1.5) shall also be followed.
25. CONTROL ROOM/SECURITY ROOM:- The control room / security room on the entrance of ground level with communication system to all floors and facilitate for receiving messages from different floors. Details of all floor plans along with the detail of firefighting equipment and installations shall be maintained in the control room.
26. HOUSE KEEPING:- To prevent the fire hazard, good housekeeping both inside and outside the building shall be strictly maintenance by MTNL authorities. The periodic inspection and maintenance of under floor space and false ceiling shall also be carried out to eliminate the fire risk.
27. GENERAL:- The fire prevention/fire safety measures recommended above cannot be effective unless these are backed by the administrative measures and the building, including the maintained in the top condition at times.
The building or part there of shall not be occupied unless compliance is ensured.
28. All the fire fighting system should be in accordance with the provision of Bombay provincial municipal corporation Act.1949 and National Building code Act.

Note:-1. After completion of above fire fighting system installation work and on The basis of Inspection of Chief Fire Officer NOC will be issued.




**I/C Chief Fire Officer
Fire & Emergency Services
Rajkot Municipal Corporation**

Copy to:-

1. T.P.O.

કલેક્ટર અને જિલ્લા મેજિસ્ટ્રેટની કચેરી, RAJKOT

સરનામું:- જિલ્લા કલેક્ટર ઓફીસ, શ્રોફ રોડ, સદર, રાજકોટ, ગુજરાત - ૩૬૦૦૦૧

ફોન:- +91 281 2473900 ફેક્સ નંબર +91 281 2453621

ઇ-મેઇલ:- chitnish-raj@gujarat.gov.in

હુકમ નંબર:- CB/NA/RAJKOT/Raiya-1/2/૨/1010120/2019

તારીખ:- 10/04/2019



વંચાણે લીધા:-

(૧) અરજદારશ્રી Shaileshbhai Premjibhai Malani and others ની તારીખ: '07/03/2019' ની અરજી તથા તારીખ: '07/03/2019' નું સોગંદનામું.

(૨) મુંબઈ જમીન મહેસૂલ કાયદો ૧૮૭૯ ની કલમ- ૪૮, ૬૫, ૬૬, તથા ૬૭.

(૩) ગુજરાત જમીન મહેસૂલ નિયમો, ૧૯૭૨ ના નિયમ-૮૧, ૧૦૦, ૧૦૧, ૧૦૨.

(૪) સરકારશ્રીના મહેસૂલ વિભાગનાં ઠરાવ ક્રમાંક: બખપ/૧૦૦૬/૪૨૫/૩ તા.૧/૭/૦૮.

(૫) સરકારશ્રીના મહેસૂલ વિભાગનાં પરિપત્ર ક્રમાંક: બખપ/૧૦૨૦૧૮/૨૨૭/૩ તા.૮/૫/૧૮.

(૬) નં. Revenue/1010120/RAJKOT/Rajkot City (West)/Raiya-1, તા. 27/03/2019

(૭) સરકારશ્રીના મહેસૂલ વિભાગનાં પરિપત્ર ક્રમાંક: બખપ/૧૦૨૦૧૮/૪૨૫/૩ તા.૧૬/૮/૧૮.

(૮) સરકારશ્રીના મહેસૂલ વિભાગનાં પરિપત્ર ક્રમાંક: બખપ/૧૦૨૦૧૫/૧૨૦૯/૩ તા. ૬/૯/૧૮.

હુકમ:-

વંચાણે લીધેલ કમ-(૧) ની અરજી તથા સોગંદનામા થી અરજદારશ્રી Shaileshbhai Premjibhai Malani and others , રહે c/o S P Patel Advocate Office No.16 Near Giriraj Hospital , Besides Prasang Hall, 150 Feet Ring Road, Rajkot, Rajkot, Rajkot Gujarat INDIA

એ મોજે: Raiya-1 , તા. Rajkot City (West) જિ RAJKOT ના સર્વે નંબર 2/૨ , ટીપી સ્કીમ નં 16 , એફપી નં 2, 6/1, 6/2, 7 ના ક્ષેત્રફળ: 10522.00 ચો.મી. પૈકી સબ પ્લોટ નં N.A. નું ક્ષેત્રફળ 6984.00 ચો.મી. જમીન અંગે મહેસૂલ કાયદાની હેઠળ બિનખેતી પરવાનગી મેળવવાની માંગણી કરેલ છે.

૨. સવાલવાળી જમીન અંગેના નમુના નં.૭-૧૨ કબજેદારની વિગત નીચે મુજબ છે.

સર્વે નંબર/ બ્લોક નંબર/ રી-સર્વે નંબર	ટીપી સ્કીમ નંબર	ફા.પ્લોટ નંબર	ક્ષેત્રફળ (ચો.મી.)	કબજેદારોના નામ
2/૨ /	16	2, 6/1, 6/2, 7	6984.00	Shaileshbhai Premjibhai Malani and others

૩. સવાલવાળી જમીન અંગેના રજુ થયેલ રેકર્ડ ની ચકાસણી કરતાં સદર જમીન હાલમાં જુની શરત સત્તાપ્રકારે ચાલતી આવે છે. તેમજ અરજદારે સોગંદનામામાં જાહેર કરેલ હકીકત તથા અન્ય આધાર પુરાવાઓ જોતાં મહેસૂલી ટાઇટલ ક્લીયર હોવાનું જણાતું હોય, બિનખેતી પરવાનગી આપવામાં વાંધાસરખું જણાતું ન હોય, હુકમના વંચાણે લીધેલ કમ નં. ૬માં જણાવેલ વિગતે અરજદારને રૂપાંતર કર, વિશેષધારો તથા અન્ય વેરાની રકમ સરકારશ્રીમાં ભરપાઇ કરવા ઓનલાઇન સિસ્ટમ દ્વારા તેઓને અરજીમાં દર્શાવેલ ઇલેક્ટ્રોનિક માધ્યમ દ્વારા ઓનલાઇન ચુકવણું કરવા જણ કરતાં, નીચે જણાવેલ વિગતેની રકમ ઓનલાઇન સિસ્ટમ દ્વારા અરજદારે સરકારશ્રીમાં જમા કરાવેલ હોવાનું જણાય છે.

બિનખેતી કરવાની થતી જમીનનું ક્ષેત્રફળ: 6984.00

ક્રમ	વિગત	રૂપાંતર કર/ બિનખેતી આકાર (દર ચો.મી. દીઠ)	વિગત			
			ચલણ/પહોંચ નંબર- તારીખ	પેમેન્ટ ની તારીખ	રકમ રૂ.	રકમ ભરપાઇ કર્યાનું સ્થળ
1	Rupantar Kar	6984.00 X 40.00 = 279360.00	100001048752	05/04/2019	279360.00	ONLINE
2	Vishesh Dhara	6984.00 X 0.60 = 4190.40	100001048752	05/04/2019	4190.40	ONLINE
3	Local Fund	6984.00 X 0.30 = 2095.20	100001048752	05/04/2019	2095.20	ONLINE

4	Shikshan Upkar	6984.00 X 0.15 = 1047.60	100001048752	05/04/2019	1047.60	ONLINE
---	-------------------	--------------------------	--------------	------------	---------	--------

૪. ઉપરોક્ત તમામ હકીકતો ધ્યાને લેતાં પેરા નં. ૨માં દર્શાવેલ જમીન સંબંધે નીચે જણાવેલ શરતોને આધીન જમીન મહેસૂલ કાયદા તથા હુકમના વંચાણે લીધેલ ક્રમ નં. ૪ તથા પમાં દર્શાવેલ સરકારશ્રીના વખતો વખતના ઠરાવ તથા પરિપત્રમાં જણાવેલ જોગવાઈઓને આધીન મલ્ટીપરપઝ / બહુ હેતુક હેતુ માટે બીનખેતી પરવાનગી આપવા આથી હુકમ કરવામાં આવે છે.

શરતો:-

- (૧) આ હુકમ મળ્યેથી બે માસમાં (પરંતુ અપીલ પીરીયડ પુરો થયા બાદ) “એમ” નમુનામાં સનદ કરી આપવી પડશે.
- (૨) જીલ્લા ઇન્સ્પેક્ટરશ્રી, જમીન રેકર્ડની કચેરીમાં માપણી ફી જમા કરાવવાની રહેશે. જથી માપણી કરી/કરાવી આ હુકમ આધારે તેમજ મંજૂર થયેલ પ્લાન મુજબ દરસ્તી પત્રક તૈયાર કરવાનું / કરાવવાનું રહેશે અને દરસ્તી પત્રકનો મહેસૂલી દફતરે અમલ થયા બાદ જ પ્રશ્નવાળી બિનખેતીની જમીન/પ્લોટનું રજી.દસ્તાવેજથી થયેલ વેચાણ વ્યવહારના અમલ માટે નોંધ પાડવાની રહેશે.
- (૩). અરજદારે પ્રતિ વર્ષે ખેતી સિવાયનો ધારો (બિનખેતી દર) હેતુ માટે દર ચો.મી.ના પૈસા પ્રમાણે રૂ. તેમજ નિયમ પ્રમાણે લોકલ ફંડ તથા શિક્ષણ ઉપકર ભરવો પડશે જે અંગેનો દર વખતોવખત ફેરફારને પાત્ર રહેશે.
- (૪) સંબંધિત નગરપાલિકા/ મહાનગરપાલિકા/શહેરી વિકાસ વિસ્તાર સત્તા મંડળ ધ્વારા મંજૂર કરેલા પ્લાન મુજબ બાંધકામ કરવાનું રહેશે અને હુકમ થયા તારીખથી ત્રણ વર્ષમાં બાંધકામ પૂર્ણ કરવાનું રહેશે.
- (૫) આ હુકમ જમીન મહેસૂલ કાયદાની કલમ-૬૭ તથા નિયમ-૧૦૦ ની જોગવાઈઓને આધારે કરેલ છે. તે સિવાય કબજેદારે અન્ય સંબંધિત કાયદાકીય પરવાનગી લેવાની થતી હશે તે તેમણે અલાયદી મેળવી લેવાની રહેશે.
- (૬) સરકારશ્રીના મહેસૂલ વિભાગના ઠરાવ નં.બખપ/૧૦૯૩/૧૦૫૨/ક તા.૧૩/૯/૯૩ માં ઠરાવ્યા મુજબ સહીયારા/કોમન પ્લોટ અને રસ્તાની જમીન સોસાયટીની માલિકીની અથવા સર્વે પ્લોટ હોલ્ડરની સહીયારી માલિકીની ગણાશે તે ઉપર મુજબ માલિકનો કોઇ હકક રહેશે નહીં.
- (૭) સરકારશ્રીના મહેસૂલ વિભાગના તા.૭/૮/૯૧ ના પરિપત્ર નં. બખપ-૧૦૯૧-૧૭૫૬-ક ની જોગવાઈ મુજબ બિન અધિકૃત બાંધકામ બાબતે બાંધકામ નિયંત્રણ કરતી સંબંધિત મહાનગરપાલિકા/શહેરી વિકાસ વિસ્તાર સત્તા મંડળએ ધોરણસરનાં પગલા લેવાના રહેશે.
- (૮) સદર જમીનમાંથી પેટ્રોલીયમ/પાણીની કે અન્ય કોઇપણ પ્રકારની પાઇપલાઇન પસાર થતી હશે તો તે સંદર્ભે વિકાસ પરવાનગી આપનાર ઓથોરીટીએ સંબંધિતો ના-વાંધા પ્રમાણપત્ર મેળવી વિકાસ પરવાનગી આપવાની રહેશે.
- (૯) સરકારશ્રીનાં મહેસૂલ વિભાગનાં તા.૧/૭/૨૦૦૮ ના ઠરાવ નં. બખપ/૧૦૦૬/૪૨૫/ક માં જણાવેલ નીચે મુજબની શરતોનું પાલન કરવાનું રહેશે.
 ૧. ડીસ્ટ્રીક્ટ ઇન્સ્પેક્ટર ઓફ લેન્ડ રેકર્ડ્સ ધ્વારા ઇસ્યુ કરાયેલ માપણી શીટ કે જેના ઉપર મૂળ ટિપ્પણની હદ પણ દર્શાવેલ હોવી જોઇએ. રજૂ કરાયેલ પ્લાન તથા લે-આઉટ પ્લાન સક્ષમ કક્ષાએ મંજૂર કરાયેલ હોવો જોઇએ.
 ૨. બાંધકામ શરૂ કરતા પહેલા બાંધકામનાં નકશા સક્ષમ અધિકારી પાસે મંજૂર કરાવવાના રહેશે. પરંતુ અરજદાર બિનખેતી પરવાનગી મેળવ્યા વગર આવા બાંધકામની રજાચિઠી મેળવી શકશે નહીં.
 ૩. શહેરી વિસ્તાર જ્યાં ટાઉન પ્લાનીંગ સ્કીમ મંજૂર થઇ ગઇ છે ત્યાં જી.ડી.સી.આર. અને ઝોનીંગના નિયમો અનુસાર બાંધકામ કરવાનું રહેશે.
 ૪. મંજૂર થયેલ નકશા મુજબ આરોગ્ય અને સ્વાસ્થ્યની દ્રષ્ટિએ ગંદા પાણીનાં નિકાલની જોગવાઈ કરવાની રહેશે.
 ૫. અરજદારે રીબન ડેવલપમેન્ટ રૂલ્સ નીચે જે તે રસ્તાનો પ્રકાર ધ્યાને લઇ રસ્તાના મધ્યભિદ્વથી બાંધકામ વચ્ચે અંતર જાળવવાનું રહેશે અન્યથા અરજદારની જવાબદારી થશે.
 ૬. ફ્લોર મીલ, સિનેમા/ટુરીંગ સિનેમા/થીયેટર માટે બિનખેતી પરવાનગીના કામે જીલ્લા મેજિસ્ટ્રેટની જરૂરી મંજૂરી મેળવી આગળની કાર્યવાહી કરવાની રહેશે.
 ૭. પેટ્રોલ, ડીઝલ, કેરોસીન, સી.એન.જી., એલ.પી.જી. પંપ નાંખવા માટે બિનખેતી પરવાનગીના કામે બાંધકામ શરૂ કરતાં પહેલા જિલ્લા મેજિસ્ટ્રેટની જરૂરી મંજૂરી મેળવી આગળની કાર્યવાહી કરવાની રહેશે.
 ૮. ઇન્ડીયન એક્સપ્લોઝીવ એક્ટ અન્વયે મેંગેનીઝ, ફાયર વર્ડ્સ, દારૂખાના માટે બિનખેતીની કાર્યવાહી કરતા પહેલા જીલ્લા મેજિસ્ટ્રેટની જરૂરી મંજૂરી મેળવી આગળની કાર્યવાહી કરવાની રહેશે.
 ૯. સવાલવાળી જમીન જો રેલવે હદની નજીક હોય તો રેલવેની હદથી (ટ્રીસ)૩૦ મીટર જગ્યા છોડી બાંધકામ કરવાનું રહેશે.
 ૧૦. સવાલવાળી જમીન ઉપરથી અથવા બાજુમાંથી વીજળી ગ્રીડના તાર/ હાઇટેન્શન પાવર અગર થાંભલા આવેલ હોય ત્યારે તે અન્વયે લાગુ પડતા નિયમોનું પાલન કરવા અને તે મુજબ બાંધકામ કરવાનું રહેશે.
 ૧૧. બિનખેતી માંગવામાં આવી હોય તેવી જમીન જો એરોડ્રામ આસપાસના ૨૦ કિ.મી. ની ત્રિજ્યામાં આવતી હોય ત્યારે બાંધકામની ઉંચાઇ તથા એરોડ્રામની દ્રષ્ટિએ જરૂરી એવું ના-વાંધા પ્રમાણપત્ર સીવીલ એવીએશન ખાતા પાસેથી મેળવવાનું રહેશે અને સીવીલ એવીએશન ખાતાના નિયમોનું પાલન કરવાનું રહેશે.
 ૧૨. ઓ.એન.જી.સી. ના કુવા નજીકમાં આવેલ જમીનના કિસ્સામાં અરજદારે સંબંધિત નિયમોનું પાલન કરવાનું રહેશે.
 ૧૩. નર્મદા કેનાલ/અન્ય સિંચાઇ કેનાલની નજીકમાં આવેલ જમીનની બાબતમાં અરજદારે સૂચિત બાંધકામ માટે જાળવવાના થતાં અંતર અંગેના નિયમોનું પાલન કરવાનું રહેશે.
 ૧૪. અરજદારે / જ્યાં જરૂરી હોય ત્યાં કેન્દ્ર સરકાર કે રાજ્ય સરકારના કાયદા નીચે રક્ષિત સ્મારક (Protected Monuments) તરીકે જાહેર કરેલ પ્રાચીન સ્મારકથી ૧૦૦ મીટર સુધીનું અંતર જાળવવાની પ્રવર્તમાન જોગવાઈઓનું પાલન કરવાનું રહેશે.
- (૧૦) પ્રશ્નવાળી જમીનમાં નગરપાલિકા/મહાનગરપાલિકા/શહેરી વિકાસ વિસ્તાર સત્તા મંડળ ધ્વારા જે શરતોએ પરવાનગી આપવામાં આવશે તે શરતોનું પાલન તથા બાંધકામ કરવાનું રહેશે.

(૧૧) આ જમીનમાં વરસાદી પાણીના ભુગર્ભ વહન એટલે કે સંચય માટે દર મકાન/બહુમાળી મકાન દીઠ એકના દરે આ જમીનમાં ઉપર પરકોલેટીંગ બોરવેલની વ્યવસ્થા અચૂક કરવાની રહેશે તથા વરસાદી પાણીના નિકાલની વ્યવસ્થા કરીને બાંધકામ કરવાનું રહેશે.
 (૧૨) અરજદાર ધ્વારા બિનખેતી પરવાનગીની માંગણીવાળી જમીનને નગરપાલિકાના હયાત રોડથી ઓછામાં ઓછા ૧૨ મી. નો. એપ્રોચ રોડ મળે છે તે મુજબની ખાતરી આપવાની રહેશે.
 (૧૩) પ્રશ્નવાળી જમીનમાં સ્થળે થયેલ બાંધકામ સ્થાનિક સ્વરાજની સંસ્થાના નિયમોનુસાર નહિં હોય તો સ્થાનિક સ્વરાજની સંસ્થા નિયમોનુસાર કાર્યવાહી કરી શકશે. તેમાં આ હુકમથી બાધ આવશે નહીં.

અરજદારે ઉપરોક્ત શરતોનું ચુસ્તપણે પાલન કરવાનું રહેશે. જો તેમાં નિષ્ફળ જશે તો શરતભંગ ગણી સક્ષમ અધિકારી કાયદેસરની કાર્યવાહી કરશે.

(૧૪) ઉપરની કોઇપણ શરતનો ભંગ થયેથી જમીન મહેસૂલ કાયદાની કલમ-૬૭ મુજબ શિક્ષાત્મક પગલા લેવામાં આવશે તેમજ બીજી કોઇપણ શિક્ષાને પાત્ર હશે તો તેને બાધ આપ્યા સિવાય કે જે ફરમાવવાનું યોગ્ય લાગે તે પ્રમાણે દંડ અથવા આકાર લઇ સદરહુ જમીનનો કબજો કબજેદાર પાસે ચાલુ રહેવા દઇ શકાશે.

(૧૫) ઉપરોક્ત શરતોમાં ગમે તે મજબૂર હોય તેમ છતાં, કલેક્ટરશ્રી સદરહુ હુકમ વિરુદ્ધ બાંધેલ ૧ અથવા વધારાના કોઇપણ મકાન અથવા ઈમલારને કલેક્ટરશ્રીએ આ અર્થે જે મુદત ઠરાવી હોય તે મુદત દરમિયાન તેવી રીતે ખસેડવામાં ન આવે કે સુચવ્યા મુજબ ફેરફાર ન કરવામાં આવે તો તેમ કરવામાં જે ખર્ચ થાય તે કબજેદાર પાસેથી જમીન મહેસૂલની બાકી તરીકે વસુલ કરવાને મુખત્યાર છે.

(૧૬) આ પરવાનગી અરજદારે રજૂ કરેલ વિગતોને આધારે આપવામાં આવેલ છે. રજૂ થયેલ કોઇ વિગત ખોટી હોવાનું જાહેર થયેથી કે ઉપરની કોઇપણ શરતોનો ભંગ થયેથી આ પરવાનગી આપો આપ રદ થયેલી ગણાશે તથા સોગંદનામાં દર્શાવેલ કાયદા હેઠળની જોગવાઈ હેઠળ પગલાં લેવાને પાત્ર રહેશે અને તત્કાલિન અમલમાં હોય તેવા બીજા કોઇપણ કાયદાની જોગવાઈઓના બાધ વિના ઇન્ડિયન પીનલ કોડ હેઠળ ફોજદારી ગુના માટે શિક્ષાત્મક પગલા લેવાને પાત્ર બનશે તથા જમીન મહેસૂલ કાયદો તથા નિયમોની જોગવાઈ અનુસાર યોગ્ય તે શિક્ષાત્મક કાર્યવાહી કરવામાં આવશે અને બાંધકામ દુર કરવા કે સરકાર સંપ્રાપ્ત સહીતના એક કે વધુ પગલાં લેવાશે.


(૧૭) પ્રકરણે રજૂ થયેલ ગામ નમુના નં. ૭/૧૨ના રેકર્ડ ચાલતાં ખાતેદારને તેણે ધારણ કરેલ હુકમમાં દર્શાવેલ જમીનમાં ફક્ત ખેતી સિવાયના ઉપયોગ કરવાની પરવાનગી આપતો સદર હુકમ કરેલ છે જેનાથી ટાઇટલ / માલિકીપણાના હક્ક પ્રસ્થાપિત થતાં નથી કે સદર હુકમથી આ કાયદો કે તેને અંતર્ગત નિયમો કે અન્ય કોઇ પ્રવર્તમાન કાયદા હેઠળ ચાલતાં કે ભવિષ્યમાં ઉપસ્થિત થનાર લીટીગેશનનો બાધ રહેશે નહીં.

(૧૮) પ્રકરણે રજૂ થયેલ હકીકત ૧ દસ્તાવેજી પુરાવાને આધારે પરવાનગી આપવામાં આવેલ છે. ભવિષ્યમાં કોઇ પુરાવો કે અન્ય કોઇ વિપરીત બાબત ધ્યાનમાં આવશે તો મુંબઇ જનરલ ક્લોઝીઝ એક્ટની જોગવાઈઓ હેઠળ આપમેળે સદર પરવાનગી રદ કરી શકાશે.

વધુમાં, ઉપર્યુક્ત શરતોને આધિન અરજદાર ધ્વારા રજૂ થયેલ સોગંદનામાની વિગતોમાં તેઓ ધ્વારા જાહેર કરેલી હકીકતોને આધારે સવાલવાળી જમીનના બિનખેતી ઉપયોગ માટે પરવાનગી આપવામાં આવે છે.

તારીખ:- 10/04/2019

રાજકોટ જિલ્લા
મામલતદાર બિનખેતી
રાજકોટ જિલ્લા
10/4/2019



સહી (ડો. રાહુલ ગુપ્તા)
કલેક્ટર, RAJKOT

RPAD
પ્રતિ,

૧. અરજદારશ્રી Shaileshbhai Premjibhai Malani and others

રહે. c/o S P Patel Advocate Office No.16 Near Giriraj Hospital, Besides Prasang Hall, 150 Feet Ring Road, Rajkot, Rajkot Gujarat INDIA

નકલ રવાના.

મામલતદારશ્રી. રાજકોટ શહેર (પશ્ચિમ)

જિલા જમીન નિરીક્ષકશ્રી RAJKOT

તલાટી કમ મન્ત્રીશ્રી. રેયા-૧, મામલતદાર કચેરી, રાજકોટ શહેર (પશ્ચિમ)

સેલેક્ટ ફાઇલ

સાહેબ. વી.કે. શાહ
ના. સામ દી.દરા મમ્મી
રાજકોટ (પશ્ચિમ)